



AIR MONITORING SUMMARY

Airsafe conducted air monitoring for airborne asbestos fibres at the 55247 Liverpool Hospital Carpark site for the period of 1st March 2021- 31st March 2021.

The following table provides a summary of any exceedances during the air monitoring period.

Date of Exceedance	Exceedance Data	Cause of Exceedance	Project Response
Nil	Nil	Nil	Nil

The results and criteria can be found on the test result reports.

Liverpool Hospital Carpark - 75 Elizabeth Street, Liverpool - MARCH

Eastern Monitor Location			
DATE	RESULT	FIELDS	FIBRES
01.03.21	0	100	0
02.03.21	0	100	0
03.03.21	0	100	0
04.03.21	0	100	0
05.03.21	0	100	0
06.03.21	0	100	0
08.03.21	0	100	0
09.03.21	0	100	0
10.03.21	0	100	0
11.03.21	0	100	0
12.03.21	0	100	0
13.03.21	0	100	0
15.03.21	0	100	0
16.03.21	0	100	0
17.03.21	0	100	0
18.03.21	0	100	0
25.03.21	0	100	0
26.03.21	0	100	0
29.03.21	0	100	0
30.03.21	0	100	0
31.03.21	0	100	0

Liverpool Hospital Carpark - 75 Elizabeth Street, Liverpool - MARCH

Northern Monitor Location			
DATE	RESULT	FIELDS	FIBRES
01.03.21	0	100	0
02.03.21	0	100	0
03.03.21	0	100	0
04.03.21	0	100	0
05.03.21	0	100	0
06.03.21	0	100	0
08.03.21	0	100	0
09.03.21	0	100	0
10.03.21	0	100	0
11.03.21	0	100	0
12.03.21	0	100	0
13.03.21	0	100	0
15.03.21	0	100	0
16.03.21	0	100	0
17.03.21	0	100	0
18.03.21	0	100	0
25.03.21	0	100	0
26.03.21	0	100	0
29.03.21	0	100	0
30.03.21	0	100	0
31.03.21	0	100	0

Liverpool Hospital Carpark - 75 Elizabeth Street, Liverpool - MARCH

Southern Monitor Location			
DATE	RESULT	FIELDS	FIBRES
01.03.21	0	100	0
02.03.21	0	100	0
03.03.21	0	100	0
04.03.21	0	100	0
05.03.21	0	100	0
06.03.21	0	100	0
08.03.21	0	100	0
09.03.21	0	100	0
10.03.21	0	100	0
11.03.21	0	100	0
12.03.21	0	100	0
13.03.21	0	100	0
15.03.21	0	100	0
16.03.21	0	100	0
17.03.21	0	100	0
18.03.21	0	100	0
25.03.21	0	100	0
26.03.21	0	100	0
29.03.21	0	100	0
30.03.21	0	100	0
31.03.21	0	100	0

Liverpool Hospital Carpark - 75 Elizabeth Street, Liverpool - MARCH

Western Monitor Location			
DATE	RESULT	FIELDS	FIBRES
01.03.21	0	100	0
02.03.21	0	100	0
03.03.21	0	100	0
04.03.21	0	100	0
05.03.21	0	100	0
06.03.21	0	100	0
08.03.21	0	100	0
09.03.21	0	100	0
10.03.21	0	100	0
11.03.21	0	100	0
12.03.21	0	100	0
13.03.21	0	100	0
15.03.21	0	100	0
16.03.21	0	100	0
17.03.21	0	100	0
18.03.21	0	100	0
25.03.21	0	100	0
26.03.21	0	100	0
29.03.21	0	100	0
30.03.21	0	100	0
31.03.21	0	100	0

TEST REPORT

March 2, 2021

Jeffsann Excavations
457 Castlereagh Road,
AGNES BANKS NSW 2753

Your Reference: Liverpool Hospital Carpark
Job Number: 55247

Attention: Hadi Farahpour

Dear Hadi

In accordance with your instructions, Airsafe conducted air monitoring for airborne asbestos fibres at the above site.

The following samples were processed on the dates indicated.

Samples:	4 Filters
Date of Sampling:	01/02/21
Date of Analysis:	02/03/21
Date of Preliminary Report Sent:	Not Issued

The results are contained in the following pages of this report.

Should you have any queries regarding this report please contact the undersigned.

Yours faithfully
AIRSAFE OHC PTY LTD



Huy Tran
Approved Counter and Signatory

PROJECT: Liverpool Hospital Carpark

JOB NO: 55247

Sample No	Location/Reference	Time		Total Time [min]	Air Flow Average [L/min]	Fields	Fibres	Concentration (Fibres/mL)
		On	Off					
55247 – 83	Site Perimeter timber boarder, adjacent carpark – West of Works	0700	1500	480	2.0	100	0	<0.01
55247 – 84	Site Fencing Adjacent High School – North of Works	0701	1501	480	2.0	100	0	<0.01
55247 – 85	Site perimeter fencing, adjacent footpath – East of Works	0702	1502	480	2.0	100	0	<0.01
55247 – 86	Fence Adjacent Site Offices – Southwest of Works	0703	1503	480	2.0	100	0	<0.01

Method: Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC: 3003 (2005)] and in-house method AS101 – Membrane Filter Method for Estimating Airborne Asbestos Fibres.

Sampling: All samples have been taken by Airsafe personnel in accordance with the sampling plan detailed in method AS101.

Quality Control: A field blank is taken and analysed for each batch of samples.

Environmental Conditions: Background Air Monitoring

Comment: These calculated concentrations are less than the reporting limit of 0.01 fibres/mL for control and exposure monitoring as stated in the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC: 3003 (2005)].

Disclaimer: N/A

Note: Times are provided for customer reference only and do not form part of the facility’s accreditation for volume measurement.

The results relate only to the samples tested. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards.

Airsafe shall not be liable for loss, cost, damages or expenses incurred by the client, or any other person or company, resulting from the use of any information or interpretation given in this report. In no case shall Airsafe be liable for consequential damages including, but not limited to, lost profits, damages for failure to meet deadlines and lost production arising from this report.

Any other holder of this document is advised that information contained hereon reflects Airsafe’s findings at the time of its intervention only and within the limits of Client’s instructions, if any. The Airsafe’s sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents

TEST REPORT

March 3, 2021

Jeffsann Excavations
457 Castlereagh Road,
AGNES BANKS NSW 2753

Your Reference: Liverpool Hospital Carpark
Job Number: 55247

Attention: Hadi Farahpour

Dear Hadi

In accordance with your instructions, Airsafe conducted air monitoring for airborne asbestos fibres at the above site.

The following samples were processed on the dates indicated.

Samples:	4 Filters
Date of Sampling:	02/02/21
Date of Analysis:	03/03/21
Date of Preliminary Report Sent:	Not Issued

The results are contained in the following pages of this report.

Should you have any queries regarding this report please contact the undersigned.

Yours faithfully
AIRSAFE OHC PTY LTD



Huy Tran
Approved Counter and Signatory

PROJECT: Liverpool Hospital Carpark

JOB NO: 55247

Sample No	Location/Reference	Time		Total Time [min]	Air Flow Average [L/min]	Fields	Fibres	Concentration (Fibres/mL)
		On	Off					
55247 – 87	Site Perimeter timber boarder, adjacent carpark – West of Works	0700	1500	480	2.0	100	0	<0.01
55247 – 88	Site Fencing Adjacent High School – North of Works	0701	1501	480	2.0	100	0	<0.01
55247 – 89	Site perimeter fencing, adjacent footpath – East of Works	0702	1502	480	2.0	100	0	<0.01
55247 – 90	Fence Adjacent Site Offices – Southwest of Works	0703	1503	480	2.0	100	0	<0.01

Method: Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC: 3003 (2005)] and in-house method AS101 – Membrane Filter Method for Estimating Airborne Asbestos Fibres.

Sampling: All samples have been taken by Airsafe personnel in accordance with the sampling plan detailed in method AS101.

Quality Control: A field blank is taken and analysed for each batch of samples.

Environmental Conditions: Background Air Monitoring

Comment: These calculated concentrations are less than the reporting limit of 0.01 fibres/mL for control and exposure monitoring as stated in the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC: 3003 (2005)].

Disclaimer: N/A

Note: Times are provided for customer reference only and do not form part of the facility's accreditation for volume measurement.

The results relate only to the samples tested. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards.

Airsafe shall not be liable for loss, cost, damages or expenses incurred by the client, or any other person or company, resulting from the use of any information or interpretation given in this report. In no case shall Airsafe be liable for consequential damages including, but not limited to, lost profits, damages for failure to meet deadlines and lost production arising from this report.

Any other holder of this document is advised that information contained hereon reflects Airsafe's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Airsafe's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents

TEST REPORT

March 8, 2021

Jeffsann Excavations
457 Castlereagh Road,
AGNES BANKS NSW 2753

Your Reference: Liverpool Hospital Carpark
Job Number: 55247

Attention: Hadi Farahpour

Dear Hadi

In accordance with your instructions, Airsafe conducted air monitoring for airborne asbestos fibres at the above site.

The following samples were processed on the dates indicated.

Samples:	4 Filters
Date of Sampling:	03/03/21
Date of Analysis:	08/03/21
Date of Preliminary Report Sent:	Not Issued

The results are contained in the following pages of this report.

Should you have any queries regarding this report please contact the undersigned.

Yours faithfully
AIRSAFE OHC PTY LTD



Huy Tran
Approved Counter and Signatory

PROJECT: Liverpool Hospital Carpark

JOB NO: 55247

Sample No	Location/Reference	Time		Total Time [min]	Air Flow Average [L/min]	Fields	Fibres	Concentration (Fibres/mL)
		On	Off					
55247 – 91	Site Perimeter timber boarder, adjacent carpark – West of Works	0700	1500	480	2.0	100	0	<0.01
55247 – 92	Site Fencing Adjacent High School – North of Works	0701	1501	480	2.0	100	0	<0.01
55247 – 93	Site perimeter fencing, adjacent footpath – East of Works	0702	1502	480	2.0	100	0	<0.01
55247 – 94	Fence Adjacent Site Offices – Southwest of Works	0703	1503	480	2.0	100	0	<0.01

Method: Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC: 3003 (2005)] and in-house method AS101 – Membrane Filter Method for Estimating Airborne Asbestos Fibres.

Sampling: All samples have been taken by Airsafe personnel in accordance with the sampling plan detailed in method AS101.

Quality Control: A field blank is taken and analysed for each batch of samples.

Environmental Conditions: Background Air Monitoring

Comment: These calculated concentrations are less than the reporting limit of 0.01 fibres/mL for control and exposure monitoring as stated in the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC: 3003 (2005)].

Disclaimer: N/A

Note: Times are provided for customer reference only and do not form part of the facility's accreditation for volume measurement.

The results relate only to the samples tested. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards.

Airsafe shall not be liable for loss, cost, damages or expenses incurred by the client, or any other person or company, resulting from the use of any information or interpretation given in this report. In no case shall Airsafe be liable for consequential damages including, but not limited to, lost profits, damages for failure to meet deadlines and lost production arising from this report.

Any other holder of this document is advised that information contained hereon reflects Airsafe's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Airsafe's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents

TEST REPORT

March 8, 2021

Jeffsann Excavations
457 Castlereagh Road,
AGNES BANKS NSW 2753

Your Reference: Liverpool Hospital Carpark
Job Number: 55247

Attention: Hadi Farahpour

Dear Hadi

In accordance with your instructions, Airsafe conducted air monitoring for airborne asbestos fibres at the above site.

The following samples were processed on the dates indicated.

Samples:	4 Filters
Date of Sampling:	04/03/21
Date of Analysis:	08/03/21
Date of Preliminary Report Sent:	Not Issued

The results are contained in the following pages of this report.

Should you have any queries regarding this report please contact the undersigned.

Yours faithfully
AIRSAFE OHC PTY LTD



Huy Tran
Approved Counter and Signatory

PROJECT: Liverpool Hospital Carpark

JOB NO: 55247

Sample No	Location/Reference	Time		Total Time [min]	Air Flow Average [L/min]	Fields	Fibres	Concentration (Fibres/mL)
		On	Off					
55247 – 95	Site Perimeter timber boarder, adjacent carpark – West of Works	0715	1515	480	2.0	100	0	<0.01
55247 – 96	Site Fencing Adjacent High School – North of Works	0716	1516	480	2.0	100	0	<0.01
55247 – 97	Site perimeter fencing, adjacent footpath – East of Works	0717	1517	480	2.0	100	0	<0.01
55247 – 98	Fence Adjacent Site Offices – Southwest of Works	0718	1518	480	2.0	100	0	<0.01

Method: Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC: 3003 (2005)] and in-house method AS101 – Membrane Filter Method for Estimating Airborne Asbestos Fibres.

Sampling: All samples have been taken by Airsafe personnel in accordance with the sampling plan detailed in method AS101.

Quality Control: A field blank is taken and analysed for each batch of samples.

Environmental Conditions: Background Air Monitoring

Comment: These calculated concentrations are less than the reporting limit of 0.01 fibres/mL for control and exposure monitoring as stated in the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC: 3003 (2005)].

Disclaimer: N/A

Note: Times are provided for customer reference only and do not form part of the facility's accreditation for volume measurement.

The results relate only to the samples tested. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards.

Airsafe shall not be liable for loss, cost, damages or expenses incurred by the client, or any other person or company, resulting from the use of any information or interpretation given in this report. In no case shall Airsafe be liable for consequential damages including, but not limited to, lost profits, damages for failure to meet deadlines and lost production arising from this report.

Any other holder of this document is advised that information contained hereon reflects Airsafe's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Airsafe's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents

TEST REPORT

March 8, 2021

Jeffsann Excavations
457 Castlereagh Road,
AGNES BANKS NSW 2753

Your Reference: Liverpool Hospital Carpark
Job Number: 55247

Attention: Hadi Farahpour

Dear Hadi

In accordance with your instructions, Airsafe conducted air monitoring for airborne asbestos fibres at the above site.

The following samples were processed on the dates indicated.

Samples:	4 Filters
Date of Sampling:	05/03/21
Date of Analysis:	08/03/21
Date of Preliminary Report Sent:	Not Issued

The results are contained in the following pages of this report.

Should you have any queries regarding this report please contact the undersigned.

Yours faithfully
AIRSAFE OHC PTY LTD



Huy Tran
Approved Counter and Signatory

PROJECT: Liverpool Hospital Carpark

JOB NO: 55247

Sample No	Location/Reference	Time		Total Time [min]	Air Flow Average [L/min]	Fields	Fibres	Concentration (Fibres/mL)
		On	Off					
55247 – 99	Site Perimeter timber boarder, adjacent carpark – West of Works	0710	1510	480	2.0	100	0	<0.01
55247 – 100	Site Fencing Adjacent High School – North of Works	0711	1511	480	2.0	100	0	<0.01
55247 – 101	Site perimeter fencing, adjacent footpath – East of Works	0712	1512	480	2.0	100	0	<0.01
55247 – 102	Fence Adjacent Site Offices – Southwest of Works	0713	1513	480	2.0	100	0	<0.01

Method: Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC: 3003 (2005)] and in-house method AS101 – Membrane Filter Method for Estimating Airborne Asbestos Fibres.

Sampling: All samples have been taken by Airsafe personnel in accordance with the sampling plan detailed in method AS101.

Quality Control: A field blank is taken and analysed for each batch of samples.

Environmental Conditions: Background Air Monitoring

Comment: These calculated concentrations are less than the reporting limit of 0.01 fibres/mL for control and exposure monitoring as stated in the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC: 3003 (2005)].

Disclaimer: N/A

Note: Times are provided for customer reference only and do not form part of the facility's accreditation for volume measurement.

The results relate only to the samples tested. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards.

Airsafe shall not be liable for loss, cost, damages or expenses incurred by the client, or any other person or company, resulting from the use of any information or interpretation given in this report. In no case shall Airsafe be liable for consequential damages including, but not limited to, lost profits, damages for failure to meet deadlines and lost production arising from this report.

Any other holder of this document is advised that information contained hereon reflects Airsafe's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Airsafe's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents

TEST REPORT

March 8, 2021

Jeffsann Excavations
457 Castlereagh Road,
AGNES BANKS NSW 2753

Your Reference: Liverpool Hospital Carpark
Job Number: 56101

Attention: Hadi Farahpour

Dear Hadi

In accordance with your instructions, Airsafe conducted air monitoring for airborne asbestos fibres at the above site.

The following samples were processed on the dates indicated.

Samples:	4 Filters
Date of Sampling:	06/03/21
Date of Analysis:	08/03/21
Date of Preliminary Report Sent:	Not Issued

The results are contained in the following pages of this report.

Should you have any queries regarding this report please contact the undersigned.

Yours faithfully
AIRSAFE OHC PTY LTD



Huy Tran
Approved Counter and Signatory

PROJECT: Liverpool Hospital Carpark

JOB NO: 56101

Sample No	Location/Reference	Time		Total Time [min]	Air Flow Average [L/min]	Fields	Fibres	Concentration (Fibres/mL)
		On	Off					
56101 – 01	Site Perimeter timber boarder, adjacent carpark – West of Works	0710	1510	480	2.0	100	0	<0.01
56101 – 02	Site Fencing Adjacent High School – North of Works	0711	1511	480	2.0	100	0	<0.01
56101 – 03	Site perimeter fencing, adjacent footpath – East of Works	0712	1512	480	2.0	100	0	<0.01
56101 – 04	Fence Adjacent Site Offices – Southwest of Works	0713	1513	480	2.0	100	0	<0.01

Method: Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC: 3003 (2005)] and in-house method AS101 – Membrane Filter Method for Estimating Airborne Asbestos Fibres.

Sampling: All samples have been taken by Airsafe personnel in accordance with the sampling plan detailed in method AS101.

Quality Control: A field blank is taken and analysed for each batch of samples.

Environmental Conditions: Background Air Monitoring

Comment: These calculated concentrations are less than the reporting limit of 0.01 fibres/mL for control and exposure monitoring as stated in the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC: 3003 (2005)].

Disclaimer: N/A

Note: Times are provided for customer reference only and do not form part of the facility’s accreditation for volume measurement.

The results relate only to the samples tested. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards.

Airsafe shall not be liable for loss, cost, damages or expenses incurred by the client, or any other person or company, resulting from the use of any information or interpretation given in this report. In no case shall Airsafe be liable for consequential damages including, but not limited to, lost profits, damages for failure to meet deadlines and lost production arising from this report.

Any other holder of this document is advised that information contained hereon reflects Airsafe’s findings at the time of its intervention only and within the limits of Client’s instructions, if any. The Airsafe’s sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents

TEST REPORT

March 9, 2021

Jeffsann Excavations
457 Castlereagh Road,
AGNES BANKS NSW 2753

Your Reference: Liverpool Hospital Carpark
Job Number: 55247

Attention: Hadi Farahpour

Dear Hadi

In accordance with your instructions, Airsafe conducted air monitoring for airborne asbestos fibres at the above site.

The following samples were processed on the dates indicated.

Samples:	4 Filters
Date of Sampling:	08/03/21
Date of Analysis:	09/03/21
Date of Preliminary Report Sent:	Not Issued

The results are contained in the following pages of this report.

Should you have any queries regarding this report please contact the undersigned.

Yours faithfully
AIRSAFE OHC PTY LTD



Huy Tran
Approved Counter and Signatory

PROJECT: Liverpool Hospital Carpark

JOB NO: 55247

Sample No	Location/Reference	Time		Total Time [min]	Air Flow Average [L/min]	Fields	Fibres	Concentration (Fibres/mL)
		On	Off					
55247 – 103	Site Perimeter timber boarder, adjacent carpark – West of Works	0715	1515	480	2.0	100	0	<0.01
55247 – 104	Site Fencing Adjacent High School – North of Works	0716	1516	480	2.0	100	0	<0.01
55247 – 105	Site perimeter fencing, adjacent footpath – East of Works	0717	1517	480	2.0	100	0	<0.01
55247 – 106	Fence Adjacent Site Offices – Southwest of Works	0718	1518	480	2.0	100	0	<0.01

Method: Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC: 3003 (2005)] and in-house method AS101 – Membrane Filter Method for Estimating Airborne Asbestos Fibres.

Sampling: All samples have been taken by Airsafe personnel in accordance with the sampling plan detailed in method AS101.

Quality Control: A field blank is taken and analysed for each batch of samples.

Environmental Conditions: Background Air Monitoring

Comment: These calculated concentrations are less than the reporting limit of 0.01 fibres/mL for control and exposure monitoring as stated in the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC: 3003 (2005)].

Disclaimer: N/A

Note: Times are provided for customer reference only and do not form part of the facility's accreditation for volume measurement.

The results relate only to the samples tested. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards.

Airsafe shall not be liable for loss, cost, damages or expenses incurred by the client, or any other person or company, resulting from the use of any information or interpretation given in this report. In no case shall Airsafe be liable for consequential damages including, but not limited to, lost profits, damages for failure to meet deadlines and lost production arising from this report.

Any other holder of this document is advised that information contained hereon reflects Airsafe's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Airsafe's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents

TEST REPORT

March 10, 2021

Jeffsann Excavations
457 Castlereagh Road,
AGNES BANKS NSW 2753

Your Reference: Liverpool Hospital Carpark
Job Number: 55247

Attention: Hadi Farahpour

Dear Hadi

In accordance with your instructions, Airsafe conducted air monitoring for airborne asbestos fibres at the above site.

The following samples were processed on the dates indicated.

Samples:	4 Filters
Date of Sampling:	09/03/21
Date of Analysis:	10/03/21
Date of Preliminary Report Sent:	Not Issued

The results are contained in the following pages of this report.

Should you have any queries regarding this report please contact the undersigned.

Yours faithfully
AIRSAFE OHC PTY LTD



Huy Tran
Approved Counter and Signatory

PROJECT: Liverpool Hospital Carpark

JOB NO: 55247

Sample No	Location/Reference	Time		Total Time [min]	Air Flow Average [L/min]	Fields	Fibres	Concentration (Fibres/mL)
		On	Off					
55247 – 107	Site Perimeter timber boarder, adjacent carpark – West of Works	0725	1525	480	2.0	100	0	<0.01
55247 – 108	Site Fencing Adjacent High School – North of Works	0726	1526	480	2.0	100	0	<0.01
55247 – 109	Site perimeter fencing, adjacent footpath – East of Works	0727	1527	480	2.0	100	0	<0.01
55247 – 110	Fence Adjacent Site Offices – Southwest of Works	0728	1528	480	2.0	100	0	<0.01

Method: Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC: 3003 (2005)] and in-house method AS101 – Membrane Filter Method for Estimating Airborne Asbestos Fibres.

Sampling: All samples have been taken by Airsafe personnel in accordance with the sampling plan detailed in method AS101.

Quality Control: A field blank is taken and analysed for each batch of samples.

Environmental Conditions: Background Air Monitoring

Comment: These calculated concentrations are less than the reporting limit of 0.01 fibres/mL for control and exposure monitoring as stated in the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC: 3003 (2005)].

Disclaimer: N/A

Note: Times are provided for customer reference only and do not form part of the facility's accreditation for volume measurement.

The results relate only to the samples tested. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards.

Airsafe shall not be liable for loss, cost, damages or expenses incurred by the client, or any other person or company, resulting from the use of any information or interpretation given in this report. In no case shall Airsafe be liable for consequential damages including, but not limited to, lost profits, damages for failure to meet deadlines and lost production arising from this report.

Any other holder of this document is advised that information contained hereon reflects Airsafe's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Airsafe's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents

TEST REPORT

March 11, 2021

Jeffsann Excavations
457 Castlereagh Road,
AGNES BANKS NSW 2753

Your Reference: Liverpool Hospital Carpark
Job Number: 55247

Attention: Hadi Farahpour

Dear Hadi

In accordance with your instructions, Airsafe conducted air monitoring for airborne asbestos fibres at the above site.

The following samples were processed on the dates indicated.

Samples:	4 Filters
Date of Sampling:	10/03/21
Date of Analysis:	11/03/21
Date of Preliminary Report Sent:	Not Issued

The results are contained in the following pages of this report.

Should you have any queries regarding this report please contact the undersigned.

Yours faithfully
AIRSAFE OHC PTY LTD



Huy Tran
Approved Counter and Signatory

PROJECT: Liverpool Hospital Carpark

JOB NO: 55247

Sample No	Location/Reference	Time		Total Time [min]	Air Flow Average [L/min]	Fields	Fibres	Concentration (Fibres/mL)
		On	Off					
55247 – 111	Site Perimeter timber boarder, adjacent carpark – West of Works	0725	1525	480	2.0	100	0	<0.01
55247 – 112	Site Fencing Adjacent High School – North of Works	0726	1526	480	2.0	100	0	<0.01
55247 – 113	Site perimeter fencing, adjacent footpath – East of Works	0727	1527	480	2.0	100	0	<0.01
55247 – 114	Fence Adjacent Site Offices – Southwest of Works	0728	1528	480	2.0	100	0	<0.01

Method: Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC: 3003 (2005)] and in-house method AS101 – Membrane Filter Method for Estimating Airborne Asbestos Fibres.

Sampling: All samples have been taken by Airsafe personnel in accordance with the sampling plan detailed in method AS101.

Quality Control: A field blank is taken and analysed for each batch of samples.

Environmental Conditions: Background Air Monitoring

Comment: These calculated concentrations are less than the reporting limit of 0.01 fibres/mL for control and exposure monitoring as stated in the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC: 3003 (2005)].

Disclaimer: N/A

Note: Times are provided for customer reference only and do not form part of the facility’s accreditation for volume measurement.

The results relate only to the samples tested. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards.

Airsafe shall not be liable for loss, cost, damages or expenses incurred by the client, or any other person or company, resulting from the use of any information or interpretation given in this report. In no case shall Airsafe be liable for consequential damages including, but not limited to, lost profits, damages for failure to meet deadlines and lost production arising from this report.

Any other holder of this document is advised that information contained hereon reflects Airsafe’s findings at the time of its intervention only and within the limits of Client’s instructions, if any. The Airsafe’s sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents

TEST REPORT

March 15, 2021

Jeffsann Excavations
457 Castlereagh Road,
AGNES BANKS NSW 2753

Your Reference: Liverpool Hospital Carpark
Job Number: 55247

Attention: Hadi Farahpour

Dear Hadi

In accordance with your instructions, Airsafe conducted air monitoring for airborne asbestos fibres at the above site.

The following samples were processed on the dates indicated.

Samples:	4 Filters
Date of Sampling:	11/03/21
Date of Analysis:	15/03/21
Date of Preliminary Report Sent:	Not Issued

The results are contained in the following pages of this report.

Should you have any queries regarding this report please contact the undersigned.

Yours faithfully
AIRSAFE OHC PTY LTD



Huy Tran
Approved Counter and Signatory

PROJECT: Liverpool Hospital Carpark

JOB NO: 55247

Sample No	Location/Reference	Time		Total Time [min]	Air Flow Average [L/min]	Fields	Fibres	Concentration (Fibres/mL)
		On	Off					
55247 – 115	Site Perimeter timber boarder, adjacent carpark – West of Works	0725	1525	480	2.0	100	0	<0.01
55247 – 116	Site Fencing Adjacent High School – North of Works	0726	1526	480	2.0	100	0	<0.01
55247 – 117	Site perimeter fencing, adjacent footpath – East of Works	0727	1527	480	2.0	100	0	<0.01
55247 – 118	Fence Adjacent Site Offices – Southwest of Works	0728	1528	480	2.0	100	0	<0.01

Method: Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC: 3003 (2005)] and in-house method AS101 – Membrane Filter Method for Estimating Airborne Asbestos Fibres.

Sampling: All samples have been taken by Airsafe personnel in accordance with the sampling plan detailed in method AS101.

Quality Control: A field blank is taken and analysed for each batch of samples.

Environmental Conditions: Background Air Monitoring

Comment: These calculated concentrations are less than the reporting limit of 0.01 fibres/mL for control and exposure monitoring as stated in the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC: 3003 (2005)].

Disclaimer: N/A

Note: Times are provided for customer reference only and do not form part of the facility's accreditation for volume measurement.

The results relate only to the samples tested. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards.

Airsafe shall not be liable for loss, cost, damages or expenses incurred by the client, or any other person or company, resulting from the use of any information or interpretation given in this report. In no case shall Airsafe be liable for consequential damages including, but not limited to, lost profits, damages for failure to meet deadlines and lost production arising from this report.

Any other holder of this document is advised that information contained hereon reflects Airsafe's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Airsafe's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents

TEST REPORT

March 15, 2021

Jeffsann Excavations
457 Castlereagh Road,
AGNES BANKS NSW 2753

Your Reference: Liverpool Hospital Carpark
Job Number: 55247

Attention: Hadi Farahpour

Dear Hadi

In accordance with your instructions, Airsafe conducted air monitoring for airborne asbestos fibres at the above site.

The following samples were processed on the dates indicated.

Samples:	4 Filters
Date of Sampling:	12/03/21
Date of Analysis:	15/03/21
Date of Preliminary Report Sent:	Not Issued

The results are contained in the following pages of this report.

Should you have any queries regarding this report please contact the undersigned.

Yours faithfully
AIRSAFE OHC PTY LTD



Huy Tran
Approved Counter and Signatory

PROJECT: Liverpool Hospital Carpark

JOB NO: 55247

Sample No	Location/Reference	Time		Total Time [min]	Air Flow Average [L/min]	Fields	Fibres	Concentration (Fibres/mL)
		On	Off					
55247 – 119	Site Perimeter timber boarder, adjacent carpark – West of Works	0710	1510	480	2.0	100	0	<0.01
55247 – 120	Site Fencing Adjacent High School – North of Works	0711	1511	480	2.0	100	0	<0.01
55247 – 121	Site perimeter fencing, adjacent footpath – East of Works	0712	1512	480	2.0	100	0	<0.01
55247 – 122	Fence Adjacent Site Offices – Southwest of Works	0713	1513	480	2.0	100	0	<0.01

Method: Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC: 3003 (2005)] and in-house method AS101 – Membrane Filter Method for Estimating Airborne Asbestos Fibres.

Sampling: All samples have been taken by Airsafe personnel in accordance with the sampling plan detailed in method AS101.

Quality Control: A field blank is taken and analysed for each batch of samples.

Environmental Conditions: Background Air Monitoring

Comment: These calculated concentrations are less than the reporting limit of 0.01 fibres/mL for control and exposure monitoring as stated in the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC: 3003 (2005)].

Disclaimer: N/A

Note: Times are provided for customer reference only and do not form part of the facility's accreditation for volume measurement.

The results relate only to the samples tested. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards.

Airsafe shall not be liable for loss, cost, damages or expenses incurred by the client, or any other person or company, resulting from the use of any information or interpretation given in this report. In no case shall Airsafe be liable for consequential damages including, but not limited to, lost profits, damages for failure to meet deadlines and lost production arising from this report.

Any other holder of this document is advised that information contained hereon reflects Airsafe's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Airsafe's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents

TEST REPORT

March 16, 2021

Jeffsann Excavations
457 Castlereagh Road,
AGNES BANKS NSW 2753

Your Reference: Liverpool Hospital Carpark
Job Number: 55247

Attention: Hadi Farahpour

Dear Hadi

In accordance with your instructions, Airsafe conducted air monitoring for airborne asbestos fibres at the above site.

The following samples were processed on the dates indicated.

Samples:	4 Filters
Date of Sampling:	13/03/21
Date of Analysis:	15/03/21
Date of Preliminary Report Sent:	Not Issued

The results are contained in the following pages of this report.

Should you have any queries regarding this report please contact the undersigned.

Yours faithfully
AIRSAFE OHC PTY LTD



Huy Tran
Approved Counter and Signatory

PROJECT: Liverpool Hospital Carpark

JOB NO: 55247

Sample No	Location/Reference	Time		Total Time [min]	Air Flow Average [L/min]	Fields	Fibres	Concentration (Fibres/mL)
		On	Off					
55247 – 123	Site Perimeter timber boarder, adjacent carpark – West of Works	0710	1510	480	2.0	100	0	<0.01
55247 – 124	Site Fencing Adjacent High School – North of Works	0711	1511	480	2.0	100	0	<0.01
55247 – 125	Site perimeter fencing, adjacent footpath – East of Works	0712	1512	480	2.0	100	0	<0.01
55247 – 126	Fence Adjacent Site Offices – Southwest of Works	0713	1513	480	2.0	100	0	<0.01

Method: Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC: 3003 (2005)] and in-house method AS101 – Membrane Filter Method for Estimating Airborne Asbestos Fibres.

Sampling: All samples have been taken by Airsafe personnel in accordance with the sampling plan detailed in method AS101.

Quality Control: A field blank is taken and analysed for each batch of samples.

Environmental Conditions: Background Air Monitoring

Comment: These calculated concentrations are less than the reporting limit of 0.01 fibres/mL for control and exposure monitoring as stated in the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC: 3003 (2005)].

Disclaimer: N/A

Note: Times are provided for customer reference only and do not form part of the facility’s accreditation for volume measurement.

The results relate only to the samples tested. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards.

Airsafe shall not be liable for loss, cost, damages or expenses incurred by the client, or any other person or company, resulting from the use of any information or interpretation given in this report. In no case shall Airsafe be liable for consequential damages including, but not limited to, lost profits, damages for failure to meet deadlines and lost production arising from this report.

Any other holder of this document is advised that information contained hereon reflects Airsafe’s findings at the time of its intervention only and within the limits of Client’s instructions, if any. The Airsafe’s sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents

TEST REPORT

March 16, 2021

Jeffsann Excavations
457 Castlereagh Road,
AGNES BANKS NSW 2753

Your Reference: Liverpool Hospital Carpark
Job Number: 55247

Attention: Hadi Farahpour

Dear Hadi

In accordance with your instructions, Airsafe conducted air monitoring for airborne asbestos fibres at the above site.

The following samples were processed on the dates indicated.

Samples:	4 Filters
Date of Sampling:	15/03/21
Date of Analysis:	16/03/21
Date of Preliminary Report Sent:	Not Issued

The results are contained in the following pages of this report.

Should you have any queries regarding this report please contact the undersigned.

Yours faithfully
AIRSAFE OHC PTY LTD



Huy Tran
Approved Counter and Signatory

PROJECT: Liverpool Hospital Carpark

JOB NO: 55247

Sample No	Location/Reference	Time		Total Time [min]	Air Flow Average [L/min]	Fields	Fibres	Concentration (Fibres/mL)
		On	Off					
55247 – 127	Site Perimeter timber boarder, adjacent carpark – West of Works	0710	1510	480	2.0	100	0	<0.01
55247 – 128	Site Fencing Adjacent High School – North of Works	0711	1511	480	2.0	100	0	<0.01
55247 – 129	Site perimeter fencing, adjacent footpath – East of Works	0712	1512	480	2.0	100	0	<0.01
55247 – 130	Fence Adjacent Site Offices – Southwest of Works	0713	1513	480	2.0	100	0	<0.01

Method: Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC: 3003 (2005)] and in-house method AS101 – Membrane Filter Method for Estimating Airborne Asbestos Fibres.

Sampling: All samples have been taken by Airsafe personnel in accordance with the sampling plan detailed in method AS101.

Quality Control: A field blank is taken and analysed for each batch of samples.

Environmental Conditions: Background Air Monitoring

Comment: These calculated concentrations are less than the reporting limit of 0.01 fibres/mL for control and exposure monitoring as stated in the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC: 3003 (2005)].

Disclaimer: N/A

Note: Times are provided for customer reference only and do not form part of the facility’s accreditation for volume measurement.

The results relate only to the samples tested. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards.

Airsafe shall not be liable for loss, cost, damages or expenses incurred by the client, or any other person or company, resulting from the use of any information or interpretation given in this report. In no case shall Airsafe be liable for consequential damages including, but not limited to, lost profits, damages for failure to meet deadlines and lost production arising from this report.

Any other holder of this document is advised that information contained hereon reflects Airsafe’s findings at the time of its intervention only and within the limits of Client’s instructions, if any. The Airsafe’s sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents

TEST REPORT

March 17, 2021

Jeffsann Excavations
457 Castlereagh Road,
AGNES BANKS NSW 2753

Your Reference: Liverpool Hospital Carpark
Job Number: 55247

Attention: Hadi Farahpour

Dear Hadi

In accordance with your instructions, Airsafe conducted air monitoring for airborne asbestos fibres at the above site.

The following samples were processed on the dates indicated.

Samples:	4 Filters
Date of Sampling:	16/03/21
Date of Analysis:	17/03/21
Date of Preliminary Report Sent:	Not Issued

The results are contained in the following pages of this report.

Should you have any queries regarding this report please contact the undersigned.

Yours faithfully
AIRSAFE OHC PTY LTD



Huy Tran
Approved Counter and Signatory

PROJECT: Liverpool Hospital Carpark

JOB NO: 55247

Sample No	Location/Reference	Time		Total Time [min]	Air Flow Average [L/min]	Fields	Fibres	Concentration (Fibres/mL)
		On	Off					
55247 – 131	Site Perimeter timber boarder, adjacent carpark – West of Works	0710	1510	480	2.0	100	0	<0.01
55247 – 132	Site Fencing Adjacent High School – North of Works	0711	1511	480	2.0	100	0	<0.01
55247 – 133	Site perimeter fencing, adjacent footpath – East of Works	0712	1512	480	2.0	100	0	<0.01
55247 – 134	Fence Adjacent Site Offices – Southwest of Works	0713	1513	480	2.0	100	0	<0.01

Method: Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC: 3003 (2005)] and in-house method AS101 – Membrane Filter Method for Estimating Airborne Asbestos Fibres.

Sampling: All samples have been taken by Airsafe personnel in accordance with the sampling plan detailed in method AS101.

Quality Control: A field blank is taken and analysed for each batch of samples.

Environmental Conditions: Background Air Monitoring

Comment: These calculated concentrations are less than the reporting limit of 0.01 fibres/mL for control and exposure monitoring as stated in the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC: 3003 (2005)].

Disclaimer: N/A

Note: Times are provided for customer reference only and do not form part of the facility’s accreditation for volume measurement.

The results relate only to the samples tested. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards.

Airsafe shall not be liable for loss, cost, damages or expenses incurred by the client, or any other person or company, resulting from the use of any information or interpretation given in this report. In no case shall Airsafe be liable for consequential damages including, but not limited to, lost profits, damages for failure to meet deadlines and lost production arising from this report.

Any other holder of this document is advised that information contained hereon reflects Airsafe’s findings at the time of its intervention only and within the limits of Client’s instructions, if any. The Airsafe’s sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents

TEST REPORT

March 18, 2021

Jeffsann Excavations
457 Castlereagh Road,
AGNES BANKS NSW 2753

Your Reference: Liverpool Hospital Carpark
Job Number: 55247

Attention: Hadi Farahpour

Dear Hadi

In accordance with your instructions, Airsafe conducted air monitoring for airborne asbestos fibres at the above site.

The following samples were processed on the dates indicated.

Samples:	4 Filters
Date of Sampling:	17/03/21
Date of Analysis:	18/03/21
Date of Preliminary Report Sent:	Not Issued

The results are contained in the following pages of this report.

Should you have any queries regarding this report please contact the undersigned.

Yours faithfully
AIRSAFE OHC PTY LTD



Huy Tran
Approved Counter and Signatory

PROJECT: Liverpool Hospital Carpark

JOB NO: 55247

Sample No	Location/Reference	Time		Total Time [min]	Air Flow Average [L/min]	Fields	Fibres	Concentration (Fibres/mL)
		On	Off					
55247 – 135	Site Perimeter timber boarder, adjacent carpark – West of Works	0710	1510	480	2.0	100	0	<0.01
55247 – 136	Site Fencing Adjacent High School – North of Works	0711	1511	480	2.0	100	0	<0.01
55247 – 137	Site perimeter fencing, adjacent footpath – East of Works	0712	1512	480	2.0	100	0	<0.01
55247 – 138	Fence Adjacent Site Offices – Southwest of Works	0713	1513	480	2.0	100	0	<0.01

Method: Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC: 3003 (2005)] and in-house method AS101 – Membrane Filter Method for Estimating Airborne Asbestos Fibres.

Sampling: All samples have been taken by Airsafe personnel in accordance with the sampling plan detailed in method AS101.

Quality Control: A field blank is taken and analysed for each batch of samples.

Environmental Conditions: Background Air Monitoring

Comment: These calculated concentrations are less than the reporting limit of 0.01 fibres/mL for control and exposure monitoring as stated in the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC: 3003 (2005)].

Disclaimer: N/A

Note: Times are provided for customer reference only and do not form part of the facility’s accreditation for volume measurement.

The results relate only to the samples tested. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards.

Airsafe shall not be liable for loss, cost, damages or expenses incurred by the client, or any other person or company, resulting from the use of any information or interpretation given in this report. In no case shall Airsafe be liable for consequential damages including, but not limited to, lost profits, damages for failure to meet deadlines and lost production arising from this report.

Any other holder of this document is advised that information contained hereon reflects Airsafe’s findings at the time of its intervention only and within the limits of Client’s instructions, if any. The Airsafe’s sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents

TEST REPORT

March 26, 2021

Jeffsann Excavations
457 Castlereagh Road,
AGNES BANKS NSW 2753

Your Reference: Liverpool Hospital Carpark
Job Number: 55247

Attention: Hadi Farahpour

Dear Hadi

In accordance with your instructions, Airsafe conducted air monitoring for airborne asbestos fibres at the above site.

The following samples were processed on the dates indicated.

Samples:	4 Filters
Date of Sampling:	25/03/21
Date of Analysis:	26/03/21
Date of Preliminary Report Sent:	Not Issued

The results are contained in the following pages of this report.

Should you have any queries regarding this report please contact the undersigned.

Yours faithfully
AIRSAFE OHC PTY LTD



Huy Tran
Approved Counter and Signatory

PROJECT: Liverpool Hospital Carpark

JOB NO: 55247

Sample No	Location/Reference	Time		Total Time [min]	Air Flow Average [L/min]	Fields	Fibres	Concentration (Fibres/mL)
		On	Off					
55247 – 139	Site Perimeter timber boarder, adjacent carpark – West of Works	0710	1510	480	2.0	100	0	<0.01
55247 – 140	Site Fencing Adjacent High School – North of Works	0711	1511	480	2.0	100	0	<0.01
55247 – 141	Site perimeter fencing, adjacent footpath – East of Works	0712	1512	480	2.0	100	0	<0.01
55247 – 142	Fence Adjacent Site Offices – Southwest of Works	0713	1513	480	2.0	100	0	<0.01

Method: Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC: 3003 (2005)] and in-house method AS101 – Membrane Filter Method for Estimating Airborne Asbestos Fibres.

Sampling: All samples have been taken by Airsafe personnel in accordance with the sampling plan detailed in method AS101.

Quality Control: A field blank is taken and analysed for each batch of samples.

Environmental Conditions: Background Air Monitoring

Comment: These calculated concentrations are less than the reporting limit of 0.01 fibres/mL for control and exposure monitoring as stated in the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC: 3003 (2005)].

Disclaimer: N/A

Note: Times are provided for customer reference only and do not form part of the facility’s accreditation for volume measurement.

The results relate only to the samples tested. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards.

Airsafe shall not be liable for loss, cost, damages or expenses incurred by the client, or any other person or company, resulting from the use of any information or interpretation given in this report. In no case shall Airsafe be liable for consequential damages including, but not limited to, lost profits, damages for failure to meet deadlines and lost production arising from this report.

Any other holder of this document is advised that information contained hereon reflects Airsafe’s findings at the time of its intervention only and within the limits of Client’s instructions, if any. The Airsafe’s sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents

TEST REPORT

March 26, 2021

Jeffsann Excavations
457 Castlereagh Road,
AGNES BANKS NSW 2753

Your Reference: Liverpool Hospital Carpark
Job Number: 55247

Attention: Hadi Farahpour

Dear Hadi

In accordance with your instructions, Airsafe conducted air monitoring for airborne asbestos fibres at the above site.

The following samples were processed on the dates indicated.

Samples:	4 Filters
Date of Sampling:	25/03/21
Date of Analysis:	26/03/21
Date of Preliminary Report Sent:	Not Issued

The results are contained in the following pages of this report.

Should you have any queries regarding this report please contact the undersigned.

Yours faithfully
AIRSAFE OHC PTY LTD



Huy Tran
Approved Counter and Signatory

PROJECT: Liverpool Hospital Carpark

JOB NO: 55247

Sample No	Location/Reference	Time		Total Time [min]	Air Flow Average [L/min]	Fields	Fibres	Concentration (Fibres/mL)
		On	Off					
55247 – 139	Site Perimeter timber boarder, adjacent carpark – West of Works	0710	1510	480	2.0	100	0	<0.01
55247 – 140	Site Fencing Adjacent High School – North of Works	0711	1511	480	2.0	100	0	<0.01
55247 – 141	Site perimeter fencing, adjacent footpath – East of Works	0712	1512	480	2.0	100	0	<0.01
55247 – 142	Fence Adjacent Site Offices – Southwest of Works	0713	1513	480	2.0	100	0	<0.01

Method: Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC: 3003 (2005)] and in-house method AS101 – Membrane Filter Method for Estimating Airborne Asbestos Fibres.

Sampling: All samples have been taken by Airsafe personnel in accordance with the sampling plan detailed in method AS101.

Quality Control: A field blank is taken and analysed for each batch of samples.

Environmental Conditions: Background Air Monitoring

Comment: These calculated concentrations are less than the reporting limit of 0.01 fibres/mL for control and exposure monitoring as stated in the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC: 3003 (2005)].

Disclaimer: N/A

Note: Times are provided for customer reference only and do not form part of the facility’s accreditation for volume measurement.

The results relate only to the samples tested. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards.

Airsafe shall not be liable for loss, cost, damages or expenses incurred by the client, or any other person or company, resulting from the use of any information or interpretation given in this report. In no case shall Airsafe be liable for consequential damages including, but not limited to, lost profits, damages for failure to meet deadlines and lost production arising from this report.

Any other holder of this document is advised that information contained hereon reflects Airsafe’s findings at the time of its intervention only and within the limits of Client’s instructions, if any. The Airsafe’s sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents

TEST REPORT

March 26, 2021

Jeffsann Excavations
457 Castlereagh Road,
AGNES BANKS NSW 2753

Your Reference: Liverpool Hospital Carpark
Job Number: 55247

Attention: Hadi Farahpour

Dear Hadi

In accordance with your instructions, Airsafe conducted air monitoring for airborne asbestos fibres at the above site.

The following samples were processed on the dates indicated.

Samples:	4 Filters
Date of Sampling:	26/03/21
Date of Analysis:	29/03/21
Date of Preliminary Report Sent:	Not Issued

The results are contained in the following pages of this report.

Should you have any queries regarding this report please contact the undersigned.

Yours faithfully
AIRSAFE OHC PTY LTD



Huy Tran
Approved Counter and Signatory

PROJECT: Liverpool Hospital Carpark

JOB NO: 55247

Sample No	Location/Reference	Time		Total Time [min]	Air Flow Average [L/min]	Fields	Fibres	Concentration (Fibres/mL)
		On	Off					
55247 – 143	Site Perimeter timber boarder, adjacent carpark – West of Works	0710	1510	480	2.0	100	0	<0.01
55247 – 144	Site Fencing Adjacent High School – North of Works	0711	1511	480	2.0	100	0	<0.01
55247 – 145	Site perimeter fencing, adjacent footpath – East of Works	0712	1512	480	2.0	100	0	<0.01
55247 – 146	Fence Adjacent Site Offices – Southwest of Works	0713	1513	480	2.0	100	0	<0.01

Method: Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC: 3003 (2005)] and in-house method AS101 – Membrane Filter Method for Estimating Airborne Asbestos Fibres.

Sampling: All samples have been taken by Airsafe personnel in accordance with the sampling plan detailed in method AS101.

Quality Control: A field blank is taken and analysed for each batch of samples.

Environmental Conditions: Background Air Monitoring

Comment: These calculated concentrations are less than the reporting limit of 0.01 fibres/mL for control and exposure monitoring as stated in the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC: 3003 (2005)].

Disclaimer: N/A

Note: Times are provided for customer reference only and do not form part of the facility’s accreditation for volume measurement.

The results relate only to the samples tested. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards.

Airsafe shall not be liable for loss, cost, damages or expenses incurred by the client, or any other person or company, resulting from the use of any information or interpretation given in this report. In no case shall Airsafe be liable for consequential damages including, but not limited to, lost profits, damages for failure to meet deadlines and lost production arising from this report.

Any other holder of this document is advised that information contained hereon reflects Airsafe’s findings at the time of its intervention only and within the limits of Client’s instructions, if any. The Airsafe’s sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents