

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

02 March 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.14-AAM1.v1-01/03/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 01/03/2022
Sample Analysis Date: 02/03/2022
Period of Sampling: 01/03/2022 07:04 AM - 01/03/2022 03:07 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 25, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092**Site number:** 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.14/S379/010322	MSCP site, temp fencing, adj. decon unit	0.0/100	<0.01
S110355.14/S382/010322	MSCP site, Labyrinth Way site sheds, fencing	0.0/100	<0.01
S110355.14/S764/010322	MSCP site, walkway to hospital entrance, southeast end, fencing	0.0/100	<0.01
S110355.14/S02/010322	MSCP site, south end, adj. small courtyard, fencing	0.0/100	<0.01
S110355.14/S103/010322	Blank	0.0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

Analysed and reported by:

Alexandar Mitevski
Analyst



Rune Knoph
Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

02 March 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

02 March 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

03 March 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.15-AAM1.v1-02/03/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 02/03/2022
Sample Analysis Date: 03/03/2022
Period of Sampling: 02/03/2022 07:05 AM - 02/03/2022 03:09 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 25, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.15/S978/020322	MSCP site, temp fencing, adj. decon unit	1.0/100	<0.01
S110355.15/S487/020322	MSCP site, Labyrinth Way site sheds, fencing	0.0/100	<0.01
S110355.15/S408/020322	MSCP site, walkway to hospital entrance, southeast end, fencing	0.0/100	<0.01
S110355.15/S090/020322	MSCP site, south end, adj. small courtyard, fencing	0.0/100	<0.01
S110355.15/S101/020322	Blank	0.0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

Analysed and reported by:


Alexandar Mitevski
Analyst



Rune Knoph
Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

03 March 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

03 March 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

Accredited for compliance
with ISO/IEC 17025 -
Testing

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.16-AAM1.v1-04/03/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 04/03/2022
Sample Analysis Date: 07/03/2022
Period of Sampling: 04/03/2022 09:05 AM - 04/03/2022 02:35 PM
Scope of Work: Air monitoring during civil works with asbestos impacted soil.
SWE Laboratory: Suite 25, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.16/S851/040322	MSCP site, Corner of Labyrinth Way and Redbank Road, fencing	0.0/100	<0.01
S110355.16/S973/040322	MSCP site, northwest end of site, adj old maintenance car park, fencing	0.0/100	<0.01
S110355.16/S740/040322	MSCP site, southeast end of site, adj site sheds, fencing	0.0/100	<0.01
S110355.16/S925/040322	MSCP site, southwest end, adj. small courtyard, fencing	1.0/100	<0.01
S110355.16/S111/040322	Blank	0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

Analysed and reported by:



Alexandar Mitevski
Analyst



Rune Knoph
Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

07 March 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

Accredited for compliance
with ISO/IEC 17025 -
Testing

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.17-AAM1.v1-05/03/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 05/03/2022
Sample Analysis Date: 07/03/2022
Period of Sampling: 05/03/2022 07:00 AM - 05/03/2022 03:00 PM
Scope of Work: Air monitoring during civil works with asbestos impacted soil.
SWE Laboratory: Suite 25, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.17/S525/050322	MSCP site, Corner of Labyrinth Way and Redbank Road, fencing	0/100	<0.01
S110355.17/S140/050322	MSCP site, northwest end of site, adj old maintenance car park, fencing	0/100	<0.01
S110355.17/S529/050322	MSCP site, southeast end of site, adj site sheds, fencing	0/100	<0.01
S110355.17/S102/050322	MSCP site, southwest end, adj. small courtyard, fencing	0/100	<0.01
S110355.17/S110/050322	Blank	0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

Analysed and reported by:



Alexandar Mitevski
Analyst



Rune Knoph
Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

07 March 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

Accredited for compliance
with ISO/IEC 17025 -
Testing

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.18-AAM1.v1-07/03/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 07/03/2022
Sample Analysis Date: 08/03/2022
Period of Sampling: 07/03/2022 07:10 AM - 07/03/2022 03:13 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 25, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.18/S979/070322	MSCP site, Corner of Labyrinth Way and Redbank Road, fencing	0/100	<0.01
S110355.18/S538/070322	MSCP site, northwest end of site, adj old maintenance car park, fencing	0/100	<0.01
S110355.18/S520/070322	MSCP site, southeast end of site, adj site sheds, fencing	0/100	<0.01
S110355.18/S200/070322	MSCP site, southwest end, adj. small courtyard, fencing	0/100	<0.01
S110355.18/S103/070322	Blank	0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

Analysed and reported by:



Alexandar Mitevski
Analyst



Rune Knoph
Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

08 March 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

Accredited for compliance
with ISO/IEC 17025 -
Testing

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: Danny.Khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.19-AAM1.v1-08/03/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 08/03/2022
Sample Analysis Date: 09/03/2022
Period of Sampling: 08/03/2022 07:00 AM - 08/03/2022 03:05 PM
Scope of Work: Control monitoring for asbestos fibres
SWE Laboratory: Suite 25, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.19/S852/080322	MSCP site, Corner of Labyrinth Way and Redbank Road, fencing	0.0/100	<0.01
S110355.19/S291/080322	MSCP site, northwest end of site, adj old maintenance car park, fencing	VOID*	VOID*
S110355.19/S082/080322	MSCP site, southwest end, adj. small courtyard, fencing	VOID*	VOID*
S110355.19/S849/080322	MSCP site, southeast end of site, adj site sheds, fencing	1.0/100	<0.01
S110355.19/S000/080322	Field Blank	0.0/100	NA

*Filter voided due to water ingress

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

Analysed and reported by:



Karl Grovenor
Analyst



Rune Knoph
Approved Issuer of Report

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

09 March 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: miguel.canas@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

Accredited for compliance
with ISO/IEC 17025 -
Testing

SWE Report Reference: S110355.20-AAM1.v1-09/03/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 09/03/2022
Sample Analysis Date: 10/03/2022
Period of Sampling: 09/03/2022 07:01 AM - 09/03/2022 03:06 PM
Scope of Work: Control monitoring for asbestos fibres
SWE Laboratory: Suite 25, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.20/S795/090322	MSCP site, Corner of Labyrinth Way and Redbank Road, fencing	0.0/100	<0.01
S110355.20/S059/090322	MSCP site, northwest end of site, adj old maintenance car park, fencing	0.0/100	<0.01
S110355.20/S886/090322	MSCP site, southeast end of site, adj site sheds, fencing	0.0/100	<0.01
S110355.20/S190/090322	MSCP site, southwest end, adj. small courtyard, fencing	0.0/100	<0.01
S110355.20/S081/090322	Field Blank	0.0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

Analysed and reported by:



Karl Grovenor
Analyst



Rune Knoph
Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

10 March 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

11 March 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: miguel.canas@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.21-AAM1.v1-10/03/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 10/03/2022
Sample Analysis Date: 11/03/2022
Period of Sampling: 10/03/2022 07:01 AM - 10/03/2022 03:12 PM
Scope of Work: Control monitoring for asbestos fibres
SWE Laboratory: Suite 25, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.21/S498/100322	MSCP site, northwest end of site, adj old maintenance car park, fencing	0.0/100	<0.01
S110355.21/S009/100322	MSCP site, Corner of Labyrinth Way and Redbank Road, fencing	0.0/100	<0.01
S110355.21/S581/100322	MSCP site, southeast end of site, adj site sheds, fencing	1.0/100	<0.01
S110355.21/S153/100322	MSCP site, southwest end, adj. small courtyard, fencing	2.0/100	<0.01
S110355.21/S206/100322	Redbank Road realignment, adjacent crossing, on fence	0.0/100	<0.01
S110355.21/S902/100322	Redbank Road realignment, adjacent decon, on fence	1.0/100	<0.01
S110355.21/S000/100322	Field Blank	0.0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

11 March 2022

Analysed and reported by:



Karl Grovenor
Analyst



Rune Knoph
Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

11 March 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

11 March 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

14 March 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.22-AAM1.v1-11/03/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 11/03/2022
Sample Analysis Date: 14/03/2022
Period of Sampling: 11/03/2022 07:00 AM - 11/03/2022 02:30 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 25, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.22/S002/110322	MSCP site, northwest end of site, adj old maintenance car park, fencing	0.0/100	<0.01
S110355.22/S724/110322	MSCP site, Corner of Labyrinth Way and Redbank Road, fencing	1.0/100	<0.01
S110355.22/S340/110322	MSCP site, southeast end of site, adj site sheds, fencing	0.0/100	<0.01
S110355.22/S757/110322	MSCP site, southwest end, adj. small courtyard, fencing	0.0/100	<0.01
S110355.22/S945/110322	Redbank Road realignment, adjacent crossing, on fence	2.0/100	<0.01
S110355.22/S494/110322	Redbank Road realignment, adjacent decon, on fence	0.0/100	<0.01
S110355.22/S110/110322	Blank	0.0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

14 March 2022

Analysed and reported by:



Alexandar Mitevski
Analyst



Rune Knoph
Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

14 March 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

14 March 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

14 March 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.23-AAM1.v1-12/03/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 12/03/2022
Sample Analysis Date: 14/03/2022
Period of Sampling: 12/03/2022 07:00 AM - 12/03/2022 03:00 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 25, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.23/S465/120322	MSCP site, northwest end of site, adj old maintenance car park, fencing	0.0/100	<0.01
S110355.23/S237/120322	MSCP site, Corner of Labyrinth Way and Redbank Road, fencing	0.0/100	<0.01
S110355.23/S895/120322	MSCP site, southeast end of site, adj site sheds, fencing	0.0/100	<0.01
S110355.23/S583/120322	MSCP site, southwest end, adj. small courtyard, fencing	0.0/100	<0.01
S110355.23/S898/120322	Redbank Road realignment, adjacent crossing, on fence	1.0/100	<0.01
S110355.23/S192/120322	Redbank Road realignment, adjacent decon, on fence	0.0/100	<0.01
S110355.23/S110/120322	Blank	0.0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

14 March 2022

Analysed and reported by:



Alexandar Mitevski
Analyst



Rune Knoph
Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

14 March 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

14 March 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

15 March 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.24-AAM1.v1-14/03/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 14/03/2022
Sample Analysis Date: 15/03/2022
Period of Sampling: 14/03/2022 07:11 AM - 14/03/2022 03:15 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 25, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092**Site number:** 18665

1. Introduction: Asbestos air samples were collected by client and submitted to the Safe Work and Environments Pty Ltd (SWE) laboratory for analysis by the membrane filter mount and count methodology. The volume measurement sampling was carried out by a SWE approved trained third party, (Ford Civil Contracting Pty Ltd), and SWE is responsible for the NATA endorsed results and data herein relied upon.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.24/S083/140322	MSCP site, northwest end of site, adj old maintenance car park, fencing	0.0/100	<0.01
S110355.24/S962/140322	MSCP site, Corner of Labyrinth Way and Redbank Road, fencing	0.0/100	<0.01
S110355.24/S183/140322	MSCP site, southeast end of site, adj site sheds, fencing	0.0/100	<0.01
S110355.24/S780/140322	MSCP site, southwest end, adj. small courtyard, fencing	1.0/100	<0.01
S110355.24/S576/140322	Redbank Road realignment, adjacent crossing, on fence	0.0/100	<0.01
S110355.24/S146/140322	Redbank Road realignment, adjacent decon, on fence	0.0/100	<0.01
S110355.24/S110/140322	Blank	0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

15 March 2022

Analysed and reported by:



Alexandar Mitevski
Analyst



Rune Knoph
Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

15 March 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

15 March 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

16 March 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.25-AAM1.v1-15/03/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 15/03/2022
Sample Analysis Date: 16/03/2022
Period of Sampling: 15/03/2022 07:05 AM - 15/03/2022 03:10 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 25, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.25/S106/150322	MSCP site, southwest end, adj. small courtyard, fencing	1.0/100	<0.01
S110355.25/S160/150322	MSCP site, southeast end of site, adj site sheds, fencing	0.0/100	<0.01
S110355.25/P21/150322	MSCP site, Corner of Labyrinth Way and Redbank Road, fencing	2.0/100	<0.01
S110355.25/S946/150322	MSCP site, northwest end of site, adj old maintenance car park, fencing	0.0/100	<0.01
S110355.25/S620/150322	PSB site, northern end, fencing along Redbank Rd.	0.0/100	<0.01
S110355.25/S626/150322	PSB site, western end, fencing along CASB loading dock.	0.0/100	<0.01
S110355.25/S199/150322	PSB site, southern end, fencing along laneway.	0.0/100	<0.01
S110355.25/S192/150322	PSB site, eastern end, fencing behind site sheds	1.0/100	<0.01
S110355.25/S110/150322	Blank	0.0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

16 March 2022

Analysed and reported by:



Alexandar Mitevski
Analyst



Rune Knoph
Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

16 March 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

16 March 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

17 March 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.26-AAM1.v1-16/03/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 16/03/2022
Sample Analysis Date: 17/03/2022
Period of Sampling: 16/03/2022 07:06 AM - 16/03/2022 03:12 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 25, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.26/S807/160322	MSCP site, southwest end, adj. small courtyard, fencing	1.0/100	<0.01
S110355.26/S408/160322	MSCP site, southeast end of site, adj site sheds, fencing	0.0/100	<0.01
S110355.26/S824/160322	MSCP site, Corner of Labyrinth Way and Redbank Road, fencing	3.0/100	<0.01
S110355.26/S384/160322	MSCP site, northwest end of site, adj old maintenance car park, fencing	1.0/100	<0.01
S110355.26/S482/160322	PSB site, northern end, fencing along Redbank Rd.	0.0/100	<0.01
S110355.26/S339/160322	PSB site, western end, fencing along CASB loading dock.	1.0/100	<0.01
S110355.26/S806/160322	PSB site, southern end, fencing along laneway.	0.0/100	<0.01
S110355.26/S182/160322	PSB site, eastern end, fencing behind site sheds	1.0/100	<0.01
S110355.26/S110/160322	Blank	0.0/100	NA

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

17 March 2022

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

Analysed and reported by:



Alexandar Mitevski
Analyst



Rune Knoph
Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

17 March 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

17 March 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

18 March 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: miguel.canas@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.27-AAM1.v1-17/03/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 17/03/2022
Sample Analysis Date: 18/03/2022
Period of Sampling: 17/03/2022 07:05 AM - 17/03/2022 03:30 PM
Scope of Work: Control monitoring for asbestos fibres
SWE Laboratory: Suite 25, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.27/S754/170322	MSCP site, southwest end, adj. small courtyard, fencing	0.0/100	<0.01
S110355.27/S235/170322	MSCP site, southeast end of site, adj site sheds, fencing	0.0/100	<0.01
S110355.27/S142/170322	MSCP site, Corner of Labyrinth Way and Redbank Road, fencing	1.0/100	<0.01
S110355.27/S960/170322	MSCP site, northwest end of site, adj old maintenance car park, fencing	0.0/100	<0.01
S110355.27/S176/170322	PSB site, northern end, fencing along Redbank Rd.	0.0/100	<0.01
S110355.27/S535/170322	PSB site, western end, fencing along CASB loading dock.	0.0/100	<0.01
S110355.27/S057/170322	PSB site, southern end, fencing along laneway	2.0/100	<0.01
S110355.27/S133/170322	PSB site, eastern end, fencing behind site sheds	0.0/100	<0.01
S110355.27/S101/170322	Field Blank	0.0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

18 March 2022

Analysed and reported by:



Karl Grovenor
Analyst



Rune Knoph
Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

18 March 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

18 March 2022



S110355.27-AAM1.v1-ControlAsbestosAirMonitoringReport-170322

Page 4 of 4

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

21 March 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.28-AAM1.v1-18/03/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 18/03/2022
Sample Analysis Date: 21/03/2022
Period of Sampling: 18/03/2022 07:11 AM - 18/03/2022 02:41 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 25, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.28/S578/180322	MSCP site, southwest end, adj. small courtyard, fencing	0.0/100	<0.01
S110355.28/S158/180322	MSCP site, southeast end of site, adj site sheds, fencing	0.0/100	<0.01
S110355.28/S987/180322	MSCP site, Corner of Labyrinth Way and Redbank Road, fencing	1.0/100	<0.01
S110355.28/S912/180322	MSCP site, northwest end of site, adj old maintenance car park, fencing	0.0/100	<0.01
S110355.28/S348/180322	PSB site, northern end, fencing along Redbank Rd.	0.0/100	<0.01
S110355.28/S645/180322	PSB site, western end, fencing along CASB loading dock.	0.0/100	<0.01
S110355.28/S648/180322	PSB site, southern end, fencing along laneway	0.0/100	<0.01
S110355.28/S318/180322	PSB site, eastern end, fencing behind site sheds	0.0/100	<0.01
S110355.28/S110/180322	Blank	0.0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

21 March 2022

Analysed and reported by:



Alexandar Mitevski
Analyst



Rune Knoph
Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

21 March 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

21 March 2022



S110355.28-AAM1.v1-ControlAsbestosAirMonitoringReport-180322

Page 4 of 4

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

21 March 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.29-AAM1.v1-19/03/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 19/03/2022
Sample Analysis Date: 21/03/2022
Period of Sampling: 19/03/2022 07:00 AM - 19/03/2022 03:00 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 25, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.29/S059/190322	MSCP site, southwest end, adj. small courtyard, fencing	0/100	<0.01
S110355.29/S980/190322	MSCP site, southeast end of site, adj site sheds, fencing	0/100	<0.01
S110355.29/S125/190322	MSCP site, Corner of Labyrinth Way and Redbank Road, fencing	0/100	<0.01
S110355.29/S561/190322	MSCP site, northwest end of site, adj old maintenance car park, fencing	0/100	<0.01
S110355.29/A190/190322	PSB site, northern end, fencing along Redbank Rd.	0/100	<0.01
S110355.29/S558/190322	PSB site, western end, fencing along CASB loading dock.	0/100	<0.01
S110355.29/S058/190322	PSB site, southern end, fencing along laneway	0/100	<0.01
S110355.29/S619/190322	PSB site, eastern end, fencing behind site sheds	0/100	<0.01
S110355.29/S110/190322	Blank	0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

21 March 2022

Analysed and reported by:



Alexandar Mitevski
Analyst



Rune Knoph
Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

21 March 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

21 March 2022



S110355.29-AAM1.v1-ControlAsbestosAirMonitoringReport-190322

Page 4 of 4

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

22 March 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.30-AAM1.v1-21/03/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 21/03/2022
Sample Analysis Date: 22/03/2022
Period of Sampling: 21/03/2022 07:10 AM - 22/03/2022 03:20 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 25, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.30/S285/210322	MSCP site, southwest end, adj. small courtyard, fencing	0/100	<0.01
S110355.30/S911/210322	MSCP site, southeast end of site, adj site sheds, fencing	0/100	<0.01
S110355.30/S26/210322	MSCP site, Corner of Labyrinth Way and Redbank Road, fencing	1.5/100	<0.01
S110355.30/S933/210322	MSCP site, northwest end of site, adj old maintenance car park, fencing	0/100	<0.01
S110355.30/S974/210322	PSB site, northern end, fencing along Redbank Rd.	1/100	<0.01
S110355.30/S174/210322	PSB site, western end, fencing along CASB loading dock.	0/100	<0.01
S110355.30/S054/210322	PSB site, southern end, fencing along laneway	0/100	<0.01
S110355.30/S265/210322	PSB site, eastern end, fencing behind site sheds	0/100	<0.01
S110355.30/S064/210322	Blank	0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

22 March 2022

Analysed and reported by:



Alexandar Mitevski
Analyst



Rune Knoph
Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

22 March 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

22 March 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

23 March 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.31-AAM1.v1-22/03/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 22/03/2022
Sample Analysis Date: 23/03/2022
Period of Sampling: 22/03/2022 07:11 AM - 22/03/2022 03:18 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 25, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.31/S983/220322	MSCP site, southwest end, adj. small courtyard, fencing	1.0/100	<0.01
S110355.31/S971/220322	MSCP site, southeast end of site, adj site sheds, fencing	0.0/100	<0.01
S110355.31/S072/220322	MSCP site, Corner of Labyrinth Way and Redbank Road, fencing	1.0/100	<0.01
S110355.31/S181/220322	MSCP site, northwest end of site, adj old maintenance car park, fencing	0.0/100	<0.01
S110355.31/S158/220322	PSB site, northern end, fencing along Redbank Rd.	0.0/100	<0.01
S110355.31/S338/220322	PSB site, western end, fencing along CASB loading dock.	0.0/100	<0.01
S110355.31/S059/220322	PSB site, southern end, fencing along laneway	1.0/100	<0.01
S110355.31/S970/220322	PSB site, eastern end, fencing behind site sheds	1.0/100	<0.01
S110355.31/S110/220322	Blank	0.0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

23 March 2022

Analysed and reported by:



Alexandar Mitevski
Analyst



Rune Knoph
Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

23 March 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

23 March 2022



S110355.31-AAM1.v1-ControlAsbestosAirMonitoringReport-220322

Page 4 of 4

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

24 March 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.32-AAM1.v1-23/03/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 23/03/2022
Sample Analysis Date: 24/03/2022
Period of Sampling: 23/03/2022 07:10 AM - 23/03/2022 03:24 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 25, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.32/S015/230322	MSCP site, southwest end, adj. small courtyard, fencing	1.0/100	<0.01
S110355.32/S337/230322	MSCP site, southeast end of site, adj site sheds, fencing	1.0/100	<0.01
S110355.32/S816/230322	MSCP site, Corner of Labyrinth Way and Redbank Road, fencing	0.0/100	<0.01
S110355.32/S915/230322	MSCP site, northwest end of site, adj old maintenance car park, fencing	0.0/100	<0.01
S110355.32/S959/230322	PSB site, northern end, fencing along Redbank Rd.	1.0/100	<0.01
S110355.32/S907/230322	PSB site, western end, fencing along CASB loading dock.	1.0/100	<0.01
S110355.32/S893/230322	PSB site, southern end, fencing along laneway	0.0/100	<0.01
S110355.32/S016/230322	PSB site, eastern end, fencing behind site sheds	0.0/100	<0.01
S110355.32/S110/230322	Blank	0.0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

24 March 2022

Analysed and reported by:



Alexandar Mitevski
Analyst



Rune Knoph
Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

24 March 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

24 March 2022



S110355.32-AAM1.v1-ControlAsbestosAirMonitoringReport-230322

Page 4 of 4

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

25 March 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.33-AAM1.v1-24/03/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 24/03/2022
Sample Analysis Date: 25/03/2022
Period of Sampling: 24/03/2022 07:05 AM - 24/03/2022 03:30 PM
Scope of Work: Control monitoring for asbestos fibres
SWE Laboratory: Suite 15, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.33/S02/240322	MSCP site, northwest end of site, adj old maintenance car park, fencing	0.0/100	<0.01
S110355.33/S752/240322	MSCP site, Corner of Labyrinth Way and Redbank Road, fencing	0.0/100	<0.01
S110355.33/S757/240322	MSCP site, southeast end of site, adj site sheds, fencing	0.0/100	<0.01
S110355.33/S899/240322	MSCP site, southwest end, adj. small courtyard, fencing	0.0/100	<0.01
S110355.33/S591/240322	PSB site, northern end, fencing along Redbank Rd.	1.0/100	<0.01
S110355.33/S393/240322	PSB site, western end, fencing along CASB loading dock.	0.0/100	<0.01
S110355.33/S177/240322	PSB site, southern end, fencing along laneway	0.0/100	<0.01
S110355.33/S963/240322	PSB site, eastern end, fencing behind site sheds	0.0/100	<0.01
S110355.33/S000/240322	Field Blank	0.0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

25 March 2022

Analysed and reported by:



Karl Grovenor
Analyst



Rune Knoph
Approved Issuer of Report



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

25 March 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

25 March 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

28 March 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.34-AAM1.v1-25/03/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 25/03/2022
Sample Analysis Date: 28/03/2022
Period of Sampling: 25/03/2022 07:10 AM - 25/03/2022 02:38 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 25, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.34/S139/250322	MSCP site, northwest end of site, adj old maintenance car park, fencing	0.0/100	<0.01
S110355.34/S925/250322	MSCP site, Corner of Labyrinth Way and Redbank Road, fencing	0.0/100	<0.01
S110355.34/S741/250322	MSCP site, southeast end of site, adj site sheds, fencing	0.0/100	<0.01
S110355.34/S504/250322	MSCP site, southwest end, adj. small courtyard, fencing	0.0/100	<0.01
S110355.34/S010/250322	PSB site, northern end, fencing along Redbank Rd.	0.0/100	<0.01
S110355.34/S832/250322	PSB site, western end, fencing along CASB loading dock.	1.0/100	<0.01
S110355.34/S897/250322	PSB site, southern end, fencing along laneway	1.0/100	<0.01
S110355.34/S058/250322	PSB site, eastern end, fencing behind site sheds	0.0/100	<0.01
S110355.34/S101/250322	Blank	0.0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

28 March 2022

Analysed and reported by:



Alexandar Mitevski
Analyst



Rune Knoph
Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

28 March 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

28 March 2022



S110355.34-AAM1.v1-ControlAsbestosAirMonitoringReport-250322

Page 4 of 4

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

28 March 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.35-AAM1.v1-26/03/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 26/03/2022
Sample Analysis Date: 28/03/2022
Period of Sampling: 26/03/2022 07:00 AM - 26/03/2022 03:00 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 25, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.35/SXXX/260322	MSCP site, northwest end of site, adj old maintenance car park, fencing	*VOID	*VOID
S110355.35/S334/260322	MSCP site, Corner of Labyrinth Way and Redbank Road, fencing	0/100	<0.01
S110355.35/S197/260322	MSCP site, southeast end of site, adj site sheds, fencing	0/100	<0.01
S110355.35/SXXX/260322	MSCP site, southwest end, adj. small courtyard, fencing	*VOID	*VOID
S110355.35/S582/260322	PSB site, northern end, fencing along Redbank Rd.	0/100	<0.01
S110355.35/S800/260322	PSB site, western end, fencing along CASB loading dock.	0/100	<0.01
S110355.35/S995/260322	PSB site, southern end, fencing along laneway	0/100	<0.01
S110355.35/S979/260322	PSB site, eastern end, fencing behind site sheds	0/100	<0.01
S110355.35/S110/260322	Blank	0/100	NA

***Sample Void due to missing air sampling pumps.**

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

28 March 2022

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

Analysed and reported by:



Alexandar Mitevski
Analyst



Rune Knoph
Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

28 March 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

28 March 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

29 March 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.36-AAM1.v1-28/03/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 28/03/2022
Sample Analysis Date: 29/03/2022
Period of Sampling: 28/03/2022 07:30 AM - 28/03/2022 02:40 PM
Scope of Work: Air monitoring during civil works with asbestos impacted soil.
SWE Laboratory: Suite 25, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.36/SXXX/280322	MSCP site, northwest end of site, adj old maintenance car park, fencing	*VOID	*VOID
S110355.36/S773/280322	MSCP site, Corner of Labyrinth Way and Redbank Road, fencing	0.0/100	<0.01
S110355.36/S791/280322	MSCP site, southeast end of site, adj site sheds, fencing	0.0/100	<0.01
S110355.36/SXXX/280322	MSCP site, southwest end, adj. small courtyard, fencing	*VOID	*VOID
S110355.36/S496/280322	PSB site, northern end, fencing along Redbank Rd.	1.0/100	<0.01
S110355.36/S797/280322	PSB site, western end, fencing along CASB loading dock.	1.0/100	<0.01
S110355.36/S808/280322	PSB site, southern end, fencing along laneway	0.0/100	<0.01
S110355.36/S241/280322	PSB site, eastern end, fencing behind site sheds	1.0/100	<0.01
S110355.36/S101/280322	Blank	0.0/100	NA

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

29 March 2022

***Sample Void due to missing air sampling pumps.**

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

Analysed and reported by:



Alexandar Mitevski
Analyst



Rune Knoph
Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

29 March 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

29 March 2022



S110355.36-AAM1.v1-ControlAsbestosAirMonitoringReport-280222

Page 4 of 4

Safe Work and Environments Pty Ltd 88127010995
Suite 25, 103 Majors Bay Road, Concord NSW 2137
Phone: 02 8757 3611
Email: info@swe.com.au

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

30 March 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.37-AAM1.v1-29/03/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 29/03/2022
Sample Analysis Date: 30/03/2022
Period of Sampling: 29/03/2022 07:00 AM - 29/03/2022 03:00 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 25, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.37/S231/290322	MSCP site, northwest end of site, adj old maintenance car park, fencing	0.0/100	<0.01
S110355.37/S408/290322	MSCP site, Corner of Labyrinth Way and Redbank Road, fencing	0.0/100	<0.01
S110355.37/S487/290322	MSCP site, southeast end of site, adj site sheds, fencing	0.0/100	<0.01
S110355.37/S200/290322	MSCP site, southwest end, adj. small courtyard, fencing	0.0/100	<0.01
S110355.37/S740/290322	PSB site, northern end, fencing along Redbank Rd.	0.0/100	<0.01
S110355.37/S252/290322	PSB site, western end, fencing along CASB loading dock.	0.0/100	<0.01
S110355.37/S506/290322	PSB site, southern end, fencing along laneway	0.0/100	<0.01
S110355.37/S487/290322	PSB site, eastern end, fencing behind site sheds	0.0/100	<0.01
S110355.37/S110/290322	Blank	0.0/100	NA

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

30 March 2022

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

Analysed and reported by:



Alexandar Mitevski
Analyst



Rune Knoph
Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

30 March 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

30 March 2022



S110355.37-AAM1.v1-ControlAsbestosAirMonitoringReport-290322

Page 4 of 4

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

31 March 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.38-AAM1.v1-30/03/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 30/03/2022
Sample Analysis Date: 31/03/2022
Period of Sampling: 30/03/2022 07:10 AM - 31/03/2022 03:10 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 25, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.37/S590/300322	MSCP site, northwest end of site, adj old maintenance car park, fencing	1.0/100	<0.01
S110355.37/S183/300322	MSCP site, Corner of Labyrinth Way and Redbank Road, fencing	1.0/100	<0.01
S110355.37/S132/300322	MSCP site, southeast end of site, adj site sheds, fencing	0.0/100	<0.01
S110355.37/S055/300322	MSCP site, southwest end, adj. small courtyard, fencing	0.0/100	<0.01
S110355.37/S978/300322	PSB site, northern end, fencing along Redbank Rd.	0.0/100	<0.01
S110355.37/S537/300322	PSB site, western end, fencing along CASB loading dock.	0.0/100	<0.01
S110355.37/S979/300322	PSB site, southern end, fencing along laneway	2.0/100	<0.01
S110355.37/S747/300322	PSB site, eastern end, fencing behind site sheds	0.0/100	<0.01
S110355.37/S110/300322	Blank	0.0/100	NA

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

31 March 2022

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

Analysed and reported by:



Alexandar Mitevski
Analyst



Rune Knoph
Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

31 March 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

31 March 2022



S110355.38-AAM1.v1-ControlAsbestosAirMonitoringReport-300322

Page 4 of 4

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

01 April 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.39-AAM1.v1-31/03/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 31/03/2022
Sample Analysis Date: 01/04/2022
Period of Sampling: 31/03/2022 07:06 AM - 31/03/2022 03:29 PM
Scope of Work: Control monitoring for asbestos fibres
SWE Laboratory: Suite 15, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.39/S978/310322	MSCP site, northwest end of site, adj old maintenance car park, fencing	0.0/100	<0.01
S110355.39/S194/310322	MSCP site, Corner of Labyrinth Way and Redbank Road, fencing	0.0/100	<0.01
S110355.39/S926/310322	MSCP site, southeast end of site, adj site sheds, fencing	3.0/100	<0.01
S110355.39/S281/310322	MSCP site, southwest end, adj. small courtyard, fencing	0.0/100	<0.01
S110355.39/S490/310322	PSB site, northern end, fencing along Redbank Rd.	1.0/100	<0.01
S110355.39/S097/310322	PSB site, western end, fencing along CASB loading dock.	0.0/100	<0.01
S110355.39/S822/310322	PSB site, southern end, fencing along laneway	0.0/100	<0.01
S110355.39/S226/310322	PSB site, eastern end, fencing behind site sheds	0.0/100	<0.01
S110355.39/S202/310322	Field Blank	0.0/100	NA

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

01 April 2022

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

Analysed and reported by:



Karl Grovenor
Analyst



Rune Knoph
Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

01 April 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

01 April 2022

