

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

05 October 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.188-AAM1.v1-05/10/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 05/10/2022
Sample Analysis Date: 05/10/2022
Period of Sampling: 05/10/2022 06:45 AM - 05/10/2022 02:05 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 15, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.188/S899/051022	MSCP site, southwestern end, adj small courtyard, between stockpile and public	0.0/100	<0.01
S110355.188/3193/051022	MSCP site, temp fencing in middle of site, between clean and dirty zone	0.0/100	<0.01
S110355.188/S205/051022	MSCP site, northwest end of site, adj old maintenance car park, fencing	0.0/100	<0.01
S110355.188/S1005/051022	PSB site, northern end, fencing along Redbank Rd	0.0/100	<0.01
S110355.188/S934/051022	PSB site, western end, fencing along CASB loading dock	0.0/100	<0.01
S110355.188/3249/051022	PSB site, eastern end, temp fencing in site, facing SE	0.0/100	<0.01
S110355.188/8983/051022	PSB site, eastern end, temp fencing in site, facing NE	0.0/100	<0.01
S110355.188/S252/051022	PSB site, fencing behind site sheds	0.0/100	<0.01
S110355.188/S736/051022	PSB site, northern end, temp fencing between site and compound	0.0/100	<0.01
S110355.188/S1001/051022	Mons Road, entry point	0.0/100	<0.01

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

05 October 2022

S110355.188/S503/051022	Mons Road, before boom gate, fencing	0.0/100	<0.01
S110355.188/S1007/051022	Field Blank	0.0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

Analysed and reported by:



Rune Knoph

Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

05 October 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

05 October 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

05 October 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

06 October 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.189-AAM1.v1-06/10/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 06/10/2022
Sample Analysis Date: 06/10/2022
Period of Sampling: 06/10/2022 06:42 AM - 06/10/2022 02:06 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 15, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.189/8972/061022	MSCP site, southwestern end, adj small courtyard, between stockpile and public	0.0/100	<0.01
S110355.189/S797/061022	MSCP site, temp fencing in middle of site, between clean and dirty zone	0.0/100	<0.01
S110355.189/3202/061022	MSCP site, adj to Redbank Rd, temp fencing, between clean and dirty zone	0.0/100	<0.01
S110355.189/S408/061022	MSCP site, northwest end of site, adj old maintenance car park, fencing	1.0/100	<0.01
S110355.189/S104/061022	PSB site, northern end, fencing along Redbank Rd	0.0/100	<0.01
S110355.189/2117/061022	PSB site, western end, fencing along CASB loading dock	0.0/100	<0.01
S110355.189/S620/061022	PSB site, fencing behind site sheds	1.0/100	<0.01
S110355.189/S176/061022	PSB site, northern end, temp fencing between site and compound	0.0/100	<0.01
S110355.189/S706/061022	Mons Road, entry point	0.0/100	<0.01
S110355.189/S817/061022	Mons Road, before boom gate, fencing	0.0/100	<0.01
S110355.189/S971/061022	Field Blank	0.0/100	NA

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

06 October 2022

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

Analysed and reported by:



Rune Knoph

Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

06 October 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

06 October 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

06 October 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

07 October 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.190-AAM1.v1-07/10/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 07/10/2022
Sample Analysis Date: 07/10/2022
Period of Sampling: 07/10/2022 06:45 AM - 07/10/2022 02:10 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 15, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.190/S059/071022	MSCP site, southwestern end, adj small courtyard, between stockpile and public	0.0/100	<0.01
S110355.190/S466/071022	MSCP site, temp fencing in middle of site, between clean and dirty zone	0.0/100	<0.01
S110355.190/S813/071022	MSCP site, adj to Redbank Rd, temp fencing, between clean and dirty zone	1.0/100	<0.01
S110355.190/S222/071022	MSCP site, northwest end of site, adj old maintenance car park, fencing	0.0/100	<0.01
S110355.190/S903/071022	PSB site, northern end, fencing along Redbank Rd	1.0/100	<0.01
S110355.190/S994/071022	PSB site, western end, fencing along CASB loading dock	0.0/100	<0.01
S110355.190/S538/071022	PSB site, eastern end, temp fencing in site, facing NE	1.0/100	<0.01
S110355.190/S074/071022	PSB site, eastern end, temp fencing in site, facing SE	0.0/100	<0.01
S110355.190/S469/071022	PSB site, fencing behind site sheds	0.0/100	<0.01
S110355.190/S515/071022	PSB site, northern end, temp fencing between site and compound	0.0/100	<0.01

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

07 October 2022

S110355.190/S083/071022	Mons Road, entry point	0.0/100	<0.01
S110355.190/S935/071022	Mons Road, before boom gate, fencing	0.0/100	<0.01
S110355.190/S229/071022	Field Blank	0.0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

Analysed and reported by:



Rune Knoph

Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

07 October 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

07 October 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

07 October 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

10 October 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.191-AAM1.v1-08/10/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 08/10/2022
Sample Analysis Date: 10/10/2022
Period of Sampling: 08/10/2022 06:50 AM - 08/10/2022 02:50 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 15, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.191/S747/081022	MSCP site, southwestern end, adj small courtyard, between stockpile and public	0.0/100	<0.01
S110355.191/S999/081022	MSCP site, temp fencing in middle of site, between clean and dirty zone	0.0/100	<0.01
S110355.191/S732/081022	MSCP site, adj to Redbank Rd, temp fencing, between clean and dirty zone	1.0/100	<0.01
S110355.191/S902/081022	MSCP site, northwest end of site, adj old maintenance car park, fencing	1.0/100	<0.01
S110355.191/S756/081022	PSB site, northern end, fencing along Redbank Rd	0.0/100	<0.01
S110355.191/S987/081022	PSB site, western end, fencing along CASB loading dock	0.0/100	<0.01
S110355.191/S576/081022	PSB site, eastern end, temp fencing in site, facing NE	1.0/100	<0.01
S110355.191/S529/081022	PSB site, eastern end, temp fencing in site, facing SE	0.0/100	<0.01
S110355.191/S853/081022	PSB site, fencing behind site sheds	Rejected: Damaged filter	
S110355.191/S153/081022	PSB site, northern end, temp fencing between site and compound	0.0/100	<0.01

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

10 October 2022

S110355.191/S089/081022	Mons Road, entry point	0.0/100	<0.01
S110355.191/S926/081022	Mons Road, before boom gate, fencing	0.0/100	<0.01
S110355.191/S422/081022	Field Blank	0.0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

Analysed and reported by:



Rune Knoph

Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

10 October 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

10 October 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

10 October 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

10 October 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.192-AAM1.v1-10/10/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 10/10/2022
Sample Analysis Date: 10/10/2022
Period of Sampling: 10/10/2022 06:54 AM - 10/10/2022 02:10 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 15, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.192/S481/101022	MSCP site, southwestern end, adj small courtyard, between stockpile and public	0.0/100	<0.01
S110355.192/S975/101022	MSCP site, temp fencing in middle of site, between clean and dirty zone	0.0/100	<0.01
S110355.192/S724/101022	MSCP site, adj to Redbank Rd, temp fencing, between clean and dirty zone	0.0/100	<0.01
S110355.192/S135/101022	MSCP site, northwest end of site, adj old maintenance car park, fencing	0.0/100	<0.01
S110355.192/S561/101022	PSB site, northern end, fencing along Redbank Rd	0.0/100	<0.01
S110355.192/S934/101022	PSB site, western end, fencing along CASB loading dock	1.0/100	<0.01
S110355.192/S971/101022	PSB site, southern end, temp fence in site, facing SE	0.0/100	<0.01
S110355.192/S899/101022	PSB site, southern end, temp fence in site, facing NE	3.0/100	<0.01
S110355.192/S307/101022	PSB site, eastern end, fencing behind site sheds	0.0/100	<0.01
S110355.192/S556/101022	PSB site, northern end, temp fencing between site and compound	0.0/100	<0.01

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

10 October 2022

S110355.192/S770/101022	Mons Rd, entry point	0.0/100	<0.01
S110355.192/S962/101022	Mons Rd, before boom gate, fencing	0.0/100	<0.01
S110355.192/S629/101022	Field Blank	0.0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

Analysed and reported by:



Rune Knoph

Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

10 October 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

10 October 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

10 October 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

11 October 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.193-AAM1.v1-11/10/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 11/10/2022
Sample Analysis Date: 11/10/2022
Period of Sampling: 11/10/2022 06:50 AM - 11/10/2022 02:04 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 15, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.193/S408/111022	MSCP site, southwestern end, adj small courtyard, between stockpile and public	0.0/100	<0.01
S110355.193/S168/111022	MSCP site, temp fencing in middle of site, between clean and dirty zone	1.0/100	<0.01
S110355.193/S169/111022	MSCP site, adj to Redbank Rd, temp fencing, between clean and dirty zone	0.0/100	<0.01
S110355.193/S817/111022	MSCP site, northwest end of site, adj old maintenance car park, fencing	0.0/100	<0.01
S110355.193/S487/111022	PSB site, northern end, fencing along Redbank Rd	0.0/100	<0.01
S110355.193/S995/111022	PSB site, western end, fencing along CASB loading dock	0.0/100	<0.01
S110355.193/S989/111022	PSB site, eastern end, temp fencing in site, facing SE	0.0/100	<0.01
S110355.193/S192/111022	PSB site, fencing behind site sheds	1.0/100	<0.01
S110355.193/S461/111022	PSB site, temp fencing around sewer works	1.0/100	<0.01
S110355.193/S979/111022	PSB site, northern end, temp fencing between site and compound	0.0/100	<0.01

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

11 October 2022

S110355.193/S492/111022	Mons Road, entry point	0.0/100	<0.01
S110355.193/S998/111022	Mons Road, before boom gate, fencing	0.0/100	<0.01
S110355.193/S821/111022	Field Blank	0.0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

Analysed and reported by:



Rune Knoph

Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

11 October 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

11 October 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

11 October 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

12 October 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.194-AAM1.v1-12/10/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 12/10/2022
Sample Analysis Date: 12/10/2022
Period of Sampling: 12/10/2022 06:45 AM - 12/10/2022 02:34 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 15, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.194/S1008/121022	MSCP site, southwestern end, adj small courtyard, between stockpile and public	0.0/100	<0.01
S110355.194/S1006/121022	MSCP site, temp fencing in middle of site, between clean and dirty zone	0.0/100	<0.01
S110355.194/S140/121022	MSCP site, adj to Redbank Rd, temp fencing, between clean and dirty zone	0.0/100	<0.01
S110355.194/3491/121022	MSCP site, northwest end of site, adj old maintenance car park, fencing	0.0/100	<0.01
S110355.194/S941/121022	PSB site, northern end, fencing along Redbank Rd	1.0/100	<0.01
S110355.194/S851/121022	PSB site, western end, fencing along CASB loading dock	0.0/100	<0.01
S110355.194/S1028/121022	PSB site, eastern end, temp fencing in site, facing SE	0.0/100	<0.01
S110355.194/S052/121022	PSB site, eastern end, temp fencing in site, facing NE	0.0/100	<0.01
S110355.194/S227/121022	PSB site, fencing behind site sheds	0.0/100	<0.01
S110355.194/S176/121022	PSB site, northern end, temp fencing between site and compound	1.0/100	<0.01

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

12 October 2022

S110355.194/S897/121022	Mons Road, entry point	1.0/100	<0.01
S110355.194/S1021/121022	Mons Road, before boom gate, fencing	0.0/100	<0.01
S110355.194/4564/121022	Field Blank	0.0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

Analysed and reported by:



Rune Knoph

Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

12 October 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

12 October 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

12 October 2022



S110355.194-AAM1.v1-ControlAsbestosAirMonitoringReport-121022

Page 5 of 5

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

13 October 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.195-AAM1.v1-13/10/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 13/10/2022
Sample Analysis Date: 13/10/2022
Period of Sampling: 13/10/2022 06:45 AM - 13/10/2022 02:11 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 15, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.195/S903/131022	MSCP site, southwestern end, adj small courtyard, between stockpile and public	1.0/100	<0.01
S110355.195/S574/131022	MSCP site, temp fencing in middle of site, between clean and dirty zone	1.0/100	<0.01
S110355.195/S222/131022	MSCP site, adj to Redbank Rd, temp fencing, between clean and dirty zone	1.0/100	<0.01
S110355.195/S576/131022	MSCP site, northwest end of site, adj old maintenance car park, fencing	0.0/100	<0.01
S110355.195/S987/131022	PSB site, northern end, fencing along Redbank Rd	0.0/100	<0.01
S110355.195/S989/131022	PSB site, western end, fencing along CASB loading dock	0.0/100	<0.01
S110355.195/S934/131022	PSB site, eastern end, temp fencing in site, facing SE	0.0/100	<0.01
S110355.195/S962/131022	PSB site, eastern end, temp fencing in site, facing NE	0.0/100	<0.01
S110355.195/S307/131022	PSB site, fencing behind site sheds	0.0/100	<0.01
S110355.195/5808/131022	PSB site, fencing behind site sheds	1.0/100	<0.01

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

13 October 2022

S110355.195/S817/131022	Mons Road, entry point	0.0/100	<0.01
S110355.195/5503/131022	Mons Road, before boom gate, fencing	1.0/100	<0.01
S110355.195/S408/131022	Field Blank	0.0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

Analysed and reported by:



Rune Knoph

Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

13 October 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

13 October 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

13 October 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

14 October 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.196-AAM1.v1-14/10/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 14/10/2022
Sample Analysis Date: 14/10/2022
Period of Sampling: 14/10/2022 06:45 AM - 14/10/2022 02:16 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 15, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.196/0604/141022	MSCP site, southwestern end, adj small courtyard, between stockpile and public	0.0/100	<0.01
S110355.196/S770/141022	MSCP site, temp fencing in middle of site, between clean and dirty zone	0.0/100	<0.01
S110355.196/S898/141022	MSCP site, adj to Redbank Rd, temp fencing, between clean and dirty zone	0.0/100	<0.01
S110355.196/5406/141022	MSCP site, northwest end of site, adj old maintenance car park, fencing	2.0/100	<0.01
S110355.196/S971/141022	PSB site, northern end, fencing along Redbank Rd	0.0/100	<0.01
S110355.196/6604/141022	PSB site, western end, fencing along CASB loading dock	0.0/100	<0.01
S110355.196/S1020/141022	PSB site, eastern end, temp fencing in site, facing SE	0.0/100	<0.01
S110355.196/S995/141022	PSB site, eastern end, temp fencing in site, facing NE	1.0/100	<0.01
S110355.196/S899/141022	PSB site, fencing behind site sheds	2.0/100	<0.01
S110355.196/S926/141022	PSB site, northern end, temp fencing between site and compound	1.0/100	<0.01

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

14 October 2022

S110355.196/S832/141022	Mons Road, entry point	0.0/100	<0.01
S110355.196/3385/141022	Mons Road, before boom gate, fencing	1.0/100	<0.01
S110355.196/S928/141022	Field Blank	0.0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

Analysed and reported by:



Rune Knoph

Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

14 October 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

14 October 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

14 October 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

17 October 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.197-AAM1.v1-15/10/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 15/10/2022
Sample Analysis Date: 17/10/2022
Period of Sampling: 15/10/2022 06:45 AM - 15/10/2022 03:15 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 15, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.197/S210/151022	MSCP site, southwestern end, adj small courtyard, between stockpile and public	1.0/100	<0.01
S110355.197/S181/151022	MSCP site, temp fencing in middle of site, between clean and dirty zone	0.0/100	<0.01
S110355.197/S1027/151022	MSCP site, adj to Redbank Rd, temp fencing, between clean and dirty zone	0.0/100	<0.01
S110355.197/S821/151022	MSCP site, northwest end of site, adj old maintenance car park, fencing	0.0/100	<0.01
S110355.197/S503/151022	PSB site, northern end, fencing along Redbank Rd	0.0/100	<0.01
S110355.197/S534/151022	PSB site, western end, fencing along CASB loading dock	0.0/100	<0.01
S110355.197/S1004/151022	PSB site, eastern end, temp fencing in site, facing SE	0.0/100	<0.01
S110355.197/S038/151022	PSB site, eastern end, temp fencing in site, facing NE	0.0/100	<0.01
S110355.197/S1025/151022	PSB site, fencing behind site sheds	0.0/100	<0.01
S110355.197/S195/151022	PSB site, northern end, temp fencing between site and compound	2.0/100	<0.01

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

17 October 2022

S110355.197/S741/151022	Mons Road, entry point	0.0/100	<0.01
S110355.197/S902/151022	Mons Road, before boom gate, fencing	0.0/100	<0.01
S110355.197/S797/151022	Field Blank	0.0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

Analysed and reported by:



Rune Knoph

Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

17 October 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

17 October 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

17 October 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

17 October 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.198-AAM1.v1-17/10/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 17/10/2022
Sample Analysis Date: 17/10/2022
Period of Sampling: 17/10/2022 07:22 AM - 17/10/2022 02:40 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 15, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.198/S154/171022	MSCP site, southwestern end, adj small courtyard, between stockpile and public	0.0/100	<0.01
S110355.198/S743/171022	MSCP site, temp fencing in middle of site, between clean and dirty zone	0.0/100	<0.01
S110355.198/S890/171022	MSCP site, adj to Redbank Rd, temp fencing, between clean and dirty zone	0.0/100	<0.01
S110355.198/S087/171022	MSCP site, northwest end of site, adj old maintenance car park, fencing	0.0/100	<0.01
S110355.198/S848/171022	PSB site, northern end, fencing along Redbank Rd	0.0/100	<0.01
S110355.198/S155/171022	PSB site, western end, fencing along CASB loading dock	0.0/100	<0.01
S110355.198/S196/171022	PSB site, eastern end, temp fencing in site, facing SE	0.0/100	<0.01
S110355.198/S807/171022	PSB site, eastern end, temp fencing in site, facing NE	0.0/100	<0.01
S110355.198/3202/171022	PSB site, fencing behind site sheds	0.0/100	<0.01
S110355.198/S548/171022	PSB site, northern end, temp fencing between site and compound	0.0/100	<0.01

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

17 October 2022

S110355.198/S620/171022	Mons Road, entry point	0.0/100	<0.01
S110355.198/3082/171022	Mons Road, before boom gate, fencing	0.0/100	<0.01
S110355.198/3249/171022	Field Blank	0.0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

Analysed and reported by:



Rune Knoph

Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

17 October 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

17 October 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

17 October 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

18 October 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.199-AAM1.v1-18/10/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 18/10/2022
Sample Analysis Date: 18/10/2022
Period of Sampling: 18/10/2022 06:40 AM - 18/10/2022 02:05 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 15, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.199/4123/181022	MSCP site, southwestern end, adj small courtyard, between stockpile and public	1.0/100	<0.01
S110355.199/S1012/181022	MSCP site, temp fencing in middle of site, between clean and dirty zone	0.0/100	<0.01
S110355.199/S104/181022	MSCP site, adj to Redbank Rd, temp fencing, between clean and dirty zone	1.0/100	<0.01
S110355.199/8459/181022	MSCP site, northwest end of site, adj old maintenance car park, fencing	0.0/100	<0.01
S110355.199/5410/181022	PSB site, northern end, fencing along Redbank Rd	0.0/100	<0.01
S110355.199/8983/181022	PSB site, western end, fencing along CASB loading dock	0.0/100	<0.01
S110355.199/S1005/181022	PSB site, eastern end, temp fencing in site, facing SE	0.0/100	<0.01
S110355.199/8972/181022	PSB site, eastern end, temp fencing in site, facing NE	0.0/100	<0.01
S110355.199/2117/181022	PSB site, fencing behind site sheds	0.0/100	<0.01
S110355.199/S1001/181022	PSB site, northern end, temp fencing between site and compound	0.0/100	<0.01

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

18 October 2022

S110355.199/3193/181022	Mons Road, entry point	1.0/100	<0.01
S110355.199/3399/181022	Mons Road, before boom gate, fencing	0.0/100	<0.01
S110355.199/S1007/181022	Field Blank	0.0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

Analysed and reported by:



Rune Knoph

Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

18 October 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

18 October 2022



S110355.199-AAM1.v1-ControlAsbestosAirMonitoringReport-181022

Page 4 of 5

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

18 October 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

19 October 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.200-AAM1.v1-19/10/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 19/10/2022
Sample Analysis Date: 19/10/2022
Period of Sampling: 19/10/2022 06:40 AM - 19/10/2022 01:00 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 15, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.200/S077/191022	MSCP site, southwestern end, adj small courtyard, between stockpile and public	2.0/100	<0.01
S110355.200/S205/191022	MSCP site, temp fencing in middle of site, between clean and dirty zone	1.0/100	<0.01
S110355.200/S592/191022	MSCP site, adj to Redbank Rd, temp fencing, between clean and dirty zone	0.0/100	<0.01
S110355.200/S087/191022	MSCP site, northwest end of site, adj old maintenance car park, fencing	0.0/100	<0.01
S110355.200/S106/191022	PSB site, northern end, fencing along Redbank Rd	1.0/100	<0.01
S110355.200/S1014/191022	PSB site, western end, fencing along CASB loading dock	0.0/100	<0.01
S110355.200/6568/191022	PSB site, eastern end, temp fencing in site, facing SE	1.0/100	<0.01
S110355.200/S233/191022	PSB site, eastern end, temp fencing in site, facing NE	1.0/100	<0.01
S110355.200/S240/191022	PSB site, fencing behind site sheds	0.0/100	<0.01
S110355.200/S199/191022	PSB site, northern end, temp fencing between site and compound	2.0/100	<0.01

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

19 October 2022

S110355.200/S590/191022	Mons Road, entry point	2.0/100	<0.01
S110355.200/S603/191022	Mons Road, before boom gate, fencing	2.0/100	<0.01
S110355.200/S997/191022	Field Blank	0.0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

Analysed and reported by:



Rune Knoph

Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

19 October 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

19 October 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

19 October 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

20 October 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.201-AAM1.v1-20/10/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 20/10/2022
Sample Analysis Date: 20/10/2022
Period of Sampling: 20/10/2022 07:00 AM - 20/10/2022 01:40 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 15, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.201/3303/201022	MSCP site, southwestern end, adj small courtyard, between stockpile and public	0.0/100	<0.01
S110355.201/S1018/201022	MSCP site, temp fencing in middle of site, between clean and dirty zone	0.0/100	<0.01
S110355.201/S221/201022	MSCP site, adj to Redbank Rd, temp fencing, between clean and dirty zone	3.0/100	<0.01
S110355.201/3546/201022	MSCP site, northwest end of site, adj old maintenance car park, fencing	0.0/100	<0.01
S110355.201/S105/201022	PSB site, northern end, fencing along Redbank Rd	0.0/100	<0.01
S110355.201/S186/201022	PSB site, western end, fencing along CASB loading dock	0.0/100	<0.01
S110355.201/S846/201022	PSB site, eastern end, temp fencing in site, facing SE	0.0/100	<0.01
S110355.201/S852/201022	PSB site, eastern end, temp fencing in site, facing NE	0.0/100	<0.01
S110355.201/6290/201022	PSB site, fencing behind site sheds	0.0/100	<0.01
S110355.201/3360/201022	PSB site, northern end, temp fencing between site and compound	1.0/100	<0.01

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

20 October 2022

S110355.201/S975/201022	Mons Road, entry point	1.0/100	<0.01
S110355.201/S571/201022	Mons Road, before boom gate, fencing	0.0/100	<0.01
S110355.201/S1003/201022	Field Blank	0.0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

Analysed and reported by:



Rune Knoph

Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

20 October 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

20 October 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

20 October 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

21 October 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.202-AAM1.v1-21/10/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 21/10/2022
Sample Analysis Date: 21/10/2022
Period of Sampling: 21/10/2022 06:40 AM - 21/10/2022 02:55 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 15, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.202/S1002/211022	Kane Civil, MSCP site, temp fencing adjacent to playground	1.0/100	<0.01
S110355.202/3221/211022	Kane Civil, MSCP site, temp fencing adjacent to Paringa Avenue	0.0/100	<0.01
S110355.202/S824/211022	MSCP site, southwestern end, adj small courtyard, between stockpile and public	1.0/100	<0.01
S110355.202/S650/211022	MSCP site, adj to Redbank Rd, temp fencing, between clean and dirty zone	3.0/100	<0.01
S110355.202/3486/211022	MSCP site, temp fencing in middle of site, between clean and dirty zone	0.0/100	<0.01
S110355.202/S005/211022	MSCP site, northwest end of site, adj old maintenance car park, fencing	0.0/100	<0.01
S110355.202/S1009/211022	PSB site, northern end, fencing along Redbank Rd	0.0/100	<0.01
S110355.202/S139/211022	PSB site, western end, fencing along CASB loading dock	1.0/100	<0.01
S110355.202/3119/211022	PSB site, eastern end, temp fencing in site, facing SE	0.0/100	<0.01

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

21 October 2022

S110355.202/3336/211022	PSB site, eastern end, temp fencing in site, facing NE	1.0/100	<0.01
S110355.202/S234/211022	PSB site, fencing behind site sheds	1.0/100	<0.01
S110355.202/S498/211022	PSB site, northern end, temp fencing between site and compound	0.0/100	<0.01
S110355.202/3530/211022	Field Blank	0.0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

Analysed and reported by:



Rune Knoph

Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

21 October 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

21 October 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

24 October 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.203-AAM1.v1-22/10/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 22/10/2022
Sample Analysis Date: 24/10/2022
Period of Sampling: 22/10/2022 06:40 AM - 22/10/2022 02:10 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 15, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.203/S945/221022	Kane Civil, MSCP site, temp fencing adjacent to playground	Rejected: Damaged Filter	
S110355.203/S537/221022	Kane Civil, MSCP site, temp fencing adjacent to Paringa Avenue	0.0/100	<0.01
S110355.203/S947/221022	MSCP site, southwestern end, adj small courtyard, between stockpile and public	Rejected: Damaged Filter	
S110355.203/S573/221022	MSCP site, adj to Redbank Rd, temp fencing, between clean and dirty zone	0.0/100	<0.01
S110355.203/S851/221022	MSCP site, temp fencing in middle of site, between clean and dirty zone	0.0/100	<0.01
S110355.203/S706/221022	MSCP site, northwest end of site, adj old maintenance car park, fencing	0.0/100	<0.01
S110355.203/S799/221022	PSB site, northern end, fencing along Redbank Rd	Rejected: Damaged Filter	
S110355.203/S135/221022	PSB site, western end, fencing along CASB loading dock	0.0/100	<0.01
S110355.203/5421/221022	PSB site, eastern end, temp fencing in site, facing SE	0.0/100	<0.01

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

24 October 2022

S110355.203/S704/221022	PSB site, eastern end, temp fencing in site, facing NE	0.0/100	<0.01
S110355.203/2048/221022	PSB site, fencing behind site sheds	0.0/100	<0.01
S110355.203/6351/221022	PSB site, northern end, temp fencing between site and compound	0.0/100	<0.01
S110355.203/S408/221022	Field Blank	0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

Analysed and reported by:



Rune Knoph

Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

24 October 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

24 October 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

25 October 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.205-AAM1.v1-25/10/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 25/10/2022
Sample Analysis Date: 25/10/2022
Period of Sampling: 25/10/2022 06:01 AM - 25/10/2022 03:11 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 15, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.205/3214/251022	MSCP site, southwestern end, adj small courtyard, between stockpile and public	1.0/100	<0.01
S110355.205/S1021/251022	MSCP site, adj to Redbank Rd, temp fencing, between clean and dirty zone	0.0/100	<0.01
S110355.205/5808/251022	MSCP site, temp fencing in middle of site, between clean and dirty zone	0.0/100	<0.01
S110355.205/S222/251022	MSCP site, northwest end of site, adj old maintenance car park, fencing	1.0/100	<0.01
S110355.205/3491/251022	PSB site, western end, fencing along CASB loading dock	0.0/100	<0.01
S110355.205/S724/251022	PSB site, eastern end, temp fencing in site, facing SE	0.0/100	<0.01
S110355.205/S1008/251022	PSB site, fencing behind site sheds	0.0/100	<0.01
S110355.205/S629/251022	PSB site, northern end, temp fencing between site and compound	0.0/100	<0.01
S110355.205/3216/251022	Mons Road, entry point	0.0/100	<0.01
S110355.205/S556/251022	Mons Road, before boom gate, fencing	0.0/100	<0.01

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

25 October 2022

S110355.205/S220/251022	PSB site, northern end, fencing along Redbank Rd	0.0/100	<0.01
S110355.205/5582/251022	PSB site, eastern end, temp fencing in site, facing NE	0.0/100	<0.01
S110355.205/S153/251022	Field Blank	0.0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

Analysed and reported by:



Rune Knoph

Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

25 October 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

25 October 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

25 October 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

26 October 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.206-AAM1.v1-26/10/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 26/10/2022
Sample Analysis Date: 26/10/2022
Period of Sampling: 26/10/2022 06:10 AM - 26/10/2022 01:36 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 15, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.206/S1010/261022	MSCP site, southwestern end, adj small courtyard, between stockpile and public	0.0/100	<0.01
S110355.206/S101/261022	MSCP site, adj to Redbank Rd, temp fencing, between clean and dirty zone	0.0/100	<0.01
S110355.206/S102/261022	MSCP site, temp fencing in middle of site, between clean and dirty zone	0.0/100	<0.01
S110355.206/S113/261022	MSCP site, northwest end of site, adj old maintenance car park, fencing	0.0/100	<0.01
S110355.206/S089/261022	PSB site, northern end, fencing along Redbank Rd	0.0/100	<0.01
S110355.206/S059/261022	PSB site, western end, fencing along CASB loading dock	0.0/100	<0.01
S110355.206/S1022/261022	PSB site, eastern end, temp fencing in site, facing SE	0.0/100	<0.01
S110355.206/S1013/261022	PSB site, eastern end, temp fencing in site, facing NE	0.0/100	<0.01
S110355.206/S979/261022	PSB site, fencing behind site sheds	1.0/100	<0.01
S110355.206/6480/261022	PSB site, northern end, temp fencing between site and compound	0.0/100	<0.01

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

26 October 2022

S110355.206/S850/261022	Mons Road, entry point	0.0/100	<0.01
S110355.206/S192/261022	Mons Road, before boom gate, fencing	1.0/100	<0.01
S110355.206/3198/261022	Field Blank	0.0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

Analysed and reported by:



Rune Knoph

Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

26 October 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

26 October 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

26 October 2022



S110355.206-AAM1.v1-ControlAsbestosAirMonitoringReport-261022

Page 5 of 5

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

28 October 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.207-AAM1.v1-27/10/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 27/10/2022
Sample Analysis Date: 28/10/2022
Period of Sampling: 27/10/2022 06:10 AM - 27/10/2022 02:13 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 15, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.207/S482/271022	MSCP site, southwestern end, adj small courtyard, between stockpile and public	0.0/100	<0.01
S110355.207/3292/271022	MSCP site, adj to Redbank Rd, temp fencing, between clean and dirty zone	0.0/100	<0.01
S110355.207/S583/271022	MSCP site, temp fencing in middle of site, between clean and dirty zone	0.0/100	<0.01
S110355.207/S335/271022	MSCP site, northwest end of site, adj old maintenance car park, fencing	0.0/100	<0.01
S110355.207/3436/271022	PSB site, northern end, fencing along Redbank Rd	0.0/100	<0.01
S110355.207/S595/271022	PSB site, western end, fencing along CASB loading dock	0.0/100	<0.01
S110355.207/S232/271022	PSB site, eastern end, temp fencing in site, facing SE	0.0/100	<0.01
S110355.207/6255/271022	PSB site, eastern end, temp fencing in site, facing NE	0.0/100	<0.01
S110355.207/S107/271022	PSB site, fencing behind site sheds	0.0/100	<0.01
S110355.207/S793/271022	PSB site, northern end, temp fencing between site and compound	0.0/100	<0.01

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

28 October 2022

S110355.207/S058/271022	Mons Road, entry point	0.0/100	<0.01
S110355.207/S231/271022	Mons Road, before boom gate, fencing	0.0/100	<0.01
S110355.207/S895/271022	Field Blank	0.0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

Analysed and reported by:



Rune Knoph

Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

28 October 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

28 October 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

28 October 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

28 October 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: danny.khal@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.208-AAM1.v1-28/10/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 28/10/2022
Sample Analysis Date: 28/10/2022
Period of Sampling: 28/10/2022 06:45 AM - 28/10/2022 01:20 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 15, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.208/9092/281022	MSCP site, southwestern end, adj small courtyard, fencing	0.0/100	<0.01
S110355.208/3417/281022	MSCP site, adj to Redbank Rd, temp fencing, between clean and dirty zone	0.0/100	<0.01
S110355.208/S444/281022	MSCP site, northwest end of site, adj old maintenance car park, fencing	1.0/100	<0.01
S110355.208/S852/281022	PSB site, northern end, fencing along Redbank Rd	0.0/100	<0.01
S110355.208/S592/281022	PSB site, western end, fencing along CASB loading dock	0.0/100	<0.01
S110355.208/S588/281022	PSB site, southern end, temp fence in site, facing SE	0.0/100	<0.01
S110355.208/S933/281022	PSB site, southern end, temp fence in site, facing NE	0.0/100	<0.01
S110355.208/S500/281022	PSB site, eastern end, fencing behind site sheds	0.0/100	<0.01
S110355.208/S846/281022	PSB site, northern end, temp fencing between site and compound	0.0/100	<0.01
S110355.208/S603/281022	Mons Rd, entry point	0.0/100	<0.01

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

28 October 2022

S110355.208/S511/281022	Mons Rd, before boom gate, fencing	0.0/100	<0.01
S110355.208/S1016/281022	MSCP site, temp fencing in middle of site, between clean and dirty zone	0.0/100	<0.01
S110355.208/S307/281022	Field Blank	0.0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

Analysed and reported by:



Rune Knoph

Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

28 October 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

28 October 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

28 October 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

31 October 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: miguel.canas@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.209-AAM1.v1-29/10/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 29/10/2022
Sample Analysis Date: 31/10/2022
Period of Sampling: 29/10/2022 06:40 AM - 29/10/2022 02:59 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 15, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.209/S601/291022	MSCP site, southwestern end, adj small courtyard, between stockpile and public	0.0/100	<0.01
S110355.209/S855/291022	MSCP site, temp fencing in middle of site, between clean and dirty zone	0.0/100	<0.01
S110355.209/S078/291022	MSCP site, adj to Redbank Rd, temp fencing, between clean and dirty zone	0.0/100	<0.01
S110355.209/8656/291022	MSCP site, northwest end of site, adj old maintenance car park, fencing	0.0/100	<0.01
S110355.209/S393/291022	PSB site, northern end, fencing along Redbank Rd	0.0/100	<0.01
S110355.209/S946/291022	PSB site, western end, fencing along CASB loading dock	0.0/100	<0.01
S110355.209/S384/291022	PSB site, eastern end, temp fencing in site, facing SE	0.0/100	<0.01
S110355.209/S098/291022	PSB site, temp fencing along sewer works in compound	0.0/100	<0.01
S110355.209/S097/291022	PSB site, fencing behind site sheds	0.0/100	<0.01

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

31 October 2022

S110355.209/S183/291022	PSB site, northern end, temp fencing between site and compound	0.0/100	<0.01
S110355.209/S571/291022	Mons Road, entry point	1.0/100	<0.01
S110355.209/S934/291022	Mons Road, before boom gate, fencing	0.0/100	<0.01
S110355.209/S197/291022	Field Blank	0.0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

Analysed and reported by:



Rune Knoph

Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

31 October 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

31 October 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

31 October 2022



S110355.209-AAM1.v1-ControlAsbestosAirMonitoringReport-291022

Page 5 of 5

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

31 October 2022

Attention: Danny Khal
Company: Ford Civil Contracting Pty Ltd
Email: miguel.canas@fordcivil.com.au
Address: 9 Hattersley Street, Arncliffe NSW 2205

SWE Report Reference: S110355.210-AAM1.v1-31/10/2022
Site Address: MSCP and PSB, Westmead Hospital
Sampling Date: 31/10/2022
Sample Analysis Date: 31/10/2022
Period of Sampling: 31/10/2022 06:40 AM - 31/10/2022 02:15 PM
Scope of Work: Air Monitoring during civil works of asbestos impacted soils
SWE Laboratory: Suite 15, 103 Majors Bay Road, Concord NSW 2137

Accreditation number: 17092

Site number: 18665

1. Introduction: Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

2. Methods: Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S110355.210/S155/311022	MSCP site, southwestern end, adj small courtyard, between stockpile and public	0.0/100	<0.01
S110355.210/5410/311022	MSCP site, adj to Redbank Rd, temp fencing, between clean and dirty zone	0.0/100	<0.01
S110355.210/2117/311022	MSCP site, temp fencing in middle of site, between clean and dirty zone	0.0/100	<0.01
S110355.210/S196/311022	MSCP site, northwest end of site, adj old maintenance car park, fencing	0.0/100	<0.01
S110355.210/S1011/311022	PSB site, northern end, fencing along Redbank Rd	0.0/100	<0.01
S110355.210/S995/311022	PSB site, western end, fencing along CASB loading dock	0.0/100	<0.01
S110355.210/S503/311022	PSB site, temp fencing adjacent sewer works, compound	1.0/100	<0.01
S110355.210/S1025/311022	PSB site, fencing behind site sheds	0.0/100	<0.01
S110355.210/S181/311022	PSB site, northern end, temp fencing between site and compound	1.0/100	<0.01
S110355.210/S832/311022	Mons Road, entry point	0.0/100	<0.01

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

31 October 2022

S110355.210/2113/311022	Mons Road, before boom gate, fencing	0.0/100	<0.01
S110355.210/S898/311022	Field Blank	0.0/100	NA

4. Conclusion: All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

Analysed and reported by:



Rune Knoph

Approved Issuer of Reports

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

31 October 2022

APPENDIX A – MONITOR LOCATIONS

CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

31 October 2022



CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

31 October 2022



S110355.210-AAM1.v1-ControlAsbestosAirMonitoringReport-311022

Page 5 of 5