

PARTICULATE MATTER (PM10) DUST MONITORING RESULTS

06 September 2022

Attention: Terry Gauci
Company: AE Smith
Fax/email: terry.gauci@aesmith.com.au
Address: Level 4, Building B, 480 Victoria Road Gladesville, NSW, 2111

WESTMEAD HOSPITAL- PSB PROJECT – REDBANK ROAD, WESTMEAD, NSW, 2145

SWE Project No.: S110356
Sampling Date: 29/08/2022 – 04/09/2022
Site Address: Westmead Hospital – PSB Site – Redbank Road, Westmead, NSW 2145
Period of Sampling: 07:00 – 16:00

DATE	SAMPLE ID.	LOCATION OF SAMPLE	Time on	Time off	Result TWA (mg/m ³)
29/08/22	S110356/905/290822	Plant Room 342 - External	07:00	16:00	0.024
29/08/22	S110356/20220113/290822	Plant Room 544 - Internal	07:00	16:00	0.014
29/08/22	S110356/220220115/290822	Ford Civil Site Sheds - External	07:00	16:00	0.007
29/08/22	S110356/20222011/290822	CASB – Level 4 Plant Room - Internal	07:00	16:00	0.012
30/08/22	S110356/905/300822	Plant Room 342 - External	07:00	16:00	0.014
30/08/22	S110356/20220113/300822	Plant Room 544 - Internal	07:00	16:00	0.007
30/08/22	S110356/220220115/300822	Ford Civil Site Sheds - External	07:00	16:00	0.003
30/08/22	S110356/20222011/300822	CASB – Level 4 Plant Room - Internal	07:00	16:00	0.007
31/08/22	S110356/905/310822	Plant Room 342 - External	07:00	16:00	0.006
31/08/22	S110356/20220113/310822	Plant Room 544 - Internal	07:00	16:00	0.006
31/08/22	S110356/220220115/310822	Ford Civil Site Sheds - External	07:00	16:00	0.003
31/08/22	S110356/20222011/310822	CASB – Level 4 Plant Room - Internal	07:00	16:00	0.005
01/09/22	S110356/905/010922	Plant Room 342 - External	07:00	16:00	0.017
01/09/22	S110356/20220113/010922	Plant Room 544 - Internal	07:00	16:00	0.013
01/09/22	S110356/220220115/010922	Ford Civil Site Sheds - External	07:00	16:00	0.006

S110356-PM10-DustMonitoring-PSB-WestmeadHospital 290822-040922

DATE	SAMPLE ID.	LOCATION OF SAMPLE	Time on	Time off	Result TWA (mg/m ³)
01/09/22	S110356/20222011/010922	CASB – Level 4 Plant Room - Internal	07:00	16:00	0.012
02/09/22	S110356/905/020922	Plant Room 342 - External	07:00	16:00	0.015
02/09/22	S110356/20220113/020922	Plant Room 544 - Internal	07:00	16:00	0.01
02/09/22	S110356/220220115/020922	Ford Civil Site Sheds - External	07:00	16:00	0.005
02/09/22	S110356/20222011/020922	CASB – Level 4 Plant Room - Internal	07:00	16:00	0.009
03/09/22	S110356/905/030922	Plant Room 342 - External	07:00	16:00	0.006
03/09/22	S110356/20220113/030922	Plant Room 544 - Internal	07:00	16:00	0.007
03/09/22	S110356/220220115/030922	Ford Civil Site Sheds - External	07:00	16:00	0.002
03/09/22	S110356/20222011/030922	CASB – Level 4 Plant Room - Internal	07:00	16:00	0.007
04/09/22	S110356/905/040922	Plant Room 342 - External	07:00	16:00	0.002
04/09/22	S110356/20220113/040922	Plant Room 544 - Internal	07:00	16:00	0.006
04/09/22	S110356/220220115/040922	Ford Civil Site Sheds - External	07:00	16:00	0.002
04/09/22	S110356/20222011/040922	CASB – Level 4 Plant Room - Internal	07:00	16:00	0.006

Sampling Description: Monitoring for atmospheric particulate matter PM10 dust was undertaken to verify the effectiveness of control measures implemented to prevent dust release as a result of the car park demolition work.

Sampling Methodology: Dust monitoring was carried out in accordance with National Environment Protection (Ambient Air Quality) Measure (2016) using a 'TSI DustTrak II Aerosol Monitor' to measure dust levels (as mg/m³). The detection limit for the method is 0.001mg/m³.

Conclusion: All dust monitoring results reported on in this report are below the maximum permissible Time Weighted Average (TWA) environmental guideline for PM10 of 0.05mg/m³ as per Table 1 of the National Environment Protection (Ambient Air Quality) Measure (2016).

Should you have any queries regarding this report please do not hesitate to contact the office on (02) 9494 0000 for further information or assistance.

Yours sincerely,

Terry Gauci | Regional Manager (Service) AE Smith, Nuvo & TGS



T1, L1, Trinity Business Campus, 39 Delhi Road, North Ryde, NSW 2113
T +61 2 9494 0000 | M +61 412 660 090
E: terry.gauci@aesmith.com.au

PARTICULATE MATTER (PM10) DUST MONITORING RESULTS

06 September 2022

Attention: Terry Gauci
Company: AE Smith
Fax/email: terry.gauci@aesmith.com.au
Address: Level 4, Building B, 480 Victoria Road Gladesville, NSW, 2111

WESTMEAD HOSPITAL– MSCP PROJECT – REDBANK ROAD, WESTMEAD, NSW, 2145

SWE Project No.: S110356
Sampling Date: 29/08/2022 – 04/09/2022
Site Address: Westmead Hospital – MSCP Site – Redbank Road, Westmead, NSW 2145
Period of Sampling: 07:00 – 16:00

DATE	SAMPLE ID.	LOCATION OF SAMPLE	Time on	Time off	Result TWA (mg/m ³)
29/08/22	S110356/20220114/290822	Plant Room 933 - External	07:00	16:00	0.004
29/08/22	S110356/20220110/290822	Plant Room 932 - External	07:00	16:00	0.014
29/08/22	S110356/85300111709/290822	Plant Room 942 - Internal	07:00	16:00	0.002
29/08/22	S110356/220220113/290822	Plant Room 941 - External	07:00	16:00	0.024
29/08/22	S110356/20220112/290822	Plant Room 943 - External	07:00	16:00	0.018
29/08/22	S110356/85301122812/290822	Plant Room 931 - External	07:00	16:00	0.015
30/08/22	S110356/20220114/300822	Plant Room 933 - External	07:00	16:00	0.002
30/08/22	S110356/20220110/300822	Plant Room 932 - External	07:00	16:00	0.006
30/08/22	S110356/85300111709/300822	Plant Room 942 - Internal	07:00	16:00	0.003
30/08/22	S110356/220220113/300822	Plant Room 941 - External	07:00	16:00	0.007
30/08/22	S110356/20220112/300822	Plant Room 943 - External	07:00	16:00	0.003
30/08/22	S110356/85301122812/300822	Plant Room 931 - External	07:00	16:00	0.008
31/08/22	S110356/20220114/310822	Plant Room 933 - External	07:00	16:00	0.008
31/08/22	S110356/20220110/310822	Plant Room 932 - External	07:00	16:00	0.006
31/08/22	S110356/85300111709/310822	Plant Room 942 - Internal	07:00	16:00	0.003
31/08/22	S110356/220220113/310822	Plant Room 941 - External	07:00	16:00	0.007

S110356-PM10-DustMonitoring-MSCP-WestmeadHospital-290822-040922

DATE	SAMPLE ID.	LOCATION OF SAMPLE	Time on	Time off	Result TWA (mg/m ³)
31/08/22	S110356/20220112/310822	Plant Room 943 - External	07:00	16:00	0.003
31/08/22	S110356/85301122812/310822	Plant Room 931 - External	07:00	16:00	0.008
01/09/22	S110356/20220114/010922	Plant Room 933 - External	07:00	16:00	0.004
01/09/22	S110356/20220110/010922	Plant Room 932 - External	07:00	16:00	0.014
01/09/22	S110356/85300111709/010922	Plant Room 942 - Internal	07:00	16:00	0.003
01/09/22	S110356/220220113/010922	Plant Room 941 - External	07:00	16:00	0.016
01/09/22	S110356/20220112/010922	Plant Room 943 - External	07:00	16:00	0.017
01/09/22	S110356/85301122812/010922	Plant Room 931 - External	07:00	16:00	0.014
02/09/22	S110356/20220114/020922	Plant Room 933 - External	07:00	16:00	0.004
02/09/22	S110356/20220110/020922	Plant Room 932 - External	07:00	16:00	0.013
02/09/22	S110356/85300111709/020922	Plant Room 942 - Internal	07:00	16:00	0.003
02/09/22	S110356/220220113/020922	Plant Room 941 - External	07:00	16:00	0.018
02/09/22	S110356/20220112/020922	Plant Room 943 - External	07:00	16:00	0.014
02/09/22	S110356/85301122812/020922	Plant Room 931 - External	07:00	16:00	0.012
03/09/22	S110356/20220114/030922	Plant Room 933 - External	07:00	16:00	0.002
03/09/22	S110356/20220110/030922	Plant Room 932 - External	07:00	16:00	0.007
03/09/22	S110356/85300111709/030922	Plant Room 942 - Internal	07:00	16:00	0.002
03/09/22	S110356/220220113/030922	Plant Room 941 - External	07:00	16:00	0.004
03/09/22	S110356/20220112/030922	Plant Room 943 - External	07:00	16:00	0.013
03/09/22	S110356/85301122812/030922	Plant Room 931 - External	07:00	16:00	0.008
04/09/22	S110356/20220114/040922	Plant Room 933 - External	07:00	16:00	0.002
04/09/22	S110356/20220110/040922	Plant Room 932 - External	07:00	16:00	0.007
04/09/22	S110356/85300111709/040922	Plant Room 942 - Internal	07:00	16:00	0.002
04/09/22	S110356/220220113/040922	Plant Room 941 - External	07:00	16:00	0.004
04/09/22	S110356/20220112/040922	Plant Room 943 - External	07:00	16:00	0.009
04/09/22	S110356/85301122812/040922	Plant Room 931 - External	07:00	16:00	0.006

S110356-PM10-DustMonitoring-MSCP-WestmeadHospital-290822-040922

Sampling Description: Monitoring for atmospheric particulate matter PM10 dust was undertaken to verify the effectiveness of control measures implemented to prevent dust release as a result of the car park demolition work.

Sampling Methodology: Dust monitoring was carried out in accordance with National Environment Protection (Ambient Air Quality) Measure (2016) using a 'TSI DustTrak II Aerosol Monitor' to measure dust levels (as mg/m³). The detection limit for the method is 0.001mg/m³.

Conclusion: All dust monitoring results reported on in this report are below the maximum permissible Time Weighted Average (TWA) environmental guideline for PM10 of 0.05mg/m³ as per Table 1 of the National Environment Protection (Ambient Air Quality) Measure (2016).

Should you have any queries regarding this report please do not hesitate to contact the office on (02) 9494 0000 for further information or assistance.

Yours sincerely,

Terry Gauci | Regional Manager (Service) AE Smith, Nuvo & TGS



T1, L1, Trinity Business Campus, 39 Delhi Road, North Ryde, NSW 2113
T +61 2 9494 0000 | M +61 412 660 090
E: terry.gauci@aesmith.com.au

PARTICULATE MATTER (PM10) DUST MONITORING RESULTS

15 September 2022

Attention: Terry Gauci
Company: AE Smith
Fax/email: terry.gauci@aesmith.com.au
Address: Level 4, Building B, 480 Victoria Road Gladesville, NSW, 2111

WESTMEAD HOSPITAL- PSB PROJECT – REDBANK ROAD, WESTMEAD, NSW, 2145

SWE Project No.: S110356
Sampling Date: 05/09/2022 – 11/09/2022
Site Address: Westmead Hospital – PSB Site – Redbank Road, Westmead, NSW 2145
Period of Sampling: 07:00 – 16:00

DATE	SAMPLE ID.	LOCATION OF SAMPLE	Time on	Time off	Result TWA (mg/m ³)
05/09/22	S110356/905/050922	Plant Room 342 - External	07:00	16:00	0.004
05/09/22	S110356/20220113/050922	Plant Room 544 - Internal	07:00	16:00	0.005
05/09/22	S110356/220220115/050922	Ford Civil Site Sheds - External	07:00	16:00	0.005
05/09/22	S110356/20222011/050922	CASB – Level 4 Plant Room - Internal	07:00	16:00	0.003
06/09/22	S110356/905/060922	Plant Room 342 - External	07:00	16:00	0.007
06/09/22	S110356/20220113/060922	Plant Room 544 - Internal	07:00	16:00	0.007
06/09/22	S110356/220220115/060922	Ford Civil Site Sheds - External	07:00	16:00	0.003
06/09/22	S110356/20222011/060922	CASB – Level 4 Plant Room - Internal	07:00	16:00	0.006
07/09/22	S110356/905/070922	Plant Room 342 - External	07:00	16:00	0.013
07/09/22	S110356/20220113/070922	Plant Room 544 - Internal	07:00	16:00	0.008
07/09/22	S110356/220220115/070922	Ford Civil Site Sheds - External	07:00	16:00	0.004
07/09/22	S110356/20222011/070922	CASB – Level 4 Plant Room - Internal	07:00	16:00	0.007
08/09/22	S110356/905/080922	Plant Room 342 - External	07:00	16:00	0.009
08/09/22	S110356/20220113/080922	Plant Room 544 - Internal	07:00	16:00	0.007
08/09/22	S110356/220220115/080922	Ford Civil Site Sheds - External	07:00	16:00	0.003

S110356-PM10-DustMonitoring-PSB-WestmeadHospital 050922-110922

DATE	SAMPLE ID.	LOCATION OF SAMPLE	Time on	Time off	Result TWA (mg/m ³)
08/09/22	S110356/20222011/080922	CASB – Level 4 Plant Room - Internal	07:00	16:00	0.007
09/09/22	S110356/905/090922	Plant Room 342 - External	07:00	16:00	0.004
09/09/22	S110356/20220113/090922	Plant Room 544 - Internal	07:00	16:00	0.004
09/09/22	S110356/220220115/090922	Ford Civil Site Sheds - External	07:00	16:00	0.002
09/09/22	S110356/20222011/090922	CASB – Level 4 Plant Room - Internal	07:00	16:00	0.005
10/09/22	S110356/905/100922	Plant Room 342 - External	07:00	16:00	0.002
10/09/22	S110356/20220113/100922	Plant Room 544 - Internal	07:00	16:00	0.002
10/09/22	S110356/220220115/100922	Ford Civil Site Sheds - External	07:00	16:00	0.001
10/09/22	S110356/20222011/100922	CASB – Level 4 Plant Room - Internal	07:00	16:00	0.003
11/09/22	S110356/905/110922	Plant Room 342 - External	07:00	16:00	0.003
11/09/22	S110356/20220113/110922	Plant Room 544 - Internal	07:00	16:00	0.004
11/09/22	S110356/220220115/110922	Ford Civil Site Sheds - External	07:00	16:00	0.002
11/09/22	S110356/20222011/110922	CASB – Level 4 Plant Room - Internal	07:00	16:00	0.004

Sampling Description: Monitoring for atmospheric particulate matter PM10 dust was undertaken to verify the effectiveness of control measures implemented to prevent dust release as a result of the car park demolition work.

Sampling Methodology: Dust monitoring was carried out in accordance with National Environment Protection (Ambient Air Quality) Measure (2016) using a 'TSI DustTrak II Aerosol Monitor' to measure dust levels (as mg/m³). The detection limit for the method is 0.001mg/m³.

Conclusion: All dust monitoring results reported on in this report are below the maximum permissible Time Weighted Average (TWA) environmental guideline for PM10 of 0.05mg/m³ as per Table 1 of the National Environment Protection (Ambient Air Quality) Measure (2016).

Should you have any queries regarding this report please do not hesitate to contact the office on (02) 9494 0000 for further information or assistance.

Yours sincerely,

Terry Gauci | Regional Manager (Service) AE Smith, Nuvo & TGS



T1, L1, Trinity Business Campus, 39 Delhi Road, North Ryde, NSW 2113
T +61 2 9494 0000 | M +61 412 660 090
E: terry.gauci@aesmith.com.au

PARTICULATE MATTER (PM10) DUST MONITORING RESULTS

15 September 2022

Attention: Terry Gauci
Company: AE Smith
Fax/email: terry.gauci@aesmith.com.au
Address: Level 4, Building B, 480 Victoria Road Gladesville, NSW, 2111

WESTMEAD HOSPITAL– MSCP PROJECT – REDBANK ROAD, WESTMEAD, NSW, 2145

SWE Project No.: S110356
Sampling Date: 05/09/2022 – 15/09/2022
Site Address: Westmead Hospital – MSCP Site – Redbank Road, Westmead, NSW 2145
Period of Sampling: 07:00 – 16:00

DATE	SAMPLE ID.	LOCATION OF SAMPLE	Time on	Time off	Result TWA (mg/m ³)
05/09/22	S110356/20220114/050922	Plant Room 933 - External	07:00	16:00	0.003
05/09/22	S110356/20220110/050922	Plant Room 932 - External	07:00	16:00	0.005
05/09/22	S110356/85300111709/050922	Plant Room 942 - Internal	07:00	16:00	0.003
05/09/22	S110356/220220113/050922	Plant Room 941 - External	07:00	16:00	0.006
05/09/22	S110356/20220112/050922	Plant Room 943 - External	07:00	16:00	0.009
05/09/22	S110356/85301122812/050922	Plant Room 931 - External	07:00	16:00	0.005
06/09/22	S110356/20220114/060922	Plant Room 933 - External	07:00	16:00	0.003
06/09/22	S110356/20220110/060922	Plant Room 932 - External	07:00	16:00	0.007
06/09/22	S110356/85300111709/060922	Plant Room 942 - Internal	07:00	16:00	0.003
06/09/22	S110356/220220113/060922	Plant Room 941 - External	07:00	16:00	0.005
06/09/22	S110356/20220112/060922	Plant Room 943 - External	07:00	16:00	0.003
06/09/22	S110356/85301122812/060922	Plant Room 931 - External	07:00	16:00	0.006
07/09/22	S110356/20220114/070922	Plant Room 933 - External	07:00	16:00	0.002
07/09/22	S110356/20220110/070922	Plant Room 932 - External	07:00	16:00	0.008
07/09/22	S110356/85300111709/070922	Plant Room 942 - Internal	07:00	16:00	0.002
07/09/22	S110356/220220113/070922	Plant Room 941 - External	07:00	16:00	0.013

S110356-PM10-DustMonitoring-MSCP-WestmeadHospital-050922-110922

DATE	SAMPLE ID.	LOCATION OF SAMPLE	Time on	Time off	Result TWA (mg/m ³)
07/09/22	S110356/20220112/070922	Plant Room 943 - External	07:00	16:00	0.014
07/09/22	S110356/85301122812/070922	Plant Room 931 - External	07:00	16:00	0.007
08/09/22	S110356/20220114/080922	Plant Room 933 - External	07:00	16:00	0.002
08/09/22	S110356/20220110/080922	Plant Room 932 - External	07:00	16:00	0.007
08/09/22	S110356/85300111709/080922	Plant Room 942 - Internal	07:00	16:00	0.002
08/09/22	S110356/220220113/080922	Plant Room 941 - External	07:00	16:00	0.008
08/09/22	S110356/20220112/080922	Plant Room 943 - External	07:00	16:00	0.003
08/09/22	S110356/85301122812/080922	Plant Room 931 - External	07:00	16:00	0.003
09/09/22	S110356/20220114/090922	Plant Room 933 - External	07:00	16:00	0.003
09/09/22	S110356/20220110/090922	Plant Room 932 - External	07:00	16:00	0.004
09/09/22	S110356/85300111709/090922	Plant Room 942 - Internal	07:00	16:00	0.002
09/09/22	S110356/220220113/090922	Plant Room 941 - External	07:00	16:00	0.006
09/09/22	S110356/20220112/090922	Plant Room 943 - External	07:00	16:00	0.003
09/09/22	S110356/85301122812/090922	Plant Room 931 - External	07:00	16:00	0.005
10/09/22	S110356/20220114/100922	Plant Room 933 - External	07:00	16:00	0.001
10/09/22	S110356/20220110/100922	Plant Room 932 - External	07:00	16:00	0.003
10/09/22	S110356/85300111709/100922	Plant Room 942 - Internal	07:00	16:00	0.002
10/09/22	S110356/220220113/100922	Plant Room 941 - External	07:00	16:00	0.004
10/09/22	S110356/20220112/100922	Plant Room 943 - External	07:00	16:00	0.009
10/09/22	S110356/85301122812/100922	Plant Room 931 - External	07:00	16:00	0.007
11/09/22	S110356/20220114/110922	Plant Room 933 - External	07:00	16:00	0.002
11/09/22	S110356/20220110/110922	Plant Room 932 - External	07:00	16:00	0.004
11/09/22	S110356/85300111709/110922	Plant Room 942 - Internal	07:00	16:00	0.001
11/09/22	S110356/220220113/110922	Plant Room 941 - External	07:00	16:00	0.005
11/09/22	S110356/20220112/110922	Plant Room 943 - External	07:00	16:00	0.007
11/09/22	S110356/85301122812/110922	Plant Room 931 - External	07:00	16:00	0.007

S110356-PM10-DustMonitoring-MSCP-WestmeadHospital-050922-110922

Sampling Description: Monitoring for atmospheric particulate matter PM10 dust was undertaken to verify the effectiveness of control measures implemented to prevent dust release as a result of the car park demolition work.

Sampling Methodology: Dust monitoring was carried out in accordance with National Environment Protection (Ambient Air Quality) Measure (2016) using a 'TSI DustTrak II Aerosol Monitor' to measure dust levels (as mg/m³). The detection limit for the method is 0.001mg/m³.

Conclusion: All dust monitoring results reported on in this report are below the maximum permissible Time Weighted Average (TWA) environmental guideline for PM10 of 0.05mg/m³ as per Table 1 of the National Environment Protection (Ambient Air Quality) Measure (2016).

Should you have any queries regarding this report please do not hesitate to contact the office on (02) 9494 0000 for further information or assistance.

Yours sincerely,

Terry Gauci | Regional Manager (Service) AE Smith, Nuvo & TGS



T1, L1, Trinity Business Campus, 39 Delhi Road, North Ryde, NSW 2113
T +61 2 9494 0000 | M +61 412 660 090
E: terry.gauci@aesmith.com.au

PARTICULATE MATTER (PM10) DUST MONITORING RESULTS

21 September 2022

Attention: Terry Gauci
Company: AE Smith
Fax/email: terry.gauci@aesmith.com.au
Address: Level 4, Building B, 480 Victoria Road Gladesville, NSW, 2111

WESTMEAD HOSPITAL- PSB PROJECT – REDBANK ROAD, WESTMEAD, NSW, 2145

SWE Project No.: S110356
Sampling Date: 12/09/2022 – 18/09/2022
Site Address: Westmead Hospital – PSB Site – Redbank Road, Westmead, NSW 2145
Period of Sampling: 07:00 – 16:00

DATE	SAMPLE ID.	LOCATION OF SAMPLE	Time on	Time off	Result TWA (mg/m ³)
12/09/22	S110356/905/120922	Plant Room 342 - External	07:00	16:00	0.004
12/09/22	S110356/20220113/120922	Plant Room 544 - Internal	07:00	16:00	0.006
12/09/22	S110356/220220115/120922	Ford Civil Site Sheds - External	07:00	16:00	0.003
12/09/22	S110356/20222011/120922	CASB – Level 4 Plant Room - Internal	07:00	16:00	0.005
13/09/22	S110356/905/130922	Plant Room 342 - External	07:00	16:00	0.005
13/09/22	S110356/20220113/130922	Plant Room 544 - Internal	07:00	16:00	0.006
13/09/22	S110356/220220115/130922	Ford Civil Site Sheds - External	07:00	16:00	0.005
13/09/22	S110356/20222011/130922	CASB – Level 4 Plant Room - Internal	07:00	16:00	0.006
14/09/22	S110356/905/140922	Plant Room 342 - External	07:00	16:00	0.005
14/09/22	S110356/20220113/140922	Plant Room 544 - Internal	07:00	16:00	0.006
14/09/22	S110356/220220115/140922	Ford Civil Site Sheds - External	07:00	16:00	0.003
14/09/22	S110356/20222011/140922	CASB – Level 4 Plant Room - Internal	07:00	16:00	0.006
15/09/22	S110356/905/150922	Plant Room 342 - External	07:00	16:00	0.015
15/09/22	S110356/20220113/150922	Plant Room 544 - Internal	07:00	16:00	0.007
15/09/22	S110356/220220115/150922	Ford Civil Site Sheds - External	07:00	16:00	0.004

S110356-PM10-DustMonitoring-PSB-WestmeadHospital 120922-180922

DATE	SAMPLE ID.	LOCATION OF SAMPLE	Time on	Time off	Result TWA (mg/m ³)
15/09/22	S110356/20222011/080922	CASB – Level 4 Plant Room - Internal	07:00	16:00	0.008
16/09/22	S110356/905/160922	Plant Room 342 - External	07:00	16:00	0.002
16/09/22	S110356/20220113/160922	Plant Room 544 - Internal	07:00	16:00	0.004
16/09/22	S110356/220220115/160922	Ford Civil Site Sheds - External	07:00	16:00	0.002
16/09/22	S110356/20222011/160922	CASB – Level 4 Plant Room - Internal	07:00	16:00	0.005
17/09/22	S110356/905/170922	Plant Room 342 - External	07:00	16:00	0.002
17/09/22	S110356/20220113/170922	Plant Room 544 - Internal	07:00	16:00	0.004
17/09/22	S110356/220220115/170922	Ford Civil Site Sheds - External	07:00	16:00	0.002
17/09/22	S110356/20222011/170922	CASB – Level 4 Plant Room - Internal	07:00	16:00	0.005
18/09/22	S110356/905/180922	Plant Room 342 - External	07:00	16:00	0.001
18/09/22	S110356/20220113/180922	Plant Room 544 - Internal	07:00	16:00	0.003
18/09/22	S110356/220220115/180922	Ford Civil Site Sheds - External	07:00	16:00	0.001
18/09/22	S110356/20222011/180922	CASB – Level 4 Plant Room - Internal	07:00	16:00	0.004

Sampling Description: Monitoring for atmospheric particulate matter PM10 dust was undertaken to verify the effectiveness of control measures implemented to prevent dust release as a result of the car park demolition work.

Sampling Methodology: Dust monitoring was carried out in accordance with National Environment Protection (Ambient Air Quality) Measure (2016) using a 'TSI DustTrak II Aerosol Monitor' to measure dust levels (as mg/m³). The detection limit for the method is 0.001mg/m³.

Conclusion: All dust monitoring results reported on in this report are below the maximum permissible Time Weighted Average (TWA) environmental guideline for PM10 of 0.05mg/m³ as per Table 1 of the National Environment Protection (Ambient Air Quality) Measure (2016).

Should you have any queries regarding this report please do not hesitate to contact the office on (02) 9494 0000 for further information or assistance.

Yours sincerely,

Terry Gauci | Regional Manager (Service) AE Smith, Nuvo & TGS



T1, L1, Trinity Business Campus, 39 Delhi Road, North Ryde, NSW 2113
T +61 2 9494 0000 | M +61 412 660 090
E: terry.gauci@aesmith.com.au

PARTICULATE MATTER (PM10) DUST MONITORING RESULTS

21 September 2022

Attention: Terry Gauci
Company: AE Smith
Fax/email: terry.gauci@aesmith.com.au
Address: Level 4, Building B, 480 Victoria Road Gladesville, NSW, 2111

WESTMEAD HOSPITAL– MSCP PROJECT – REDBANK ROAD, WESTMEAD, NSW, 2145

SWE Project No.: S110356
Sampling Date: 12/09/2022 – 18/09/2022
Site Address: Westmead Hospital – MSCP Site – Redbank Road, Westmead, NSW 2145
Period of Sampling: 07:00 – 16:00

DATE	SAMPLE ID.	LOCATION OF SAMPLE	Time on	Time off	Result TWA (mg/m ³)
12/09/22	S110356/20220114/120922	Plant Room 933 - External	07:00	16:00	0.002
12/09/22	S110356/20220110/120922	Plant Room 932 - External	07:00	16:00	0.005
12/09/22	S110356/85300111709/120922	Plant Room 942 - Internal	07:00	16:00	0.002
12/09/22	S110356/220220113/120922	Plant Room 941 - External	07:00	16:00	0.004
12/09/22	S110356/20220112/120922	Plant Room 943 - External	07:00	16:00	0.006
12/09/22	S110356/85301122812/120922	Plant Room 931 - External	07:00	16:00	0.004
13/09/22	S110356/20220114/130922	Plant Room 933 - External	07:00	16:00	0.003
13/09/22	S110356/20220110/130922	Plant Room 932 - External	07:00	16:00	0.007
13/09/22	S110356/85300111709/130922	Plant Room 942 - Internal	07:00	16:00	0.003
13/09/22	S110356/220220113/130922	Plant Room 941 - External	07:00	16:00	0.008
13/09/22	S110356/20220112/130922	Plant Room 943 - External	07:00	16:00	0.01
13/09/22	S110356/85301122812/130922	Plant Room 931 - External	07:00	16:00	0.007
14/09/22	S110356/20220114/140922	Plant Room 933 - External	07:00	16:00	0.001
14/09/22	S110356/20220110/140922	Plant Room 932 - External	07:00	16:00	0.006
14/09/22	S110356/85300111709/140922	Plant Room 942 - Internal	07:00	16:00	0.002
14/09/22	S110356/220220113/140922	Plant Room 941 - External	07:00	16:00	0.006

S110356-PM10-DustMonitoring-MSCP-WestmeadHospital-120922-180922

DATE	SAMPLE ID.	LOCATION OF SAMPLE	Time on	Time off	Result TWA (mg/m ³)
14/09/22	S110356/20220112/140922	Plant Room 943 - External	07:00	16:00	0.008
14/09/22	S110356/85301122812/140922	Plant Room 931 - External	07:00	16:00	0.006
15/09/22	S110356/20220114/150922	Plant Room 933 - External	07:00	16:00	0.002
15/09/22	S110356/20220110/150922	Plant Room 932 - External	07:00	16:00	0.008
15/09/22	S110356/85300111709/150922	Plant Room 942 - Internal	07:00	16:00	0.002
15/09/22	S110356/220220113/150922	Plant Room 941 - External	07:00	16:00	0.013
15/09/22	S110356/20220112/150922	Plant Room 943 - External	07:00	16:00	0.01
15/09/22	S110356/85301122812/150922	Plant Room 931 - External	07:00	16:00	0.008
16/09/22	S110356/20220114/160922	Plant Room 933 - External	07:00	16:00	0.002
16/09/22	S110356/20220110/160922	Plant Room 932 - External	07:00	16:00	0.003
16/09/22	S110356/85300111709/160922	Plant Room 942 - Internal	07:00	16:00	0.001
16/09/22	S110356/220220113/160922	Plant Room 941 - External	07:00	16:00	0.005
16/09/22	S110356/20220112/160922	Plant Room 943 - External	07:00	16:00	0.004
16/09/22	S110356/85301122812/160922	Plant Room 931 - External	07:00	16:00	0.003
17/09/22	S110356/20220114/170922	Plant Room 933 - External	07:00	16:00	0.001
17/09/22	S110356/20220110/170922	Plant Room 932 - External	07:00	16:00	0.006
17/09/22	S110356/85300111709/170922	Plant Room 942 - Internal	07:00	16:00	0.002
17/09/22	S110356/220220113/170922	Plant Room 941 - External	07:00	16:00	0.007
17/09/22	S110356/20220112/170922	Plant Room 943 - External	07:00	16:00	0.007
17/09/22	S110356/85301122812/170922	Plant Room 931 - External	07:00	16:00	0.005
18/09/22	S110356/20220114/180922	Plant Room 933 - External	07:00	16:00	0.001
18/09/22	S110356/20220110/180922	Plant Room 932 - External	07:00	16:00	0.002
18/09/22	S110356/85300111709/180922	Plant Room 942 - Internal	07:00	16:00	0.002
18/09/22	S110356/220220113/180922	Plant Room 941 - External	07:00	16:00	0.003
18/09/22	S110356/20220112/180922	Plant Room 943 - External	07:00	16:00	0.004
18/09/22	S110356/85301122812/180922	Plant Room 931 - External	07:00	16:00	0.003

S110356-PM10-DustMonitoring-MSCP-WestmeadHospital-120922-180922

Sampling Description: Monitoring for atmospheric particulate matter PM10 dust was undertaken to verify the effectiveness of control measures implemented to prevent dust release as a result of the car park demolition work.

Sampling Methodology: Dust monitoring was carried out in accordance with National Environment Protection (Ambient Air Quality) Measure (2016) using a 'TSI DustTrak II Aerosol Monitor' to measure dust levels (as mg/m³). The detection limit for the method is 0.001mg/m³.

Conclusion: All dust monitoring results reported on in this report are below the maximum permissible Time Weighted Average (TWA) environmental guideline for PM10 of 0.05mg/m³ as per Table 1 of the National Environment Protection (Ambient Air Quality) Measure (2016).

Should you have any queries regarding this report please do not hesitate to contact the office on (02) 9494 0000 for further information or assistance.

Yours sincerely,

Terry Gauci | Regional Manager (Service) AE Smith, Nuvo & TGS



T1, L1, Trinity Business Campus, 39 Delhi Road, North Ryde, NSW 2113
T +61 2 9494 0000 | M +61 412 660 090
E: terry.gauci@aesmith.com.au

PARTICULATE MATTER (PM10) DUST MONITORING RESULTS

28 September 2022

Attention: Terry Gauci
Company: AE Smith
Fax/email: terry.gauci@aesmith.com.au
Address: Level 4, Building B, 480 Victoria Road Gladesville, NSW, 2111

WESTMEAD HOSPITAL- PSB PROJECT – REDBANK ROAD, WESTMEAD, NSW, 2145

SWE Project No.: S110356
Sampling Date: 19/09/2022 – 25/09/2022
Site Address: Westmead Hospital – PSB Site – Redbank Road, Westmead, NSW 2145
Period of Sampling: 07:00 – 16:00

DATE	SAMPLE ID.	LOCATION OF SAMPLE	Time on	Time off	Result TWA (mg/m ³)
19/09/22	S110356/905/190922	Plant Room 342 - External	07:00	16:00	0.009
19/09/22	S110356/20220113/190922	Plant Room 544 - Internal	07:00	16:00	0.006
19/09/22	S110356/220220115/190922	Ford Civil Site Sheds - External	07:00	16:00	0.003
19/09/22	S110356/20222011/190922	CASB – Level 4 Plant Room - Internal	07:00	16:00	0.007
20/09/22	S110356/905/200922	Plant Room 342 - External	07:00	16:00	0.006
20/09/22	S110356/20220113/200922	Plant Room 544 - Internal	07:00	16:00	0.007
20/09/22	S110356/220220115/200922	Ford Civil Site Sheds - External	07:00	16:00	0.002
20/09/22	S110356/20222011/200922	CASB – Level 4 Plant Room - Internal	07:00	16:00	0.007
21/09/22	S110356/905/210922	Plant Room 342 - External	07:00	16:00	0.016
21/09/22	S110356/20220113/210922	Plant Room 544 - Internal	07:00	16:00	0.014
21/09/22	S110356/220220115/210922	Ford Civil Site Sheds - External	07:00	16:00	0.005
21/09/22	S110356/20222011/210922	CASB – Level 4 Plant Room - Internal	07:00	16:00	0.009
22/09/22	S110356/905/220922	Plant Room 342 - External	07:00	16:00	0.044
22/09/22	S110356/20220113/220922	Plant Room 544 - Internal	07:00	16:00	0.011
22/09/22	S110356/220220115/220922	Ford Civil Site Sheds - External	07:00	16:00	0.004

S110356-PM10-DustMonitoring-PSB-WestmeadHospital 190922-250922

DATE	SAMPLE ID.	LOCATION OF SAMPLE	Time on	Time off	Result TWA (mg/m ³)
22/09/22	S110356/20222011/220922	CASB – Level 4 Plant Room - Internal	07:00	16:00	0.01
23/09/22	S110356/905/230922	Plant Room 342 - External	07:00	16:00	0.01
23/09/22	S110356/20220113/230922	Plant Room 544 - Internal	07:00	16:00	0.014
23/09/22	S110356/220220115/230922	Ford Civil Site Sheds - External	07:00	16:00	0.005
23/09/22	S110356/20222011/230922	CASB – Level 4 Plant Room - Internal	07:00	16:00	0.012
24/09/22	S110356/905/240922	Plant Room 342 - External	07:00	16:00	0.01
24/09/22	S110356/20220113/240922	Plant Room 544 - Internal	07:00	16:00	0.01
24/09/22	S110356/220220115/240922	Ford Civil Site Sheds - External	07:00	16:00	0.004
24/09/22	S110356/20222011/240922	CASB – Level 4 Plant Room - Internal	07:00	16:00	0.008
25/09/22	S110356/905/250922	Plant Room 342 - External	07:00	16:00	0.006
25/09/22	S110356/20220113/250922	Plant Room 544 - Internal	07:00	16:00	0.004
25/09/22	S110356/220220115/250922	Ford Civil Site Sheds - External	07:00	16:00	0.002
25/09/22	S110356/20222011/250922	CASB – Level 4 Plant Room - Internal	07:00	16:00	0.005

Sampling Description: Monitoring for atmospheric particulate matter PM10 dust was undertaken to verify the effectiveness of control measures implemented to prevent dust release as a result of the car park demolition work.

Sampling Methodology: Dust monitoring was carried out in accordance with National Environment Protection (Ambient Air Quality) Measure (2016) using a 'TSI DustTrak II Aerosol Monitor' to measure dust levels (as mg/m³). The detection limit for the method is 0.001mg/m³.

Conclusion: All dust monitoring results reported on in this report are below the maximum permissible Time Weighted Average (TWA) environmental guideline for PM10 of 0.05mg/m³ as per Table 1 of the National Environment Protection (Ambient Air Quality) Measure (2016).

Should you have any queries regarding this report please do not hesitate to contact the office on (02) 9494 0000 for further information or assistance.

Yours sincerely,

Terry Gauci | Regional Manager (Service) AE Smith, Nuvo & TGS



T1, L1, Trinity Business Campus, 39 Delhi Road, North Ryde, NSW 2113
T +61 2 9494 0000 | M +61 412 660 090
E: terry.gauci@aesmith.com.au

PARTICULATE MATTER (PM10) DUST MONITORING RESULTS

28 September 2022

Attention: Terry Gauci
Company: AE Smith
Fax/email: terry.gauci@aesmith.com.au
Address: Level 4, Building B, 480 Victoria Road Gladesville, NSW, 2111

WESTMEAD HOSPITAL– MSCP PROJECT – REDBANK ROAD, WESTMEAD, NSW, 2145

SWE Project No.: S110356
Sampling Date: 19/09/2022 – 25/09/2022
Site Address: Westmead Hospital – MSCP Site – Redbank Road, Westmead, NSW 2145
Period of Sampling: 07:00 – 16:00

DATE	SAMPLE ID.	LOCATION OF SAMPLE	Time on	Time off	Result TWA (mg/m ³)
19/09/22	S110356/20220114/190922	Plant Room 933 - External	07:00	16:00	0.002
19/09/22	S110356/20220110/190922	Plant Room 932 - External	07:00	16:00	0.003
19/09/22	S110356/85300111709/190922	Plant Room 942 - Internal	07:00	16:00	0.001
19/09/22	S110356/220220113/190922	Plant Room 941 - External	07:00	16:00	NA*
19/09/22	S110356/20220112/190922	Plant Room 943 - External	07:00	16:00	0.006
19/09/22	S110356/85301122812/190922	Plant Room 931 - External	07:00	16:00	0.003
20/09/22	S110356/20220114/200922	Plant Room 933 - External	07:00	16:00	0.002
20/09/22	S110356/20220110/200922	Plant Room 932 - External	07:00	16:00	0.007
20/09/22	S110356/85300111709/200922	Plant Room 942 - Internal	07:00	16:00	0.002
20/09/22	S110356/220220113/200922	Plant Room 941 - External	07:00	16:00	NA*
20/09/22	S110356/20220112/200922	Plant Room 943 - External	07:00	16:00	0.009
20/09/22	S110356/85301122812/200922	Plant Room 931 - External	07:00	16:00	0.006
21/09/22	S110356/20220114/210922	Plant Room 933 - External	07:00	16:00	0.004
21/09/22	S110356/20220110/210922	Plant Room 932 - External	07:00	16:00	0.014
21/09/22	S110356/85300111709/210922	Plant Room 942 - Internal	07:00	16:00	0.004
21/09/22	S110356/220220113/210922	Plant Room 941 - External	07:00	16:00	NA*

S110356-PM10-DustMonitoring-MSCP-WestmeadHospital-190922-250922

DATE	SAMPLE ID.	LOCATION OF SAMPLE	Time on	Time off	Result TWA (mg/m ³)
21/09/22	S110356/20220112/210922	Plant Room 943 - External	07:00	16:00	0.02
21/09/22	S110356/85301122812/210922	Plant Room 931 - External	07:00	16:00	0.013
22/09/22	S110356/20220114/220922	Plant Room 933 - External	07:00	16:00	0.002
22/09/22	S110356/20220110/220922	Plant Room 932 - External	07:00	16:00	0.013
22/09/22	S110356/85300111709/220922	Plant Room 942 - Internal	07:00	16:00	0.005
22/09/22	S110356/220220113/220922	Plant Room 941 - External	07:00	16:00	NA*
22/09/22	S110356/20220112/220922	Plant Room 943 - External	07:00	16:00	0.016
22/09/22	S110356/85301122812/220922	Plant Room 931 - External	07:00	16:00	0.013
23/09/22	S110356/20220114/230922	Plant Room 933 - External	07:00	16:00	0.006
23/09/22	S110356/20220110/230922	Plant Room 932 - External	07:00	16:00	0.004
23/09/22	S110356/85300111709/230922	Plant Room 942 - Internal	07:00	16:00	0.004
23/09/22	S110356/220220113/230922	Plant Room 941 - External	07:00	16:00	NA*
23/09/22	S110356/20220112/230922	Plant Room 943 - External	07:00	16:00	0.02
23/09/22	S110356/85301122812/230922	Plant Room 931 - External	07:00	16:00	0.015
24/09/22	S110356/20220114/240922	Plant Room 933 - External	07:00	16:00	0.003
24/09/22	S110356/20220110/240922	Plant Room 932 - External	07:00	16:00	0.01
24/09/22	S110356/85300111709/240922	Plant Room 942 - Internal	07:00	16:00	0.004
24/09/22	S110356/220220113/240922	Plant Room 941 - External	07:00	16:00	NA*
24/09/22	S110356/20220112/240922	Plant Room 943 - External	07:00	16:00	0.013
24/09/22	S110356/85301122812/240922	Plant Room 931 - External	07:00	16:00	0.01
25/09/22	S110356/20220114/250922	Plant Room 933 - External	07:00	16:00	0.003
25/09/22	S110356/20220110/250922	Plant Room 932 - External	07:00	16:00	0.003
25/09/22	S110356/85300111709/250922	Plant Room 942 - Internal	07:00	16:00	0.001
25/09/22	S110356/220220113/250922	Plant Room 941 - External	07:00	16:00	NA*
25/09/22	S110356/20220112/250922	Plant Room 943 - External	07:00	16:00	0.005
25/09/22	S110356/85301122812/250922	Plant Room 931 - External	07:00	16:00	0.003

S110356-PM10-DustMonitoring-MSCP-WestmeadHospital-190922-250922

*NA: Dustrack sent for servicing

Sampling Description: Monitoring for atmospheric particulate matter PM10 dust was undertaken to verify the effectiveness of control measures implemented to prevent dust release as a result of the car park demolition work.

Sampling Methodology: Dust monitoring was carried out in accordance with National Environment Protection (Ambient Air Quality) Measure (2016) using a 'TSI DustTrak II Aerosol Monitor' to measure dust levels (as mg/m³). The detection limit for the method is 0.001mg/m³.

Conclusion: All dust monitoring results reported on in this report are below the maximum permissible Time Weighted Average (TWA) environmental guideline for PM10 of 0.05mg/m³ as per Table 1 of the National Environment Protection (Ambient Air Quality) Measure (2016).

Should you have any queries regarding this report please do not hesitate to contact the office on (02) 9494 0000 for further information or assistance.

Yours sincerely,

Terry Gauci | Regional Manager (Service) AE Smith, Nuvo & TGS



T1, L1, Trinity Business Campus, 39 Delhi Road, North Ryde, NSW 2113
T +61 2 9494 0000 | M +61 412 660 090
E: terry.gauci@aesmith.com.au

PARTICULATE MATTER (PM10) DUST MONITORING RESULTS

05 October 2022

Attention: Terry Gauci
Company: AE Smith
Fax/email: terry.gauci@aesmith.com.au
Address: Level 4, Building B, 480 Victoria Road Gladesville, NSW, 2111

WESTMEAD HOSPITAL- PSB PROJECT – REDBANK ROAD, WESTMEAD, NSW, 2145

SWE Project No.: S110356
Sampling Date: 26/09/2022 – 03/10/2022
Site Address: Westmead Hospital – PSB Site – Redbank Road, Westmead, NSW 2145
Period of Sampling: 07:00 – 16:00

DATE	SAMPLE ID.	LOCATION OF SAMPLE	Time on	Time off	Result TWA (mg/m ³)
26/09/22	S110356/905/260922	Plant Room 342 - External	07:00	16:00	0.015
26/09/22	S110356/20220113/260922	Plant Room 544 - Internal	07:00	16:00	0.005
26/09/22	S110356/20222011/260922	Ford Civil Site Sheds - External	07:00	16:00	0.002
26/09/22	S110356/202220115/260922	CASB – Level 4 Plant Room - Internal	07:00	16:00	*NA
27/09/22	S110356/905/270922	Plant Room 342 - External	07:00	16:00	0.02
27/09/22	S110356/20220113/270922	Plant Room 544 - Internal	07:00	16:00	0.01
27/09/22	S110356/20222011/270922	Ford Civil Site Sheds - External	07:00	16:00	0.005
27/09/22	S110356/202220115/270922	CASB – Level 4 Plant Room - Internal	07:00	16:00	*NA
28/09/22	S110356/905/280922	Plant Room 342 - External	07:00	16:00	0.006
28/09/22	S110356/20220113/280922	Plant Room 544 - Internal	07:00	16:00	0.005
28/09/22	S110356/20222011/280922	Ford Civil Site Sheds - External	07:00	16:00	0.003
28/09/22	S110356/202220115/280922	CASB – Level 4 Plant Room - Internal	07:00	16:00	*NA
29/09/22	S110356/905/290922	Plant Room 342 - External	07:00	16:00	0.005
29/09/22	S110356/20220113/290922	Plant Room 544 - Internal	07:00	16:00	0.002
29/09/22	S110356/20222011/290922	Ford Civil Site Sheds - External	07:00	16:00	0.001

S110356-PM10-DustMonitoring-PSB-WestmeadHospital 260922-031022

DATE	SAMPLE ID.	LOCATION OF SAMPLE	Time on	Time off	Result TWA (mg/m ³)
29/09/22	S110356/202220115/290922	CASB – Level 4 Plant Room - Internal	07:00	16:00	*NA
30/09/22	S110356/905/300922	Plant Room 342 - External	07:00	16:00	0.011
30/09/22	S110356/20220113/300922	Plant Room 544 - Internal	07:00	16:00	0.005
30/09/22	S110356/20222011/300922	Ford Civil Site Sheds - External	07:00	16:00	0.001
30/09/22	S110356/202220115/300922	CASB – Level 4 Plant Room - Internal	07:00	16:00	*NA
01/10/22	S110356/905/011022	Plant Room 342 - External	07:00	16:00	0.009
01/10/22	S110356/20220113/011022	Plant Room 544 - Internal	07:00	16:00	0.008
01/10/22	S110356/20222011/011022	Ford Civil Site Sheds - External	07:00	16:00	0.004
01/10/22	S110356/202220115/011022	CASB – Level 4 Plant Room - Internal	07:00	16:00	*NA
02/10/22	S110356/905/021022	Plant Room 342 - External	07:00	16:00	0.017
02/10/22	S110356/20220113/021022	Plant Room 544 - Internal	07:00	16:00	0.003
02/10/22	S110356/20222011/021022	Ford Civil Site Sheds - External	07:00	16:00	0.001
02/10/22	S110356/202220115/021022	CASB – Level 4 Plant Room - Internal	07:00	16:00	*NA
03/10/22	S110356/905/031022	Plant Room 342 - External	07:00	16:00	0.005
03/10/22	S110356/20220113/031022	Plant Room 544 – External	07:00	16:00	0.004
03/10/22	S110356/20222011/031022	Ford Civil Site Sheds - External	07:00	16:00	0.001
03/10/22	S110356/202220115/031022	CASB – Level 4 Plant Room - Internal	07:00	16:00	*NA

*Data not collected due to the security office being closed at time of collection

Sampling Description: Monitoring for atmospheric particulate matter PM10 dust was undertaken to verify the effectiveness of control measures implemented to prevent dust release as a result of the car park demolition work.

Sampling Methodology: Dust monitoring was carried out in accordance with National Environment Protection (Ambient Air Quality) Measure (2016) using a 'TSI DustTrak II Aerosol Monitor' to measure dust levels (as mg/m³). The detection limit for the method is 0.001mg/m³.

Conclusion: All dust monitoring results reported on in this report are below the maximum permissible Time Weighted Average (TWA) environmental guideline for PM10 of 0.05mg/m³ as per Table 1 of the National Environment Protection (Ambient Air Quality) Measure (2016).

Should you have any queries regarding this report please do not hesitate to contact the office on (02) 9494 0000 for further information or assistance.

Yours sincerely,

Terry Gauci | Regional Manager (Service) AE Smith, Nuvo & TGS



T1, L1, Trinity Business Campus, 39 Delhi Road, North Ryde, NSW 2113
T +61 2 9494 0000 | M +61 412 660 090
E: terry.gauci@aesmith.com.au

PARTICULATE MATTER (PM10) DUST MONITORING RESULTS

05 October 2022

Attention: Terry Gauci
Company: AE Smith
Fax/email: terry.gauci@aesmith.com.au
Address: Level 4, Building B, 480 Victoria Road Gladesville, NSW, 2111

WESTMEAD HOSPITAL– MSCP PROJECT – REDBANK ROAD, WESTMEAD, NSW, 2145

SWE Project No.: S110356
Sampling Date: 26/09/2022 – 03/10/2022
Site Address: Westmead Hospital – MSCP Site – Redbank Road, Westmead, NSW 2145
Period of Sampling: 07:00 – 16:00

DATE	SAMPLE ID.	LOCATION OF SAMPLE	Time on	Time off	Result TWA (mg/m ³)
26/09/22	S110356/20220114/260922	Plant Room 933 - External	07:00	16:00	0.002
26/09/22	S110356/20220110/260922	Plant Room 932 - External	07:00	16:00	0.003
26/09/22	S110356/85300111709/260922	Plant Room 942 - Internal	07:00	16:00	0.003
26/09/22	S110356/220220113/260922	Plant Room 941 - External	07:00	16:00	NA*
26/09/22	S110356/20220112/260922	Plant Room 943 - External	07:00	16:00	0.004
26/09/22	S110356/85301122812/260922	Plant Room 931 - External	07:00	16:00	0.005
27/09/22	S110356/20220114/270922	Plant Room 933 - External	07:00	16:00	0.002
27/09/22	S110356/20220110/270922	Plant Room 932 - External	07:00	16:00	0.01
27/09/22	S110356/85300111709/270922	Plant Room 942 - Internal	07:00	16:00	0.003
27/09/22	S110356/220220113/270922	Plant Room 941 - External	07:00	16:00	NA*
27/09/22	S110356/20220112/270922	Plant Room 943 - External	07:00	16:00	0.013
27/09/22	S110356/85301122812/270922	Plant Room 931 - External	07:00	16:00	0.01
28/09/22	S110356/20220114/280922	Plant Room 933 - External	07:00	16:00	0.001
28/09/22	S110356/20220110/280922	Plant Room 932 - External	07:00	16:00	0.004
28/09/22	S110356/85300111709/280922	Plant Room 942 - Internal	07:00	16:00	0.002
28/09/22	S110356/220220113/280922	Plant Room 941 - External	07:00	16:00	NA*

S110356-PM10-DustMonitoring-MSCP-WestmeadHospital-260922-031022

DATE	SAMPLE ID.	LOCATION OF SAMPLE	Time on	Time off	Result TWA (mg/m ³)
28/09/22	S110356/20220112/280922	Plant Room 943 - External	07:00	16:00	0.008
28/09/22	S110356/85301122812/280922	Plant Room 931 - External	07:00	16:00	0.005
29/09/22	S110356/20220114/290922	Plant Room 933 - External	07:00	16:00	0.003
29/09/22	S110356/20220110/290922	Plant Room 932 - External	07:00	16:00	0.002
29/09/22	S110356/85300111709/290922	Plant Room 942 - Internal	07:00	16:00	0.002
29/09/22	S110356/220220113/290922	Plant Room 941 - External	07:00	16:00	NA*
29/09/22	S110356/20220112/290922	Plant Room 943 - External	07:00	16:00	0.003
29/09/22	S110356/85301122812/290922	Plant Room 931 - External	07:00	16:00	0.002
30/09/22	S110356/20220114/300922	Plant Room 933 - External	07:00	16:00	0.006
30/09/22	S110356/20220110/300922	Plant Room 932 - External	07:00	16:00	0.006
30/09/22	S110356/85300111709/300922	Plant Room 942 - Internal	07:00	16:00	0.017
30/09/22	S110356/220220113/300922	Plant Room 941 - External	07:00	16:00	NA*
30/09/22	S110356/20220112/300922	Plant Room 943 - External	07:00	16:00	0.011
30/09/22	S110356/85301122812/300922	Plant Room 931 - External	07:00	16:00	0.012
01/10/22	S110356/20220114/011022	Plant Room 933 - External	07:00	16:00	0.002
01/10/22	S110356/20220110/011022	Plant Room 932 - External	07:00	16:00	0.009
01/10/22	S110356/85300111709/011022	Plant Room 942 - Internal	07:00	16:00	0.003
01/10/22	S110356/220220113/011022	Plant Room 941 - External	07:00	16:00	NA*
01/10/22	S110356/20220112/011022	Plant Room 943 - External	07:00	16:00	0.011
01/10/22	S110356/85301122812/011022	Plant Room 931 - External	07:00	16:00	0.009
02/10/22	S110356/20220114/021022	Plant Room 933 - External	07:00	16:00	0.003
02/10/22	S110356/20220110/021022	Plant Room 932 - External	07:00	16:00	0.003
02/10/22	S110356/85300111709/021022	Plant Room 942 - Internal	07:00	16:00	0.001
02/10/22	S110356/220220113/021022	Plant Room 941 - External	07:00	16:00	NA*
02/10/22	S110356/20220112/021022	Plant Room 943 - External	07:00	16:00	0.005
02/10/22	S110356/85301122812/021022	Plant Room 931 - External	07:00	16:00	0.003

S110356-PM10-DustMonitoring-MSCP-WestmeadHospital-260922-031022

*NA: Dustrack sent for servicing

DATE	SAMPLE ID.	LOCATION OF SAMPLE	Time on	Time off	Result TWA (mg/m ³)
03/10/22	S110356/20220114/031022	Plant Room 933 - External	07:00	16:00	0.001
03/10/22	S110356/20220110/031022	Plant Room 932 - External	07:00	16:00	0.003
03/10/22	S110356/85300111709/031022	Plant Room 942 - Internal	07:00	16:00	0.002
03/10/22	S110356/220220113/031022	Plant Room 941 - External	07:00	16:00	NA*
03/10/22	S110356/20220112/031022	Plant Room 943 - External	07:00	16:00	0.006
03/10/22	S110356/85301122812/031022	Plant Room 931 - External	07:00	16:00	0.003

Sampling Description: Monitoring for atmospheric particulate matter PM10 dust was undertaken to verify the effectiveness of control measures implemented to prevent dust release as a result of the car park demolition work.

Sampling Methodology: Dust monitoring was carried out in accordance with National Environment Protection (Ambient Air Quality) Measure (2016) using a 'TSI DustTrak II Aerosol Monitor' to measure dust levels (as mg/m³). The detection limit for the method is 0.001mg/m³.

Conclusion: All dust monitoring results reported on in this report are below the maximum permissible Time Weighted Average (TWA) environmental guideline for PM10 of 0.05mg/m³ as per Table 1 of the National Environment Protection (Ambient Air Quality) Measure (2016).

Should you have any queries regarding this report please do not hesitate to contact the office on (02) 9494 0000 for further information or assistance.

Yours sincerely,

Terry Gauci | Regional Manager (Service) AE Smith, Nuvo & TGS



T1, L1, Trinity Business Campus, 39 Delhi Road, North Ryde, NSW 2113
T +61 2 9494 0000 | M +61 412 660 090
E: terry.gauci@aesmith.com.au