

Memorandum

ARUP

To	Travis Searle	Date	23 August 2021
Copies	Samuel Grieve	Reference number	
From	Pranav Rawal	File reference	
Subject	Campbelltown Hospital Redevelopment: Summary of Recently Recorded Vibration Data		

This memo summarises the vibration data collected over the past week of 15/08/2021 to 21/08/2021 at the Medical Imaging Facility at Campbelltown Hospital.

Figure 1 below shows the measured vibration levels at the Medical Imaging Facility and is presented against various acceptability criteria. For reference, the current trigger level, based on typical equipment is $V_{RMS} = 0.0375$ mm/s.




Figure 1: Measured vibration levels for 15/08/2021 to 21/08/2021 at the Medical Imaging Facility

All events that exceed the trigger level during the monitored period are reported below.

Memorandum

Table 1: Table of events exceeding acceptability criteria

Date	Peak 1/3rd Octave Band V_{RMS} Vibration Level (mm/s)
20/08/2021 09:30	0.0419

Further investigations of vibration patterns at times of exceedances can be performed upon request.