

Noise Monitoring - St George Hospital Stage 3

Review Date: 31/01/25



Level	Date	Time	Decibels (dBa)	Noise Exceedance (Yes/No)	Comments
Outside Sleep Clinic	15-Jan-25	8:07:00 AM	65	No	Construction noise, general foot traffic and chatter, general foot traffic and chatter
Outside Radiology	15-Jan-25	8:10:00 AM	54.6	No	Construction noise, general foot traffic and chatter
Outside Burt Neilson	15-Jan-25	8:11:00 AM	58.7	No	Construction noise, general foot traffic and chatter
Outside Sleep Clinic	22-Jan-25	8:55:00 AM	63.8	No	Construction noise, general traffic noise from road, general foot traffic and chatter
Outside Radiology	22-Jan-25	8:57:00 AM	50.6	No	Construction noise, general foot traffic and chatter
Outside Burt Neilson	22-Jan-25	8:59:00 AM	59.8	No	Construction noise, general foot traffic and chatter

KEY:

- OUTSIDE SLEEP CLINIC
- OUTSIDE BURT NEILSON
- OUTSIDE RADIOLOGY

KENSINGTON ST



SGH3

AED
FIRST AID ROOM
SITE AMENITIES

BELGRAVE ST