

Noise Monitoring - St George Hospital Stage 3

Review Date: 31/10/2024



Level	Date	Time	Decibels (dBa)	Noise Exceedance (Yes/No)	Comments
Outside Sleep Clinic	11-Oct-24	3:16:00 PM	62.9	No	Construction noise, general foot traffic and chatter, general foot traffic and chatter
Outside Radiology	11-Oct-24	3:25:00 PM	44.6	No	Construction noise, general foot traffic and chatter
Outside Burt Neilson	11-Oct-24	3:24:00 PM	56.7	No	Construction noise, general foot traffic and chatter
Outside Sleep Clinic	17-Oct-24	12:56:00 PM	65.5	No	Construction noise, general traffic noise from road, general foot traffic and chatter
Outside Radiology	17-Oct-24	12:59:00 PM	59.1	No	Construction noise, general foot traffic and chatter
Outside Burt Neilson	17-Oct-24	12:59:00 PM	54.4	No	Construction noise, general foot traffic and chatter
Outside Sleep Clinic	22-Oct-24	7:40:00 AM	65.8	No	Construction noise, general traffic noise from road, general foot traffic and chatter
Outside Radiology	22-Oct-24	7:43:00 AM	58	No	Construction noise, general foot traffic and chatter
Outside Burt Neilson	22-Oct-24	7:44:00 AM	58.5	No	Construction noise, general foot traffic and chatter
Outside Sleep Clinic	29-Oct-24	9:18:00 AM	65.5	No	Construction noise, general traffic noise from road, general foot traffic and chatter
Outside Radiology	29-Oct-24	9:18:00 AM	47.7	No	Construction noise, general foot traffic and chatter
Outside Burt Neilson	29-Oct-24	9:40:00 AM	56.4	No	Construction noise, general foot traffic and chatter