


# Noise Monitoring - St George Hospital Stage 3

Review Date: 31/07/2024



Level	Date	Time	Decibels (dBA)	Noise Exceedance (Yes/No)	Comments
Outside Sleep Clinic	02-Jul-24	11:11:00 AM	66.1	No	Construction noise, general foot traffic and chatter, general foot traffic and chatter
Outside Radiology	02-Jul-24	11:14:00 AM	46.2	No	Construction noise, general foot traffic and chatter
Outside Burt Neilson	02-Jul-24	11:14:00 AM	57.3	No	Construction noise, general foot traffic and chatter
Outside Sleep Clinic	09-Jul-24	11:24:00 AM	64.8	No	Construction noise, general traffic noise from road, general foot traffic and chatter
Outside Radiology	09-Jul-24	11:29:00 AM	49.9	No	Construction noise, general foot traffic and chatter
Outside Burt Neilson	09-Jul-24	11:30:00 AM	57.5	No	Construction noise, general foot traffic and chatter
Outside Sleep Clinic	18-Jul-24	11:00:00 AM	66.4	No	Construction noise, general traffic noise from road, general foot traffic and chatter
Outside Radiology	18-Jul-24	10:57:00 AM	59.1	No	Construction noise, general foot traffic and chatter
Outside Burt Neilson	18-Jul-24	10:58:00 AM	59.4	No	Construction noise, general foot traffic and chatter
Outside Sleep Clinic	25-Jul-24	11:11:00 AM	65.7	No	Construction noise, general traffic noise from road, general foot traffic and chatter
Outside Radiology	25-Jul-24	11:14:00 AM	54.5	No	Construction noise, general foot traffic and chatter
Outside Burt Neilson	25-Jul-24	11:14:00 AM	58	No	Construction noise, general foot traffic and chatter

**KEY:**

- OUTSIDE SLEEP CLINIC 
- OUTSIDE BURT NEILSON 
- OUTSIDE RADIOLOGY 

**KENSINGTON ST**

**SGH3**

**SITE AMENITIES**

-  AED
-  FIRST AID ROOM
- 

**BELGRAVE ST**

