

Noise Monitoring - St George Hospital Stage 3

Review Date: 20/12/2024



Level	Date	Time	Decibels (dBA)	Noise Exceedance (Yes/No)	Comments
Outside Sleep Clinic	04-Dec-24	8:07:00 AM	66.4	No	Construction noise, general foot traffic and chatter, general foot traffic and chatter
Outside Radiology	04-Dec-24	8:10:00 AM	42	No	Construction noise, general foot traffic and chatter
Outside Burt Neilson	04-Dec-24	8:11:00 AM	59.7	No	Construction noise, general foot traffic and chatter
Outside Sleep Clinic	10-Dec-24	8:55:00 AM	67	No	Construction noise, general traffic noise from road, general foot traffic and chatter
Outside Radiology	10-Dec-24	8:57:00 AM	48.6	No	Construction noise, general foot traffic and chatter
Outside Burt Neilson	10-Dec-24	8:59:00 AM	57.7	No	Construction noise, general foot traffic and chatter
Outside Sleep Clinic	19-Dec-24	8:03:00 AM	65.7	No	Construction noise, general traffic noise from road, general foot traffic and chatter
Outside Radiology	19-Dec-24	8:07:00 AM	50.2	No	Construction noise, general foot traffic and chatter
Outside Burt Neilson	19-Dec-24	8:10:00 AM	59.9	No	Construction noise, general foot traffic and chatter

KEY:

- OUTSIDE SLEEP CLINIC
- OUTSIDE BURT NEILSON
- OUTSIDE RADIOLOGY

KENSINGTON ST

SGH3

AED

FIRST AID ROOM

SITE AMENITIES

BELGRAVE ST