

## BCA Crown Certificate

Pursuant to Section 6.28 of the Environmental Planning & Assessment Act 1979

<b>Certificate No.</b>	CRO-23076	
<b>Date of Certificate</b>	06 September 2023	
<b>+ Subject Land</b>		
<b>Lot + DP</b>	Lot 101	DP 1119583
<b>Address</b>	The Children's Hospital at Westmead Corner of Hawkesbury Road & Hainsworth Street WESTMEAD NSW 2145	
<b>Local Government Area</b>	Parramatta City Council	
<b>+ Applicant</b>		
<b>Name</b>	Anna Chernih	
<b>Company</b>	Health Infrastructure NSW	
<b>Address</b>	1 Reserve Road, ST LEONARDS NSW 2065	
<b>Phone</b>	0408 702 690	<b>Email</b> anna.chernih@health.nsw.gov.au
<b>+ Owner</b>		
<b>Name</b>	Sydney Children Hospital Network	
<b>Address</b>	5 Fleet Street NORTH PARRAMATTA NSW 2151	
<b>Phone</b>	(02) 9840 3000	
<b>+ Description of Development</b>		
<b>Description</b>	<p>The Children's Hospital at Westmead - Paediatric Services Building comprising:</p> <ul style="list-style-type: none"> <li>+ Demolition, earthworks, remediation and tree removal</li> <li>+ Construction and operation of a 14 level Paediatric Services Building</li> <li>+ Extension of the existing medical gas compound</li> <li>+ Weather protection awning and pedestrian connections to the adjacent Central Acute Services Building and Kids Research Building</li> <li>+ Expansion and refurbishment of the pathology building</li> <li>+ Retails pods, landscaping, public domain works and signage zones</li> </ul> <p><b>Stage 3 Crown Certificate</b> - Construction of the building façade</p> <p><i>1. This staged BCA Crown Certificate has been issued for the building works described above only. Separate BCA Crown Certificate/s will be required prior to commencement of any subsequent works.</i></p> <p><i>2. This BCA Crown Certificate excludes any external ancillary services, structures or civil works required by relevant authorities.</i></p>	
<b>BCA Classification</b>	Class 3, 5, 6, 7a & 9a	
<b>Applicable BCA</b>	Building Code of Australia 2019 (Amendment 1)	
<b>Development Consent</b>	Consent Number: 10349252	Date: 15 December 2021
<b>Statutory Certification</b>	Pursuant to the provisions of Section 6.28 of the Environmental Planning and Assessment Act 1979, Blackett Maguire + Goldsmith Pty Ltd hereby certifies that the building works have been designed in accordance with the Building Code of Australia 2019 (Amendment 1), subject to the attached Conditions.	
<b>Referenced Documentation</b>	Refer to Schedule 1	
<b>Conditions and Exclusions</b>	Refer to Schedule 2	
<b>Fire Safety Schedule</b>	Refer to Schedule 3	

**+ Details of Crown Certifier**

**Crown Certifier** Blackett Maguire + Goldsmith Pty Ltd

**Registration Number** RBC00004

**Signature**

**Signed on Behalf of BM+G** Crown Certifier's Name David Blackett

Registration Number: BDC0032

Liability limited by a scheme approved under Professional Standards Legislation

## + Schedule 1 – Schedule of Documentation

### Referenced Plans

#### + Architectural Plans prepared by Billard Leece Partnership Pty Ltd

+ Drawing Number	+ Rev	+ Date	+ Drawing Number	+ Rev	+ Date
19038 CHW-AR-DG-PSB-19-02001	1	09.12.2022	19038 CHW-AR-DG-PSB-19-02002	1	09.12.2022
19038 CHW-AR-DG-PSB-19-03001	1	09.12.2022	19038 CHW-AR-DG-PSB-19-03002	1	09.12.2022
19038 CHW-AR-DG-PSB-19-04001	1	09.12.2022	19038 CHW-AR-DG-PSB-19-04002	1	09.12.2022
19038 CHW-AR-DG-PSB-19-05001	1	09.12.2022	19038 CHW-AR-DG-PSB-19-05002	1	09.12.2022
19038 CHW-AR-DG-PSB-19-06001	1	09.12.2022	19038 CHW-AR-DG-PSB-19-06002	1	09.12.2022
19038 CHW-AR-DG-PSB-19-07001	1	09.12.2022	19038 CHW-AR-DG-PSB-19-07002	1	09.12.2022
19038 CHW-AR-DG-PSB-19-08001	1	09.12.2022	19038 CHW-AR-DG-PSB-19-08002	1	09.12.2022
19038 CHW-AR-DG-PSB-19-09001	1	09.12.2022	19038 CHW-AR-DG-PSB-19-09002	1	09.12.2022
19038 CHW-AR-DG-PSB-19-10001	1	09.12.2022	19038 CHW-AR-DG-PSB-19-10002	1	09.12.2022
19038 CHW-AR-DG-PSB-19-11001	1	09.12.2022	19038 CHW-AR-DG-PSB-19-11002	1	09.12.2022
19038 CHW-AR-DG-PSB-19-12001	1	09.12.2022	19038 CHW-AR-DG-PSB-19-12002	1	09.12.2022
19038 CHW-AR-DG-PSB-19-13001	1	09.12.2022	19038 CHW-AR-DG-PSB-19-13002	1	09.12.2022
19038 CHW-AR-DG-PSB-19-14001	1	09.12.2022	19038 CHW-AR-DG-PSB-19-14002	1	09.12.2022
19038 CHW-AR-DG-PSB-19-15001	1	09.12.2022	19038 CHW-AR-DG-PSB-19-XX001	1	09.12.2022
19038 CHW-AR-DG-PSB-19-XX002	1	09.12.2022	19038 CHW-AR-DG-PSB-19-XX003	1	09.12.2022
19038 CHW-AR-DG-PSB-19-XX004	1	09.12.2022	19038 CHW-AR-DG-PSB-19-XX010	1	09.12.2022
19038 CHW-AR-DG-PSB-19-XX101	1	09.12.2022	19038 CHW-AR-DG-PSB-19-XX102	1	09.12.2022
19038 CHW-AR-DG-PSB-20-EL001	1	09.12.2022	19038 CHW-AR-DG-PSB-20-EL002	1	09.12.2022
19038 CHW-AR-DG-PSB-20-EL003	1	09.12.2022	19038 CHW-AR-DG-PSB-20-EL004	1	09.12.2022
19038 CHW-AR-DG-PSB-21-EL001	1	09.12.2022	19038 CHW-AR-DG-PSB-21-EL002	1	09.12.2022
19038 CHW-AR-DG-PSB-21-EL003	1	09.12.2022	19038 CHW-AR-DG-PSB-21-EL004	1	09.12.2022

19038 CHW-AR-DG-PSB-21-EL011	1	09.12.2022	19038 CHW-AR-DG-PSB-21-EL012	1	09.12.2022
19038 CHW-AR-DG-PSB-21-EL021	1	09.12.2022	19038 CHW-AR-DG-PSB-21-EL031	1	09.12.2022
19038 CHW-AR-DG-PSB-21-EL041	1	09.12.2022	19038 CHW-AR-DG-PSB-21-EL042	1	09.12.2022
19038 CHW-AR-DG-PSB-21-EL043	1	09.12.2022	19038 CHW-AR-DG-PSB-21-EL101	1	09.12.2022
19038 CHW-AR-DG-PSB-21-EL102	1	09.12.2022	19038 CHW-AR-DG-PSB-21-EL103	1	09.12.2022
19038 CHW-AR-DG-PSB-21-EL104	1	09.12.2022	19038 CHW-AR-DG-PSB-21-EL105	1	09.12.2022
19038 CHW-AR-DG-PSB-21-EL106	1	09.12.2022	19038 CHW-AR-DG-PSB-21-EL107	1	09.12.2022
19038 CHW-AR-DG-PSB-21-EL108	1	09.12.2022	19038 CHW-AR-DG-PSB-21-EL109	1	09.12.2022
19038 CHW-AR-DG-PSB-21-EL201	1	09.12.2022	19038 CHW-AR-DG-PSB-21-EL202	1	09.12.2022
19038 CHW-AR-DG-PSB-21-EL203	1	09.12.2022	19038 CHW-AR-DG-PSB-21-EL204	1	09.12.2022
19038 CHW-AR-DG-PSB-21-EL211	1	09.12.2022	19038 CHW-AR-DG-PSB-21-EL212	1	09.12.2022
19038 CHW-AR-DG-PSB-30-SE001	1	09.12.2022	19038 CHW-AR-DG-PSB-30-SE002	1	09.12.2022
19038 CHW-AR-DG-PSB-30-SE003	1	09.12.2022	19038 CHW-AR-DG-PSB-30-SE004	1	09.12.2022
19038 CHW-AR-DG-PSB-30-SE005	1	09.12.2022	19038 CHW-AR-DG-PSB-31-SE001	1	09.12.2022
19038 CHW-AR-DG-PSB-31-SE002	1	09.12.2022	19038 CHW-AR-DG-PSB-31-SE003	1	09.12.2022
19038 CHW-AR-DG-PSB-31-SE101	1	09.12.2022	19038 CHW-AR-DG-PSB-31-SE111	1	09.12.2022
19038 CHW-AR-DG-PSB-31-SE121	1	09.12.2022	19038 CHW-AR-DG-PSB-31-SE131	1	09.12.2022
19038 CHW-AR-DG-PSB-31-SE151	1	09.12.2022	19038 CHW-AR-DG-PSB-31-SE152	1	09.12.2022
19038 CHW-AR-DG-PSB-31-SE201	1	09.12.2022	19038 CHW-AR-DG-PSB-31-SE202	1	09.12.2022
19038 CHW-AR-DG-PSB-31-SE203	1	09.12.2022	19038 CHW-AR-DG-PSB-42-XX200	1	09.12.2022
19038 CHW-AR-DG-PSB-42-XX210	1	09.12.2022	19038 CHW-AR-DG-PSB-42-XX221	1	09.12.2022
19038 CHW-AR-DG-PSB-42-XX222	1	09.12.2022	19038 CHW-AR-DG-PSB-42-XX225	1	09.12.2022
19038 CHW-AR-DG-PSB-42-XX233	1	09.12.2022	19038 CHW-AR-DG-PSB-42-XX242	1	09.12.2022
19038 CHW-AR-DG-PSB-42-XX252	1	09.12.2022	19038 CHW-AR-DG-PSB-90-XX002	1	09.12.2022

## Documentation Relied Upon

In conjunction with the approved plans and specifications the following documentation was relied upon in issuing the BCA Crown Certificate:

### + Documentation:

+ Item	+ Documentation	+ Prepared by	+ Date
1.	Crown Certificate Application Form	Health Infrastructure NSW	20 April 2023
2.	Letter requesting the issue of the Staged 3 Crown Certificate	Roberts Co (NSW) Pty Ltd	06 September 2023
3.	Facade Design Statement	Meinhardt Façade Technology Pty Ltd	17 May 2023
4.	External Wall System Disclosure Statement	Sharvain Facades Pty Ltd	05 April 2023
5.	Facade Design Statement	Sharvain Facades Pty Ltd	28 March 2023
6.	FP1.4 Performance Solution Report	Prism Design Pty Ltd	30 August 2023
7.	Facade Performance Specification	Meinhardt-Bonacci	02 March 2023
8.	Section J Part J1 JV3 Report	E-LAB Consulting	28 June 2023
9.	Section J Design Statement	E-LAB Consulting	24 January 2023
10.	Architectural Design Statement	Billard Leece Partnership Pty Ltd	13 February 2023
11.	Statement of Compliance	Roberts Co (NSW) Pty Ltd	06 September 2023
12.	Certificate of Test No. FNC11629	CSIRO	04 February 2016
13.	Reaction-to-Fire Test Report No. RFT200379	Warringtonfire Australia	09 December 2020
14.	GALVABOND® Steel Data Sheet	BlueScope Steel Limited	October 2020

## + Schedule 2 – Conditions and Exclusions

---

This Crown Certificate has been issued subject to the following conditions:

1. This Crown Certificate does not certify compliance with the Conditions of the Development Consent No. 10349252 dated 17 December 2021. The building works should not commence until the Crown is satisfied that the relevant conditions of the Development Consent that are a pre-requisite to commencement have been appropriately addressed where relevant.
2. Once the signage for the development has been selected, the External Wall Disclosure Statement is to be updated to include the signage details.
3. There is to be no impact, disruption, impediment or modification to existing active or passive fire safety systems or egress arrangements within the existing hospital building as a direct or indirect result of the proposed works without prior consultation and approval by the LHD (as applicable) and the crown certifier (BM+G).
4. All building works associated with the subject development are to be carried out in accordance with the requirements of the Blackett Maguire + Goldsmith BCA Assessment Report Revision 9 dated 21 September 2021.
5. Demolition works are to be undertaken in accordance with the documentation listed in Schedule 1 & AS 2601-2001.
6. Where the proposed demolition works necessitate the isolation and/or decommissioning of any existing fire services, particularly the fire hydrant system or the sprinkler system, then Fire & Rescue NSW and any relevant insurance providers should be notified prior to de-commissioning and/or isolation of the system.
7. No approval is given nor implied for the construction of works beyond the scope specifically approved by the Stage 3 Crown Certificate.
8. All building works associated with the subject development are to be carried out in accordance with the approved documentation listed above in Schedule 1.  
  
Any departure from the documentation cannot be undertaken without the review and approval by Blackett Maguire + Goldsmith.
9. Where there is any conflict between the Design Documentation and the advice provided by Blackett Maguire + Goldsmith, the advice issued takes precedence unless approved by Blackett Maguire + Goldsmith.
10. Any changes to the Architectural Documentation that may affect compliance with the Building Code of Australia or the referenced Australian Standards are to be appropriately disclosed to Blackett Maguire + Goldsmith for review.
11. Blackett Maguire + Goldsmith are to be contacted throughout the project for routine site inspections to ensure that the works are being carried out in accordance with the approved documentation.

## + Schedule 3 – Fire Safety Schedule

Part 10 of the Environmental Planning and Assessment Act (Development Certification and Fire Safety) Regulation 2021.

Please note:

- + A fire safety Schedule must deal with the whole of the building not just part of the building

### Section 1: Location of building

Address (Street No., Street Name, Suburb and Postcode)

CORNER OF HAWKESBURY ROAD & HAINSWORTH STREET, WESTMEAD NSW 2145

Lot No. (if known) CP/DP/SP No. (if known) Building name (if applicable)

LOT 101 DP 1119583 THE CHILDREN'S HOSPITAL AT WESTMEAD

### Section 2: Reissue of Fire Safety Schedule (Section 80A of the Regulation)

- Not applicable – Fire Safety Schedule is not being re-issued.
- Reissued Fire Safety Schedule (please state reason below)

*Reason for Reissue of Schedule*

- Original Schedule Lost or Destroyed
- Correction of errors or omissions.

### Section 3: Reference Details (Section 78 of the Regulation)

Reference Type

Reference Number (if known)

DEVELOPMENT CONSENT

10349252

### Section 4: Fire Safety Measures for the building – excluding Critical Fire Safety Measures (Section 79 of the Regulation)

+ Item No.	+ Fire safety measure	+ Minimum standard of performance
<b>Current (Existing)</b>		
1.	N/A	

<b>Proposed (New or Modified including section 84(6) of the Regulation)</b>		
1.	ACCESS PANELS, DOORS & HOPPERS	BCA CLAUSE C3.13 & AS 1530.4 – 2014 AND MANUFACTURER'S SPECIFICATIONS
2.	ALARM SIGNALLING EQUIPMENT	AS 1670.3 – 2018
3.	AUTOMATIC FAIL SAFE DEVICES	BCA CLAUSE D2.21
4.	AUTOMATIC FIRE DETECTION & ALARM SYSTEM	BCA SPEC. E2.2a AS 1670.1 – 2018
5.	AUTOMATIC FIRE SUPPRESSION SYSTEMS	BCA SPEC. E1.5 AS 2118.1 – 2017 AS 2118.6 – 2012
6.	EMERGENCY LIFTS	BCA CLAUSE E3.4 AS 1735.2 – 2001
7.	EMERGENCY LIGHTING	BCA CLAUSE E4.4 AS 2293.1 – 2018
8.	EMERGENCY EVACUATION PLAN	AS 3745

Proposed (New or Modified including section 84(6) of the Regulation)		
9.	EMERGENCY WARNING & INTERCOMMUNICATION SYSTEM (EWIS)	BCA E4.9 AS1670.4 - 2018
10.	EXIT SIGNS	BCA CLAUSES E4.5, E4.6 & E4.8 AS 2293.1 – 2018
11.	FIRE CONTROL ROOM	BCA SPEC E1.8
12.	FIRE BLANKETS	AS 3504 – 2006 AS2444 – 2001
13.	FIRE DAMPERS	BCA CLAUSE C3.15 AS 1668.1 – 2015 AS 1682.1 & 2 – 2015 MANUFACTURER'S SPECIFICATION
14.	FIRE DOORS	BCA CLAUSE C2.12, C2.13, C3.4, C3.5, C3.7, C3.8 & C3.11 AS 1905.1 – 2015 MANUFACTURER'S SPECIFICATION
15.	FIRE HOSE REELS	BCA CLAUSE E1.4 AS 2441 – 2005
16.	FIRE HYDRANT SYSTEMS	CLAUSE E1.3 AS 2419.1 – 2005
17.	FIRE SEALS	BCA CLAUSE C3.15 AS 1530.4 – 2014 AS 4072.1 – 2005 m MANUFACTURER SPECIFICATION
18.	LIGHTWEIGHT CONSTRUCTION	BCA CLAUSE C1.8 AS 1530.4 – 2014 MANUFACTURER'S SPECIFICATION
19.	MECHANICAL AIR HANDLING SYSTEMS (SHUTDOWN)	BCA CLAUSE E2.2 AS/NZS 1668.1 – 2015 AS 1668.2 – 2012
20.	PATHS OF TRAVEL	EP&A REGULATION CLAUSE 186
21.	PORTABLE FIRE EXTINGUISHERS	BCA CLAUSE E1.6 AS 2444 – 2001
22.	PRESSURISING SYSTEMS	BCA CLAUSE E2.2 AS/NZS 1668.1 – 2015
23.	REQUIRED EXIT DOORS (POWER OPERATED)	BCA CLAUSE D2.19(b)
24.	SMOKE HAZARD MANAGEMENT SYSTEMS – ZONE SMOKE CONTROL SYSTEM	BCA PART E2 AS/NZS 1668.1 –2015
25.	SMOKE DAMPERS	AS/NZS 1668.1 – 2015
26.	SMOKE DOORS	BCA SPEC C3.4 & C2.5
27.	STAND-BY POWER SYSTEMS	BCA CLAUSE E1.3, E3.4, E4.2 & E4.5 AS 3000 – 2018
28.	WALL-WETTING SPRINKLERS	AS 2118.2 – 2010
29.	WARNING & OPERATIONAL SIGNS	SECTION 183 OF THE EP&A REGULATION 2000 AS 1905.1 – 2015



<b>Proposed (New or Modified including section 84(6) of the Regulation)</b>	
	BCA CLAUSE D2.23, D3.6 & E3.3

**Details of Fire Safety Building Code of Australia (BCA) Performance Solutions Report(s)**

+ (Ref No./Title of report/Author/Date)	+ BCA Performance Requirement(s)	+ BCA DtS Provision(s) and details of non-compliance
N/A		

**Section 5: Critical Fire Safety Measures – where applicable to the building (Section 79 of the Regulation)**

Note: A critical fire safety measure is one where the performance is verified at intervals of less than 12 months through the submission of a supplementary fire safety statement.

+ Item No.	+ Fire safety measure	+ Minimum standard of performance
<b>Current (Existing)</b>		
1.	N/A	

<b>Proposed (New or Modified)</b>		
1.	N/A	

**Section 6: Details of approved exemptions from compliance with BCA standards for a relevant fire safety system (Section 74 of the Regulation)**

+ Item No.	+ Relevant fire safety measures	+ Description of exemption
1.	N/A	

**Section 7: Name of authority or registered certifier issuing this schedule**

Name	Organisation (Business name)
DAVID BLACKETT	BLACKETT MAGUIRE + GOLDSMITH PTY LTD
Business Address (Street No., Street Name, Suburb and Postcode)	
SUITE 2.01, 22-36 MOUNTAIN ST, ULTIMO NSW 2007	
Registration Number (Where Applicable)	
RBC00004 (BDC0032)	
Date of Issue	
<b>6/09/2023</b>	

**Please note:**

The following information is provided to help persons completing this fire safety schedule (FSS) template and does not comprise part of the form. The following pages do not have to be displayed in the building or submitted to the local Council or the Commissioner of Fire and Rescue NSW or attached to any fire safety certificate or annual fire safety statement.

### General

- Please print in CAPITAL LETTERS and complete all relevant sections in full.
- A reference to 'the Regulation' is a reference to the Environmental Planning and Assessment (Development Certification and Fire Safety) Regulation 2021.
- The completed fire safety schedule form must be attached to the relevant application.
- An earlier fire safety schedule is superseded by a later fire safety schedule and ceases to have effect when the later fire safety schedule is issued.
- A fire safety schedule must deal with the whole of the building and not only the part of the building to which the development consent, complying development certificate, construction certificate or fire safety order relates.
- Further information about building fire safety is available on the 'Fire safety' page of the Department's website at <https://www.fairtrading.nsw.gov.au/housing-and-property/reforms-to-fire-safety-regulation-2022>.

### Section 1: Description of the building

- The address and other property details should be provided here.

### Section 2: Reissue of Fire Safety Schedule

- The purpose of this section is to specify whether the fire safety schedule is a new schedule or a schedule that has been reissued under section 80A of the Regulation.
- An initial fire safety schedule issued when a Development Consent, Complying Development Certificate, Construction Certificate, or a fire safety order is issued is not taken to be a re-issued Schedule.
- The re-issue of a fire safety schedule may occur because the original schedule was lost or destroyed or to correct errors or omissions in the fire safety schedule.
- It must be noted that a fire safety schedule cannot be reissued under section 80A of the Regulation if the error or omission is due to building work or a change in plans or specifications for the fire safety measures of the building.
- A private certifier **cannot** re-issue a schedule under s80A after an occupation certificate has been issued by the certifier.
- A council that reissues a fire safety schedule where the 'original' was not required to be in the approved form does not need to issue the replacement schedule on the approved form. Instead, a council may reissue the schedule in the same form as the schedule being replaced.

### Section 3: Reference Details

- Provide details of the relevant reference document by selecting the relevant type from the drop-down list.
- The reference number of the relevant Development Consent, Construction Certificate, Complying Development Certificate or Fire Safety Order Reference must be listed where known.
- For ease of use only one reference to a relevant document type is necessary for filling out this part. It is unnecessary to reference multiple Development Consents, staged CCs, or CDCs that are/or were once applicable to the building over its lifetime.

### Section 4: Fire Safety Measures currently implemented OR proposed to be implemented for the building

- The purpose of this section is to identify those current and proposed fire safety measures that must be implemented for the building.

#### Fire safety measures

- A proposed fire safety measure is taken to be either a required measure not currently installed in the building or an existing measure which is being altered.
- Fire safety measures include both statutory fire safety measures and other fire safety measures. The statutory fire measures are specified in section 79(4) of the Regulation and include portable fire extinguishers, fire hydrants, fire sprinklers, fire detection and alarm systems and lightweight construction.
- Other fire safety measures could include any measure that is specific to the building such as those required as part of a fire safety Building Code of Australia (BCA) performance solution for the building.

#### Minimum standard of performance

- The minimum standard of performance for a fire safety measure describes the technical specification for the design, installation and operation of the measures. The minimum standard of performance is generally determined by the BCA and should not be confused with the specified maintenance activities which are used for maintenance of a fire safety measure.
- Where noting the minimum standard of performance for a fire safety measure (FSM) care needs to be taken to ensure relevant details are provided. When expressing a minimum standard of performance for a FSM the following referencing sequence should be used: (the Building Code of Australia (BCA) edition applicable to the FSM, then any relevant BCA Deemed-to-Satisfy Clause(s) or Specification(s), then any relevant Reference Document(s) (such as Australian Standards) and the applicable edition (year) of that Referenced Standard.

- If an application relates only to a part of a building and the required fire safety measures and their associated minimum standard of performance varies from other parts of the building, the fire safety schedule must clearly identify the different fire safety measures and/or different standards of performance in a building.

#### Using the table

- If there are no existing fire safety measures specify 'Nil' in the first row under both 'Current' and 'Minimum standard of performance'. The remaining rows of the table under 'Current' can be deleted.
- If there are no proposed fire safety measures specify 'Nil' in the first row under both 'Proposed' and 'Minimum standard of performance'. The remaining rows of the table under 'Proposed' can be deleted.
- Additional rows can be added under 'Current' and 'Proposed' measures if required.

#### Performance solutions

- The fire safety schedule must identify all fire safety measures that are required as part of a fire safety BCA performance solution, including any reference to the BCA performance solution report document when specifying the standard of performance for each measure.
- Provide identifying details of any fire engineered BCA performance solution report(s) relevant to those corresponding fire safety measures in the table 'Details of Building Code of Australia Performance Solution Report(s)'.
- Details including the author of the report, the relevant BCA performance requirements about which the report demonstrates compliance, and a brief description of the relevant BCA deemed-to-satisfy provision(s) considered are to be provided here.

#### **Section 5: Critical Fire Safety Measures currently implemented OR proposed to be implemented in the building**

- The purpose of this section is to identify those current or proposed critical fire safety measures for the building.
- A critical fire safety measure is a measure that requires periodic assessment and certification at intervals of less than 12 months, because of its nature, the environment, or other circumstances.
- Not all buildings will be subject to critical fire safety measures and this section must only be filled out where a building has critical fire safety measures as identified by the registered certifier (council or private) or appropriate authority.
- Each critical fire safety measure and the associated minimum standard of performance must be listed.
- The intervals, of less than 12 months, at which the critical fire safety measure must be assessed and requiring the submission of a supplementary fire safety statement must also be specified.
- It is up to the registered certifier (council or private) or appropriate authority to identify what is a critical fire safety measure and the frequency in which a supplementary fire safety statement is required to be lodged to the council.
- If there are no applicable critical fire safety measures insert 'Nil' in the row under 'Current', 'Proposed' and 'Minimum standard of performance'. The remaining rows of the table under 'Current' and 'Proposed' can be deleted.
- Additional rows can be added to the table if required.

#### **Section 6: Exemption from BCA standard for a relevant fire safety system**

- The purpose of this section is to identify in accordance with section 23(3)(b) of the Regulation any exemptions from BCA standards for the fire safety building work granted under a construction certificate by a certifier resulting from an objection under section 74 of the Regulation.
- Objections made under this provision relate to the operational performance of a relevant fire safety system.
- A relevant fire safety system is defined by the Regulation and can be either a hydraulic fire system, a fire detection and alarm system, or a mechanical ducted smoke control system.
- In this section the applicant must specify the relevant fire safety measure to which an exemption applies. In addition, a detailed description of the exemption is to be provided.
- If there are no exemptions relevant to the building insert 'Nil' in the first row under both 'Relevant Fire Safety System' and 'Details of the exemption'. The remaining rows of the table can be deleted.
- Additional rows may be added to the table if required.

#### **Section 7: Name and contact details of the person issuing the schedule**

- The purpose of this section of the form is to include details of the person or authority that is issuing the schedule.
- Where the fire safety schedule is issued by a registered certifier details of the registration number of the certifier are to be provided.
- The date of issue must also be included on the fire safety schedule.

---

© State of New South Wales through the Department of Customer Service 2023. Information contained in this publication is based on knowledge and understanding at the time of writing (May 2023) and is subject to change. For more information, please visit <https://www.nsw.gov.au/nsw-government/copyright>

---

## + Inspection and Certification Schedule

---

### Required Inspections

The following inspections must be undertaken during the construction program.

- + Completion of smoke proof walls prior to the installation of set ceilings / ceiling tiles throughout each level of the building.
- + Completion of fire rated walls prior to the installation of set ceilings / ceiling tiles throughout each level of the building.
- + Completion of fire rated shafts throughout the building.
- + Completion of sealing of service penetrations through fire and smoke walls throughout each level of the building.
- + Installation of concealed essential fire safety measures prior to covering throughout each level of the building.
- + Installation of essential fire safety measures below the ceiling throughout each level of the building.
- + Completion of internal fitout works including sanitary facilities, joinery and furniture throughout each level of the building.
- + Preliminary Final Inspection and onsite testing of all active fire safety systems as part of system commissioning works.
- + After all the building works has been completed.