

## CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

03 May 2023

**Attention:** Jason Simionato  
**Company:** Theos Bros. (Aust) Pty Ltd  
**Email:** jason@tbagroup.com.au  
**Address:** Suite 3/52-54 McEvoy St, Waterloo NSW 2017

**SWE Report Reference:** S111573.5-AAM1.v1-03/05/2023  
**Site Address:** Children's Hospital at Westmead - PSB site  
**Sampling Date:** 03/05/2023  
**Sample Analysis Date:** 03/05/2023  
**Period of Sampling:** 03/05/2023 08:18 AM - 03/05/2023 03:22 PM  
**Scope of Work:** Air monitoring during disturbance of ACM in north end of site  
**SWE Laboratory:** Suite 15, 103 Majors Bay Road, Concord NSW 2137

**Accreditation number:** 17092                      **Site number:** 18665

**1. Introduction:** Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

**2. Methods:** Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

### 3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S111573.5/S576/030523	NW of removal area	0.0/100	<0.01
S111573.5/S195/030523	SW end of removal area adjacent decon	0.0/100	<0.01
S111573.5/S192/030523	South of removal area	0.0/100	<0.01
S111573.5/S528/030523	East of removal area	0.0/100	<0.01
S111573.5/S807/030523	Field Blank	0.0/100	NA

**4. Conclusion:** All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

### Analysed and reported by:



**Rune Knoph**  
Analyst



**Rune Knoph**  
Approved Issuer of Reports

## CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

04 May 2023

Accredited for compliance  
with ISO/IEC 17025 -  
Testing

**Attention:** Jason Simionato  
**Company:** Theos Bros. (Aust) Pty Ltd  
**Email:** denny@tbagroup.com.au  
**Address:** Suite 3/52-54 McEvoy St, Waterloo NSW 2017

**SWE Report Reference:** S111573.6-AAM1.v1-04/05/2023  
**Site Address:** Children's Hospital at Westmead - PSB site  
**Sampling Date:** 04/05/2023  
**Sample Analysis Date:** 04/05/2023  
**Period of Sampling:** 04/05/2023 07:00 AM - 04/05/2023 02:53 PM  
**Scope of Work:** Air monitoring during civil work disturbing asbestos impacted soil  
**SWE Laboratory:** Suite 15, 103 Majors Bay Road, Concord NSW 2137

**Accreditation number:** 17092                      **Site number:** 18665

**1. Introduction:** Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

**2. Methods:** Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

### 3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S111573.6/2117/040523	North West of Removal Area	0.0/100	<0.01
S111573.6/S1019/040523	SW end of removal area adjacent decon	0.0/100	<0.01
S111573.6/S1056/040523	South of removal area	0.0/100	<0.01
S111573.6/S824/040523	East of removal area	0.0/100	<0.01
S111573.6/S240/040523	Field Blank	0.0/100	NA

**4. Conclusion:** All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

### Analysed and reported by:



**Rune Knoph**  
Analyst



**Rune Knoph**  
Approved Issuer of Reports

## CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

05 May 2023

**Attention:** Jason Simionato  
**Company:** Theos Bros. (Aust) Pty Ltd  
**Email:** denny@tbagroup.com.au  
**Address:** Suite 3/52-54 McEvoy St, Waterloo NSW 2017

**SWE Report Reference:** S111573.7-AAM1.v1-05/05/2023  
**Site Address:** Children's Hospital at Westmead - PSB site  
**Sampling Date:** 05/05/2023  
**Sample Analysis Date:** 05/05/2023  
**Period of Sampling:** 05/05/2023 07:05 AM - 05/05/2023 02:43 PM  
**Scope of Work:** Air monitoring during civil work disturbing asbestos impacted soil  
**SWE Laboratory:** Suite 15, 103 Majors Bay Road, Concord NSW 2137

**Accreditation number:** 17092                      **Site number:** 18665

**1. Introduction:** Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

**2. Methods:** Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

### 3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S111573.7/S1046/050523	North West of Removal Area	0.0/100	<0.01
S111573.7/S1002/050523	SW end of removal area adjacent decon	0.0/100	<0.01
S111573.7/S224/050523	South of removal area	0.0/100	<0.01
S111573.7/S335/050523	East of removal area	0.0/100	<0.01
S111573.7/S1056/050523	Field Blank	0.0/100	NA

**4. Conclusion:** All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

### Analysed and reported by:



**Rune Knoph**  
Analyst



**Rune Knoph**  
Approved Issuer of Reports

## CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

08 May 2023

**Attention:** Jason Simionato  
**Company:** Theos Bros. (Aust) Pty Ltd  
**Email:** denny@tbagroup.com.au  
**Address:** Suite 3/52-54 McEvoy St, Waterloo NSW 2017

**SWE Report Reference:** S111573.8-AAM1.v1-08/05/2023  
**Site Address:** Children's Hospital at Westmead - PSB site  
**Sampling Date:** 08/05/2023  
**Sample Analysis Date:** 08/05/2023  
**Period of Sampling:** 08/05/2023 07:25 AM - 08/05/2023 12:28 PM  
**Scope of Work:** Air monitoring during asbestos removal work at North end of PSB  
**SWE Laboratory:** Suite 15, 103 Majors Bay Road, Concord NSW 2137

**Accreditation number:** 17092                      **Site number:** 18665

**1. Introduction:** Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

**2. Methods:** Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

### 3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S111573.8/S198/080523	South west of removal area	0.0/100	<0.01
S111573.8/S1011/080523	SW end of removal area adjacent decon	0.0/100	<0.01
S111573.8/S656/080523	South of removal area	0.0/100	<0.01
S111573.8/S092/080523	East of removal area	0.0/100	<0.01
S111573.8/S224/080523	Field Blank	0.0/100	NA

**4. Conclusion:** All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

### Analysed and reported by:



**Rune Knoph**  
Analyst



**Rune Knoph**  
Approved Issuer of Reports

## CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

11 May 2023

**Attention:** Jason Simionato  
**Company:** Theos Bros. (Aust) Pty Ltd  
**Email:** jason@tbagroup.com.au  
**Address:** Suite 3/52-54 McEvoy St, Waterloo NSW 2017

**SWE Report Reference:** S111573.9-AAM1.v1-11/05/2023  
**Site Address:** Children's Hospital at Westmead - PSB site  
**Sampling Date:** 11/05/2023  
**Sample Analysis Date:** 11/05/2023  
**Period of Sampling:** 11/05/2023 06:50 AM - 11/05/2023 03:15 PM  
**Scope of Work:** Air monitoring during disturbance of asbestos soil  
**SWE Laboratory:** Suite 15, 103 Majors Bay Road, Concord NSW 2137

**Accreditation number:** 17092                      **Site number:** 18665

**1. Introduction:** Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

**2. Methods:** Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

### 3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S111573.9/S087/110523	NW of removal area	0.0/100	<0.01
S111573.9/S546/110523	SW of removal area adjacent decon unit	0.0/100	<0.01
S111573.9/S408/110523	South of removal area	1.0/100	<0.01
S111573.9/S447/110523	East of removal area	0.0/100	<0.01
S111573.9/S566/110523	Field Blank	0.0/100	NA

**4. Conclusion:** All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

### Analysed and reported by:



**Rune Knoph**  
Analyst



**Rune Knoph**  
Approved Issuer of Reports

## CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

12 May 2023

**Attention:** Jason Simionato  
**Company:** Theos Bros. (Aust) Pty Ltd  
**Email:** jason@tbagroup.com.au  
**Address:** Suite 3/52-54 McEvoy St, Waterloo NSW 2017

**SWE Report Reference:** S111573.10-AAM1.v1-12/05/2023  
**Site Address:** Children's Hospital at Westmead - PSB site  
**Sampling Date:** 12/05/2023  
**Sample Analysis Date:** 12/05/2023  
**Period of Sampling:** 12/05/2023 07:03 AM - 12/05/2023 03:17 PM  
**Scope of Work:** Air monitoring during disturbance of asbestos soil  
**SWE Laboratory:** Suite 15, 103 Majors Bay Road, Concord NSW 2137

**Accreditation number:** 17092                      **Site number:** 18665

**1. Introduction:** Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

**2. Methods:** Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

### 3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S111573.10/S173/120523	Northwest of removal area	0.0/100	<0.01
S111573.10/S174/120523	Adjacent decon unit, SW of removal area	0.0/100	<0.01
S111573.10/S106/120523	South of removal area	0.0/100	<0.01
S111573.10/S008/120523	East of removal area	0.0/100	<0.01
S111573.10/S005/120523	Field Blank	0.0/100	NA

**4. Conclusion:** All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

### Analysed and reported by:



**Rune Knoph**  
Analyst



**Rune Knoph**  
Approved Issuer of Reports

## CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

15 May 2023

**Attention:** Jason Simionato  
**Company:** Theos Bros. (Aust) Pty Ltd  
**Email:** denny@tbagroup.com.au  
**Address:** Suite 3/52-54 McEvoy St, Waterloo NSW 2017

**SWE Report Reference:** S111573.11-AAM1.v1-15/05/2023  
**Site Address:** Children's Hospital at Westmead - PSB site  
**Sampling Date:** 15/05/2023  
**Sample Analysis Date:** 15/05/2023  
**Period of Sampling:** 15/05/2023 07:00 AM - 15/05/2023 03:24 PM  
**Scope of Work:** Air monitoring during disturbance of asbestos soil - North end PSB  
**SWE Laboratory:** Suite 15, 103 Majors Bay Road, Concord NSW 2137

**Accreditation number:** 17092                      **Site number:** 18665

**1. Introduction:** Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

**2. Methods:** Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

### 3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S111573.11/S528/150523	NW of removal area	0.0/100	<0.01
S111573.11/S195/150523	SW of removal area adjacent decontamination unit	0.0/100	<0.01
S111573.11/S087/150523	South of removal area	0.0/100	<0.01
S111573.11/S576/150523	East of removal area	0.0/100	<0.01
S111573.11/S1011/150523	Field blank	0.0/100	NA

**4. Conclusion:** All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

### Analysed and reported by:



**Rune Knoph**  
Analyst



**Rune Knoph**  
Approved Issuer of Reports

## CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

16 May 2023

**Attention:** Jason Simionato  
**Company:** Theos Bros. (Aust) Pty Ltd  
**Email:** jason@tbagroup.com.au  
**Address:** Suite 3/52-54 McEvoy St, Waterloo NSW 2017

**SWE Report Reference:** S111573.12-AAM1.v1-16/05/2023  
**Site Address:** Children's Hospital at Westmead - PSB site  
**Sampling Date:** 16/05/2023  
**Sample Analysis Date:** 16/05/2023  
**Period of Sampling:** 16/05/2023 07:00 AM - 16/05/2023 11:15 AM  
**Scope of Work:** Air monitoring during disturbance of asbestos soil - North end PSB  
**SWE Laboratory:** Suite 15, 103 Majors Bay Road, Concord NSW 2137

**Accreditation number:** 17092                      **Site number:** 18665

**1. Introduction:** Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

**2. Methods:** Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

### 3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S111573.12/S566/160523	NW end of removal area	0.0/100	<0.01
S111573.12/S240/160523	SW of removal area adjacent decontamination unit	0.0/100	<0.01
S111573.12/S447/160523	South of removal area	0.0/100	<0.01
S111573.12/S092/160523	East of removal area	0.0/100	<0.01
S111573.12/S576/160523	Field Blank	0.0/100	NA

**4. Conclusion:** All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

### Analysed and reported by:



**Rune Knoph**  
Analyst



**Rune Knoph**  
Approved Issuer of Reports



## CONTROL AIR MONITORING FOR ASBESTOS FIBRES RESULTS

18 May 2023

**Attention:** Jason Simionato  
**Company:** Theos Bros. (Aust) Pty Ltd  
**Email:** denny@tbagroup.com.au  
**Address:** Suite 3/52-54 McEvoy St, Waterloo NSW 2017

**SWE Report Reference:** S111573.13-AAM1.v1-18/05/2023  
**Site Address:** Children's Hospital at Westmead - PSB site  
**Sampling Date:** 18/05/2023  
**Sample Analysis Date:** 18/05/2023  
**Period of Sampling:** 18/05/2023 07:20 AM - 18/05/2023 01:48 PM  
**Scope of Work:** Air monitoring during disturbance of asbestos soil  
**SWE Laboratory:** Suite 15, 103 Majors Bay Road, Concord NSW 2137

**Accreditation number:** 17092                      **Site number:** 18665

**1. Introduction:** Control monitoring for airborne asbestos fibres was undertaken by Safe Work and Environments Pty Ltd (SWE) is used to verify the effectiveness of control measures implemented to prevent fibre release as a result of asbestos removal/related work.

**2. Methods:** Airborne asbestos fibre monitoring was carried out in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres, 2nd Edition [NOHSC:3003 (2005)] and SWE's In-House Method 2 – Volume Measurement, Calibration and Standardisation. Analysis of collected filter membrane samples was performed in accordance with NOHSC:3003 (2005) and SWE's In-House Method 1 – Asbestos Fibre Count and Mount.

### 3. Results:

SWE REF.	LOCATION OF SAMPLE	FIBRES/ FIELDS	CONCENTRATION (FIBRES/mL)
S111573.13/S101/180523	NW of removal area	0.0/100	<0.01
S111573.13/S436/180523	SW of removal area adjacent decontamination unit	0.0/100	<0.01
S111573.13/S1051/180523	South of removal area	0.0/100	<0.01
S111573.13/S620/180523	East of removal area	0.0/100	<0.01
S111573.13/S576/180523	Field Blank	0.0/100	NA

**4. Conclusion:** All air monitoring analytical results reported on in this report are below the lowest detectable level of 0.01 fibres/mL of air.

### Analysed and reported by:



**Rune Knoph**  
Analyst



**Rune Knoph**  
Approved Issuer of Reports