

Noise Monitoring - St George Hospital Stage 3

Review Date: 30/04/2024



Level	Date	Time	Decibels (dBa)	Noise Exceedance (Yes/No)	Comments
Outside Sleep Clinic	03-Apr-24	12:21:32PM	65.4	No	Construction noise, general foot traffic and chatter, general foot traffic and chatter
Outside Radiology	03-Apr-24	12:26:54PM	56.1	No	Construction noise, general foot traffic and chatter
Outside Burt Neilson	03-Apr-24	12:26:16PM	58.2	No	Construction noise, general foot traffic and chatter
Outside Sleep clinic	11-Apr-24	12:33:42PM	63.7	No	Construction noise, general traffic noise from road, general foot traffic and chatter
Outside Burt Neilson	11-Apr-24	12:36:02PM	56.6	No	Construction noise, general foot traffic and chatter
Outside Radiology	11-Apr-24	12:36:24PM	53.9	No	Construction noise, general foot traffic and chatter
Outside Sleep Clinic	15-Apr-24	12:03:39PM	63.3	No	Construction noise, general foot traffic and chatter
Outside Radiology	15-Apr-24	12:12:20PM	55.8	No	Construction noise, general foot traffic and chatter
Outside Burt Neilson	15-Apr-24	12:12:08PM	59.4	No	Construction noise, general foot traffic and chatter
Outside Sleep Clinic	23-Apr-24	17:47:00PM	66.9	No	Construction noise, general traffic noise from road, general foot traffic and chatter
Outside Radiology	23-Apr-24	17:48:45PM	43.5	No	Construction noise, general foot traffic and chatter
Outside Burt Neilson	23-Apr-24	17:49:00PM	54.1	No	Construction noise, general foot traffic and chatter

KEY:
OUTSIDE SLEEP CLINIC ●
OUTSIDE BURT NEILSON ●
OUTSIDE RADIOLOGY ●

KENSINGTON ST

SGH3

SITE AMENITIES
AED
FIRST AID ROOM

BELGRAVE ST